

Cruse And Associates, P.A.

Engineering Services



October 30, 2024
Mr. Bradley Gardner
Ample Storage
P. O. Box 608
225 Peden Rd.
Smithfield, NC 27577

RE: Job #24-23, Ample Storage "Apartment", Erwin, North Carolina

The masonry fire wall detail 3/F-1 is being deleted from sheet F-1 of 3 by this letter. It is acceptable to replace this detail with a 4 hour rated, masonry wall detail provided by Betco for this project. See attached.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Randy L. Cruse', written over the printed name.

Randy L. Cruse, PE



