

# APPENDIX G

## DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

**Project Information:**

Residential Single-Family Project: Yes	Commercial Project: No
Code Enforcement Project No:	Permit No: SFD 2409-0078
Project Name:	Owner:
Project Address: Lot 371 Oakmont Subdivision 24 Tackett Court, Harnett County, NC	Suite No:
Date Inspected: 12-08-2024	Contractor Name: Ascot Homes
Component Inspected: Stem Foundation Wall	

**Responsible Licensed NC Architect or NC Engineer**

Name:	Britt McCurry		
Firm Name:	B.A. McCurry Engineering		
Phone Numbers:	Office: 336.223.4604	Mobile:	
Email Address:	britt.mccurry@bamccurryengineering.com 329		
Mailing Address:	Brinkley Cir, Mebane, NC 27302		

**APPLICABLE CODE:**

2018 NC Residential Code

*2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code*

Describe Element/Component/Type of Inspection: \*

CMU block walls were observed to be 8-inch CMU on the upper courses with 12-inch CMU block on the lower sections. The base of the wall was measured from the probed footing edges indicating adequate footing projection

*\*(subgrade form/letter may also be required)*

**Attestation/Signature:**

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.

Britt McCurry



Licensed Architect or Engineer 12-08-2024



**Inspection Department disclaimer:**

Upon the receipt of a signed written document as required under subsection (a) of G.S. 160D-11-1, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.