

October 15th, 2024

Red Door Homes
12809 Hwy 70 Business West
Clayton, NC 27520

RE: Existing Tank Application #SFD2409-0099

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank fully and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Need site plan

4. Other – Existing septic system is designed for a 3 bedroom not 4 bedroom. Application can be revised to 3 bedroom or you will need to apply for a septic system expansion, must have property lines marked every 50' and corner irons demonstrated, will be required to have septic contractor to locate and demonstrate septic drain lines from start to end. If the option chosen is to expand septic system then EH will need to take another soil evaluation.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy - Central Permitting