## Harnett County Department of Public Health

PERMIT # SFD 2410-0027 **Operation Permit** Mew Installation 🗷 Septic Tank 🗷 Nitrification Line 🗆 Repair 🗆 Expansion PROPERTY LOCATION: 151 Towelers way (SR 1116)

SUBDIVISION COLEMONT Phose of B LOT # 336 Calement Holding inc System Installer: Garage Number of Bedrooms 4 (8 people) Basement with plumbing: Public Well Distance from well Type of Water Supply: 

Community TYPS IT 6 System Type: Types V and VI Systems expire in 5 years. (In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal. This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization. PERMIT CONDITIONS: Travelers Way -> Performance: System shall perform in accordance with Rule . 1961. II. As required by Rule .1961. Monitoring: III. Maintenance: As required by Rule .1961. Other: Subsurface system operator required? Yes \( \square\) No \( \square\) If yes, see attached sheet for additional operation conditions, maintenance and reporting. IV. Operation: Other: D-Box □ Alarm □ \_\_\_\_ Pump H20Line **PWR Line** Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: 

Conventional

Other

Type of system: Septic Tank: gallons Pump Tank: Subsurface No. of exact length width of of each ditch 374 Drainage Field ditches ditches inches French Drain Required: Linear feet Authorized State Agent Date

## Oakmont - Lot #336 4-Bedroom "As Built" 151 Travelers Way - Harnett County Ascot Corporation, LLC PIN# 0507-63-2681 \*At time of installation septic installer modified the system as shown on this drawing. Modifications "Approved" by Alex Adams System: Gravity to Serial Distribution Lines: 1-5 (374' total) LTAR: 0.35 \*Not a Survey 18" Max Trench Bottom Sketched from a plot plan supplied by owner Accepted Status System Repair: Gravity to D-Box Lines: 6-10 (375') LTAR: 0.35 18" Max Trench Bottom Accepted Status System 10.0 S 88°28'21" E 395.85 35.0 **TRAVELERS WAY** (LOT 336) 302.2 0.920 Acres 40,072 Sq. Ft. 10.0 N 88°28'21" W 405.24 \*\*1000 Gallon Septic and Pump Tank Tank and trenches to be located minimum of 10' from any property line and minimum of 5' from any building foundation. \*Do Not Cut, Fill, or Alter Drainfield or Repair Area \*Comply with all setbacks \*Contact local health dept. and/or Alex Adams prior to or during installation with any questions or concerns. Adams Soil Consulting 1" = 50'919-414-6761 Job #1968 10-10-25