



May 7, 2025

Zachary Cabe
Vuncannon & Sons Builders, Inc.
112 Strickland Lane
Lillington, NC 27546
Email: zwc@vuncannonandsonsbuilderinc.com

Reference: Engineering Services
2950 Leaflet Church Road
Broadway, NC 27505
TE&D Project No.: 2501-020287_A

To Whom It May Concern;

As requested by the client, a representative of Tyndall Engineering & Design, PA (TE&D) is providing comments on the following items:

1. Projection repairs per our letter previously sealed on 4/15/2025.

The following conclusions and recommendations were noted:


1. Based on our observations of photos provided to us by the client, the projection repairs were completed in general accordance with our specifications in our letter sealed on 4/15/2025. The completed repairs are suitable and the newly placed concrete will provide the required support for the anticipated loading conditions.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design

Tripp Amos
PT III | 2501-020287_A

Prentice Tyndall Jr., P.E.





Example of repairs completed



Additional example of repairs completed