

Owner/Legal Representative Signature: ___

HARNETT COUNTY ENVIROMENTAL HEALTH

File/Permit #: SFD2411-0036

IMPROVEMENT PERMIT (IP) CDP #:		
	stem Relocation	
	ot Identifier: 0645-47-5835.000	
Subdivision: LAKE VIEW	4 Block: Section:	
Facility Type: SFD 24' x 24' Number of bedrooms: 1 Number of	of Occupants: 2 Other: System is designed for future 2-BR	
Design Daily Flow: 240 GPD LTAR (Initial): .6 gpd/ft²		
Wastewater System Type: 25% Reduction System		
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Initial): 48"		
Wastewater System Type 25% Reduction System		
Pump Required: Yes No May be required Usable Depth to	Limiting Condition (Repair): 48"	
Effluent Standard: DSE HSE Other: Type of Water Supply	: Private well Municipal Supply Other:	
Permit conditions: No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area.		
The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responding requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The In This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit is subject to revocation if the site plan, plat, or the intended use changes.	provement Permit shall not be affected by a change in ownership of the site. nit.	
Authorized Agent's Printed Name: Ren Levocz	Date: 07/14/2025	
Authorized Agent's Signature:	Expiration Date: <u>07/14/2030</u>	
CONSTRUCTION AUTHORIZATION (CA)		
	stem Relocation Change of Use sant: LEE RICHARD DALE	
Property Location: 9006 CHRISTIAN LIGHT RD FUQUAY VARINA, NC 27526 PIN/L	ot Identifier: 0645-47-5835.000	
Subdivision: LAKE VIEW Lot #	4 Block: Section:	
Facility Type: SFD 24' x 24' Number of bedrooms: 1 Number	of Occupants: 2 Other: System is designed for future 2-BR	
Design Daily Flow: 240 GPD LTAR: .6 gpd/ft²		
Effluent Standard: DSE HSE Other: Type of Water Supply	: Private well Municipal Supply Other:	
Installation Requirements/Conditions		
Wastewater System Type: 25% Reduction System	Pump Required: Yes No May be required	
Septic Tank Size: 1,000 gallons Total Trench Length: 120' feet	Trench Spacing: 9' feet on center	
Pump Tank Size: 1,000 gallons Maximum Trench Depth: 18"-28" inches		
Trench Width: 36" inches Distribution Method: Serial D-Bo	x or Parallel Pressure Manifold Other: 2 - 60' Lines	
Artificial Drainage Required: Yes No III If yes, please specify details:		
Management Entity Required: Yes No Minimum O&M Requirements:		
Permit conditions: No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area. Route Water Line on Left Side of Drive Way as Shown on Site Sketch.		
The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. <u>This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.</u> The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.		
Authorized Agent's Printed Name: Ren Levocz	Date: 07/14/25	
Authorized Agent's Signature: hu has LEH'S	Expiration Date: 07/14/2030	

Date: __

SITE SKETCH

_{PIN} 0645-47-5835.000

Permit Number SFD2411-0036

LEE RICHARD DALE	LAKE VIEW Lot 4	
Applicant's Name	Subdivision/Section/Lot Number	
Ren Levocz	07/14/2025	
Authorized State Agent	Date	

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

