

RE: 4439145 - HSE#227 TRAVELERS WAY

Trenco
818 Soundside Rd
Edenton, NC 27932

Site Information:

Project Customer: THE ASCOT CORPORATION Project Name:
Lot/Block: 340 Subdivision: OAKMONT
Address: HSE#227 TRAVELERS WAY
City: LILINGTON State: NC

Name Address and License # of Structural Engineer of Record, If there is one, for the building.

Name: License #:
Address:
City, County: State:

General Truss Engineering Criteria & Design Loads (Individual Truss Design Drawings Show Special Loading Conditions):

Design Code: IRC2015/TPI2014 Design Program: MiTek 20/20 8.8
Wind Code: ASCE 7-10 Design Method: MWFRS (Envelope)/C-C hybrid Wind ASCE 7-10
Wind Speed: 115 mph
Roof Load: 40.0 psf Floor Load: N/A psf

This package includes 1 individual, dated Truss Design Drawings and 0 Additional Drawings.

No.	Seal#	Job ID#	Truss Name	Date
1	I73101301	4439145	A2A	4/29/25

The truss drawing(s) referenced above have been prepared by
Truss Engineering Co. under my direct supervision based on the parameters
provided by Builders FirstSource (Albermarle,NC).

Truss Design Engineer's Name: Delbert, Ryan

My license renewal date for the state of North Carolina is December 31, 2025.

IMPORTANT NOTE: The seal on these truss component designs is a certification that the engineer named is licensed in the jurisdiction(s) identified and that the designs comply with ANSI/TPI 1. These designs are based upon parameters shown (e.g., loads, supports, dimensions, shapes and design codes), which were given to MiTek or TRENCO. Any project specific information included is for MiTek's or TRENCO's customers file reference purpose only, and was not taken into account in the preparation of these designs. MiTek or TRENCO has not independently verified the applicability of the design parameters or the designs for any particular building. Before use, the building designer should verify applicability of design parameters and properly incorporate these designs into the overall building design per ANSI/TPI 1, Chapter 2.



April 29, 2025

Delbert, Ryan

RE: \$JOBNAME - \$JOBDESC

Trenco
818 Soundside Rd
Edenton, NC 27932

Site Information:

Project Customer: \$SI_CUSTOMER Project Name: \$SI_JOBNAME
Lot/Block: \$SI_LOTNUM Subdivision: \$SI_SUBDIV
Address: \$SI_SITEADDR
City, County: \$SI_SITECITY State: \$SI_SITESTATE

RE: \$JOBNAME - \$JOBDESC

Trenco
818 Soundside Rd
Edenton, NC 27932

Site Information:

Project Customer: \$SI_CUSTOMER Project Name: \$SI_JOBNAME
Lot/Block: \$SI_LOTNUM Subdivision: \$SI_SUBDIV
Address: \$SI_SITEADDR
City, County: \$SI_SITECITY State: \$SI_SITESTATE


Job	Truss	Truss Type	Qty	Ply	HSE#227 TRAVELERS WAY	173101301
4439145	A2A	Common	3	1	Job Reference (optional)	

Builders FirstSource (Albermarle), Albermarle, NC - 28001,


Run: 8.83 S Apr 11 2025 Print: 8.830 S Apr 11 2025 MiTek Industries, Inc. Tue Apr 29 10:07:26

Page: 1

ID:8iptF?B7TQfOLECN_jwCzhKpk-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



SEE NOTES 1-2 FOR REPAIR CONDITIONS.



Scale = 1:100.6

Plate Offsets (X, Y): [2:Edge,0-0-5], [10:Edge,0-0-5]

Loading	(psf)	Spacing	2-0-0	CSI	DEFL	in	(loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.35	Vert(LL)	-0.12	15-16	>999	360	MT20
Snow (Pf/Pg)	7.0/10.0	Lumber DOL	1.15	BC	0.57	Vert(CT)	-0.20	17-19	>999	240	244/190
TCDL	10.0	Rep Stress Incr	YES	WB	0.47	Horz(CT)	0.01	13	n/a	n/a	
BCLL	0.0*	Code	IRC2015/TPI2014	Matrix-MSH		Wind(LL)	0.02	18	>999	240	
BCDL	10.0										

Weight: 242 lb FT = 20%

LUMBER

TOP CHORD	2x4 SP No.1
BOT CHORD	2x6 SP No.2 *Except* 18-15:2x4 SP No.2
WEBS	2x4 SP No.2
WEDGE	Left: 2x4 SP No.2
	Right: 2x4 SP No.2

BRACING

TOP CHORD	Structural wood sheathing directly applied or 5-6-13 oc purlins.
BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing. Except:
	6-0-0 oc bracing: 12-13.
WEBS	1 Row at midpt 6-15

REACTIONS

(size)	2=0-3-8, 10=0-3-8, 13=0-3-8
Max Horiz	2=123 (LC 16)
Max Uplift	2=33 (LC 16), 10=53 (LC 17)
Max Grav	2=856 (LC 34), 10=492 (LC 35), 13=1968 (LC 3)

FORCES

(lb) - Maximum Compression/Maximum Tension	
TOP CHORD	1-2=0/25, 2-3=-1210/47, 3-5=-779/30, 5-6=-778/130, 6-7=0/429, 7-9=-393/141, 9-10=-491/89, 10-11=0/25
BOT CHORD	2-21=-98/1014, 19-21=-89/1014, 17-19=-17/185, 13-17=-17/185, 12-13=-169/84, 10-12=-5/379, 16-18=-13/58, 15-16=-13/58
WEBS	3-21=0/87, 5-19=-374/160, 6-15=-1110/35, 13-15=-1129/6, 7-13=-596/186, 7-12=-80/556, 18-19=-101/1002, 6-18=-72/1035, 3-19=-475/126, 9-12=-320/133, 16-17=-203/0

NOTES

- 1) Repair Condition: web has 0-1-0 long break centered at 0-2-6 above joint 21.


- 2) Attach 14"H X 12"W X 1/2" Plywood or OSB (15/32" APA Rated Sheathing 32/16 Exposure 1) gusset to both sides of truss at joint 21 with 8d (0.131"x2.5") nails from each face, driven through both sheets of plywood. Connected together as follows: 2x6 - 2 rows 0-8-0 o.c., 2x4 - 1 rows 0-4-0 o.c. Minimum 0-3-0 end distance.

- 3) n/a

- 4) Unbalanced roof live loads have been considered for this design.
- 5) Wind: ASCE 7-10; Vult=115mph (3-second gust) Vasd=91mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; Cat. II; Exp B; Enclosed; MWFRS (envelope) exterior zone and C-C Exterior (2) -0-11-0 to 2-8-2, Interior (1) 2-8-2 to 17-11-8, Exterior (2) 17-11-8 to 21-6-10, Interior (1) 21-6-10 to 36-10-0 zone; cantilever left and right exposed ;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- 6) TCLL: ASCE 7-10; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=10.0 psf (ground snow); Pf=7.0 psf (flat roof snow: Lum DOL=1.15 Plate DOL=1.15); Category II; Exp B; Partially Exp.; Ct=1.00
- 7) Unbalanced snow loads have been considered for this design.
- 8) This truss has been designed for greater of min roof live load of 12.0 psf or 2.00 times flat roof load of 7.0 psf on overhangs non-concurrent with other live loads.
- 9) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 10) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-06-00 tall by 2-00-00 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.

- 11) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 33 lb uplift at joint 2 and 53 lb uplift at joint 10.

LOAD CASE(S) Standard



April 29, 2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.


Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Symbols

PLATE LOCATION AND ORIENTATION



* Plate location details available in MITek software or upon request.

PLATE SIZE

4 X 4


The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

LATERAL BRACING LOCATION



Indicated by symbol shown and/or by text in the bracing section of the output. Use T or I bracing if indicated.


BEARING



Indicates location where bearings (supports) occur. Icons vary but reaction section indicates joint number/letter where bearings occur. Min size shown is for crushing only.

Industry Standards:
ANSI/TP1: National Design Specification for Metal Plate Connected Wood Truss Construction.
DSB-22: Building Component Safety Information, Guide to Good Practice for Handling, Installing, Restraining & Bracing of Metal Plate Connected Wood Trusses.

Numbering System



JOINTS ARE GENERALLY NUMBERED/LETTERED CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.

CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.

Product Code Approvals

ICC-ES Reports:
ESR-1988, ESR-2362, ESR-2685, ESR-3282
ESR-4722, ESL-1388

Design General Notes

Trusses are designed for wind loads in the plane of the truss unless otherwise shown.
Lumber design values are in accordance with ANSI/TP1 section 6.3. These truss designs rely on lumber values established by others.

© 2023 MITek® All Rights Reserved

General Safety Notes

Failure to Follow Could Cause Property Damage or Personal Injury

1. Additional stability bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative Tor I bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by ANSI/TP1 1.
7. Design assumes trusses will be suitably protected from the environment in accord with ANSI/TP1 1.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with ANSI/TP1 1 Quality Criteria.
21. The design does not take into account any dynamic or other loads other than those expressly stated.

MITek®

ENGINEERING BY
TRENCO
A MITek Affiliate

MITek Engineering Reference Sheet: MII-7473 rev. 1/2/2023