

Harnett County Department of Public Health

PERMIT # SFD 2411-0085

Operation Permit

☒ New Installation ☒ Septic Tank ☒ Nitrification Line ☐ Repair ☐ Expansion

PROPERTY LOCATION: 654 Thomas Gage, Fuquay

SUBDIVISION Birchwood Grove

LOT # 41

Name: (owner) KB Hams

System Installer: David Bantley

Basement with plumbing: ☐ Garage ☒ Number of Bedrooms 3

Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well _____ feet


System Type: 25% Reduction Type III(b) Jet Chambers Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

** Needs pump + Alarm
For final*



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes ☐ No ☐
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

- IV. Operation: _____
- V. Other: _____

☐ D-Box ☐ Pump ☐ Alarm ☐ H2O Line ☐ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: ☐ Conventional ☒ Other Type III(b) Jet Chambers Septic Tank: 1,400 gallons Pump Tank: 1,400 gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 1 of each ditch 278' feet ditches 3' feet ditches 18" inches
French Drain Required: _____ Linear feet

Authorized State Agent REHS

Date 3-26-25