



Permit Inspections

Harnett County

Permit Number: **SFD2411-0091**

Description: **50' x 75' SFD 3 Bed, 2.5 Bath**

Applied: **11/26/2024**

Approved: **12/3/2024**

Site Address: **232 LOOPING CT**

Issued: **12/3/2024**

Finalized:

City, State Zip Code: **ANGIER, NC 27501**

Status: **ISSUED**

Applicant: **Davidson Homes, LLC**

Parent Permit:

Owner: **BC SMOKE A LITTLE SMOKE LLC**

Parent Project:

Contractor: **Davidson Homes, LLC**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
			GAS PIPING	Deen Taylor		
Notes:						
			TEMP POWER CERTIFICATION	Deen Taylor		
Notes:						
	12/16/2024	12/16/2024	FOUNDATION	Scott Guy	FAIL W/ PENALTY	eTRAKiT Inspection Request
Notes: 12/12/2024 1:41 PM Davidson Homes, LLC Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com Work not done.						
	12/16/2024	12/16/2024	FOOTING	Scott Guy	DISAPPROVED	eTRAKiT Inspection Request
Notes: 12/12/2024 1:40 PM Davidson Homes, LLC 3rd Partied Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com Footing covered, no inspection or third party on file.						



Permit Inspections

Harnett County

	12/18/2024	12/18/2024	FOOTING	Deen Taylor	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>12/17/2024 11:13 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p> <p>Eng letter in attachments.</p>						
	12/18/2024	12/18/2024	FOUNDATION	Deen Taylor	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>12/17/2024 11:13 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p> <p>Eng letter in attachments.</p>						
	12/30/2024	12/30/2024	OPEN FLOOR	Steven Gazlay	CANCELLED	eTRAKiT Inspection Request
<p>Notes:</p> <p>12/27/2024 11:56 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p> <p>Per Don, not ready.</p>						
	12/30/2024	12/30/2024	WATER CONNECTION	Steven Gazlay	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>12/27/2024 11:49 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						
	1/2/2025	1/2/2025	OPEN FLOOR	Steven Gazlay	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>12/31/2024 8:13 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						



Permit Inspections

Harnett County

	1/27/2025	1/27/2025	ROUGH IN	Steven Gazlay	DISAPPROVED	eTRAKiT Inspection Request
--	-----------	-----------	----------	---------------	-------------	----------------------------

<p>Notes:</p> <p>1/24/2025 9:12 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p> <p>No plumbing pressure test,DWV test or pan tests. Provide engineering and repairs on broken trusses.</p>						
--	--	--	--	--	--	--

	2/14/2025	2/14/2025	ROUGH IN REINSPECT	Scott Guy	DISAPPROVED	eTRAKiT Inspection Request
--	-----------	-----------	-----------------------	-----------	-------------	----------------------------

<p>Notes:</p> <p>2/13/2025 10:44 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p> <p>1/ Repair 1 (A5) repairs not per letter 2/ (8th truss from left second vertical repair does not include break at the top of the member. This area may not have been observed during engineering visit and should require a gusset for repair. Due to the multitude of damaged truss here and repairs for first couple done per engineering requirements. I recommend the engineer co come back out to observe their requirements are met. Also please have the firm identify each repair with the truss ID if possible. Ok to insulate</p>						
--	--	--	--	--	--	--

	2/25/2025	2/25/2025	ROUGH IN REINSPECT	Steven Gazlay	CANCELLED	eTRAKiT Inspection Request
--	-----------	-----------	-----------------------	---------------	-----------	----------------------------

<p>Notes:</p> <p>2/24/2025 9:21 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						
---	--	--	--	--	--	--

	2/27/2025	2/27/2025	ROUGH IN REINSPECT	Steven Gazlay	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	-----------------------	---------------	----------	----------------------------

<p>Notes:</p> <p>2/26/2025 8:34 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						
---	--	--	--	--	--	--



Permit Inspections

Harnett County

	3/5/2025	3/5/2025	T-POLE	Scott Guy	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>3/4/2025 12:15 PM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p> <p>Inspector SPG changed the inspection assignment from SPG to TSG</p>						
	3/14/2025	3/14/2025	SEWER CONNECTION	Scott Guy	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>3/13/2025 7:40 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						
20	2/3/2025	2/3/2025	AS BUILT SURVEY	Michelle Myatt	APPROVED	Needed
<p>Notes:</p>						
30	2/25/2025	2/25/2025	INSULATION	Steven Gazlay	CANCELLED	eTRAKiT Inspection Request
<p>Notes:</p> <p>2/24/2025 9:20 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						
30	2/27/2025	2/27/2025	INSULATION REINSPECTION	Steven Gazlay	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>2/26/2025 8:34 AM Davidson Homes, LLC</p> <p>Contact Name: Davidson Homes, LLC Site Address: 232 LOOPING CT Phone: 2563501322 e-Mail: mstephens@davidsonhomesllc.com</p>						
30	3/12/2025	3/12/2025	ENVIR OPERATIONS PERMIT	Reynold J Levocz	APPROVED	
<p>Notes:</p>						
50			FINAL SFD CRAWL**	Deen Taylor		
<p>Notes:</p>						