

PERMIT # SFD 2412-0053

☒ New Installation ☒ Septic Tank ☒ Nitrification Line ☐ Repair ☐ Expansion

Name: (owner) Miller Jeremy

SUBDIVISION Captains Landing LOT # 36

System Installer: Zack Seibert

Basement with plumbing: ☐ Garage ☐ Number of Bedrooms 3


Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well \_\_\_\_\_ feet

System Type: 25% Reduction System Type II (g) chamber (Types V and VI Systems expire in 5 years).

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other:

Subsurface system operator required? Yes ☐ No ☐

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation:

V. Other:

☐ \_\_\_\_\_ D-Box    ☐ \_\_\_\_\_ Pump    ☐ \_\_\_\_\_ Alarm    ☐ \_\_\_\_\_ H2O Line    ☐ \_\_\_\_\_ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: ☐ Conventional ☒ Other Type III (9) Jet pumps Septic Tank: 1,000 gallons Pump Tank: — gallons

Subsurface  
Drainage Field

No. of  
ditches 3

exact length  
of each ditch 102' feet

width of  
ditches 3 feet

depth of  
ditches 18" 22" inches

French Drain Required: \_\_\_\_\_ Linear feet

Authorized State Agent Paul J. DEHS

Date 5-21-25