

britt.mccurry@bamccurryengineering.com

Mebane, NC, Firm: P-1819

03-04-2025

Client: Adams Homes, 149 US Hwy 70 West, Garner, NC

Kipling Creek Subdivision: ATTN: Marty Stephenson: martystephenson2008@gmail.com,

raleighclosing@adamshomes.com, raleighpermits@adamshomes.com, bjohnson@adamshomes.com

Field Observation: Subgrade Testing

Re-Test: No Creep: No

Lot #: 39 Kipling Creek Subdivision Address: 127 High Hampton Way

Project #: 25PG0304J BAM

County: Harnett County
Permit #: SFD25010017

OFESSIO

4. McCU

At your request, B.A. McCurry Engineering, PLLC (BAM) visited the site on 03-04-2025 to test the subgrade for the fill at the above referenced home site. The fill was tested with a Dynamic Cone Penetrometer (DCP) test in accordance with the ASTM special publication 399 and probed with a steel probe rod for comparison to the test locations.

The fill consisted of: red sandy clay And was tested to a depth of 1 ft.

Based on testing and observation, the subgrade prepared for the footing excavations at property above is of adequate bearing capacity to support the proposed loads (2,000 psf) of the home. If you have any questions about this report, please email or call.

Britt McCurry, PE 03-04-2025

ritt McCurry

This report is intended exclusively for the client's use. B.A. McCurry Engineering (BAM) accepts no liability for its use or interpretation by any third party. Parties with an interest in this property are advised to obtain an independent professional evaluation tailored to their requirements. Should unforeseen conditions or substantial deviations from the specified scope of work arise during repairs, please notify BAM prior to continuing.

