



May 15, 2025

Blake Farley
RiverWILD
114 W. Main Street
Clayton, NC 27513
Email: blake@stayWILD.com

Reference: Engineering Services
Permit #SFD2501 0032
Stewart Farms – Lot 4
3943 Baileys Crossroads Road
Benson, NC 27504
TE&D Project No.: 2501-020210_A

To Whom It May Concern:

As requested, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following item(s):

- 1) Valley members located above the garage not properly bearing at support locations.

The following conclusions and recommendations were noted:

- 1) Based on our observations and analysis, the existing valley members located above the garage are adequate as constructed to support the anticipated loading conditions.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design



Sean M. Holmes
SMH | 2501-020210_A

Scott Pyrch, P.E.

