

Sheet:
Property ID:
Lot #:
File #:
Code:

Owner: Wellco Applicant:

Owner: Wellco Applicant:

Address: 512 Blackgun

Proposed Facility: *SFD*

Location of Site:

Water Supply:

Evaluation Method: ☒ Auger

Type of Wastewater:

Date Evaluated:

Design Flow (.1949): 480 GPD

Property Size:

Property Recorded:

☒ Public ☐ Individual ☐ Well☐ Spring☐ Other☐ Pit☐ Cut☐ Industrial Process☐ Mixed

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>SMA</i> Others Present: <i>REHS</i>
Available Space (.1945)	☒	☒	
System Type(s)	☒	☒	
Site LTAR	.6	.6	

COMMENTS: _____

LANDSCAPE POSITIONS

R-RIDGE
S-SHOULDER SLOPE
L-LINEAR SLOPE
FS-FOOT SLOPE
N-NOSE SLOPE
H-HEAD SLOPE
CC-CONCLAVE SLOPE
CV-CONVEX SLOPE
T-TERRACE
FP-FLOOD PLAN

GROUPTEXTURES.1955 LTARCONSISTENCE MOISTWET

I	S-SAND LS-LOAMY SAND	1.2 - 0.8
II	SL-SANDY LOAM L-LOAM	0.8 - 0.6
III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3
IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1

VFR-VERY FRIABLE
FR-FRIABLE
FI-FIRM
VFI-VERY FIRM
EFI-EXTREMELY FIRM

NS-NON-STICKY
SS-SLIGHTLY STICKY
S-STICKY
VS-VERY STICKY
NP-NON-PLASTIC
SP-SLIGHTLY STICKY
P-PLASTIC
VP-VERY PLASTIC

STRUCTURE

SG-SINGLE GRAIN
M-MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY

SLIGHTLY EXPANSIVE
EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

