

# North Carolina 2018 - Simulated Performance Alternative (N1105)

## Property

TBD Grove Township Way  
Angier, NC 27501  
Model: Russell 9'  
Community: Langdon Preserve

Mungo Homes Langdon Preserve Lot 16  
TBD Grove Township Way Lot 16

## Organization

Builder i Group  
Noe Montalvo

## Builder

Mungo Homes

## Inspection Status

Results are projected

**This report is based on a proposed design and does not confirm field enforcement of design elements.**

## Annual Energy Cost

Design	North Carolina 2018 Performance	As Designed
Heating	\$844	\$815
Cooling	\$268	\$238
Water Heating	\$290	\$290
Mechanical Ventilation	\$0	\$0
<b>SubTotal - Used to determine compliance</b>	<b>\$1,402</b>	<b>\$1,343</b>
Lights & Appliances w/out Ventilation	\$618	\$618
Onsite generation	\$0	\$0
<b>Total</b>	<b>\$2,020</b>	<b>\$1,961</b>

null Source Energy Exception: The proposed home uses 5.23 MBtu LESS source energy than the reference home.


## Requirements

✓	R405.3	Performance-based compliance passes by 4.9%	The proposed house meets the North Carolina 2018 Performance reference energy bill requirement by \$58.94 (5.23 MBtu).
✓	R402.4.2.2	Air Leakage Testing	Air sealing is 5.00 ACH at 50 Pa. It must not exceed 5.00 ACH at 50 Pa.
✓	R402.5	Area-weighted average fenestration SHGC	Area-weighted average fenestration SHGC is 0.22. The maximum allowed value is [No Limit].
✓	R402.5	Area-weighted average fenestration U-Factor	
✓	R404.1	Lighting Equipment	
✓	Mandatory Checklist	Mandatory code requirements that are not checked by Ekotrope must be met.	2015 IECC Mandatory Checklist must be checked as complete.
✓	R403.3.1	Duct Insulation	Duct insulation meets the requirements specified in North Carolina 2018 Code Section 403.3.1.

## Design exceeds requirements for North Carolina 2018 Performance compliance by 4.9%.

As a 3rd party extension of the code jurisdiction utilizing these reports, I certify that this energy code compliance document has been created in accordance with the requirements of Chapter 4 of the adopted International Energy Conservation Code based on HARNETT County. If rating is Projected, I certify that the building design described herein is consistent with the building plans, specifications, and other calculations submitted with the permit application. If rating is Confirmed, I certify that the address referenced above has been inspected/tested and that the mandatory provisions of the IECC have been installed to meet or exceed the intent of the IECC or will be verified as such by another party.

Name: Noe Montalvo  
Organization: Builder i Group

Signature:   
Digitally signed: 12/23/24 at 12:00 PM

### Ekotrope RATER - Version 4.2.2.3542

North Carolina 2018 Performance compliance results calculated using Ekotrope RATER's energy and code compliance algorithm, including appropriate amendments. Ekotrope RATER is a RESNET Accredited HERS Rating Tool. All results are based on data entered by Ekotrope users. Ekotrope disclaims all liability for the information shown on this report.

# Energy Code Inspection Checklist

## Property

TBD Grove Township Way  
Angier, NC 27501  
Model: Russell 9'  
Community: Langdon Preserve

## Organization

Builder i Group  
Noe Montalvo

## Inspection Status

Results are projected

## Builder

Mungo Homes

Mungo Homes Langdon Preserve Lot 16  
TBD Grove Township Way Lot 16

## General Building Information

Conditioned Area (sq ft)	2,531
Conditioned Volume (cubic ft)	22,748
Insulated Shell Area (sq ft)	5,850.5

The building energy model in Ekotrope reflects the building assemblies and energy features listed below. Sometimes energy features will change in the field from what has been modeled. The inspection process should identify any changes and ensure that the home continues to meet the applicable energy code.

## Slab

None Present

## Framed Floor



Name: Floor Over Crawlspace (1,088 s.f.)  
R-0 continuous insulation, R-19 cavity insulation  
Insulation Grade: II



Name: Floor Over Garage (381 s.f.)  
R-0 continuous insulation, R-38 cavity insulation  
Insulation Grade: II

## Foundation Wall

None Present

## Above Grade Wall



Name: Exterior Wall (2,258 s.f.)  
R-0 continuous insulation, R-15 cavity insulation  
Insulation Grade: II



Name: Garage Wall (351 s.f.)  
R-0 continuous insulation, R-15 cavity insulation  
Insulation Grade: II

## Rim Joist

# Energy Code Inspection Checklist

## Property

TBD Grove Township Way  
Angier, NC 27501  
Model: Russell 9'  
Community: Langdon Preserve

## Organization

Builder i Group  
Noe Montalvo

## Inspection Status

Results are projected

## Builder

Mungo Homes

Mungo Homes Langdon Preserve Lot 16  
TBD Grove Township Way Lot 16



Name: Rim (204 s.f.)  
R: 15.00

## Ceiling / Roof



Name: Roof (1,386 s.f.)  
R-40 continuous insulation, R-10 cavity insulation  
Insulation Grade: I



Name: Mechanical Platform (182.5 s.f.)  
R-0 continuous insulation, R-30.4 cavity insulation  
Insulation Grade: I

## Opaque Door



Name: Opaque Door - Entry (20 s.f.)  
R: 3.50



Name: Opaque Door - Garage entry (17.8 s.f.)  
R: 3.50

## Glazing



Name: Front Windows (99.3 s.f.), U: 0.330, SHGC: 0.22, Orientation: EAST



Name: Right Window (4 s.f.), U: 0.330, SHGC: 0.22, Orientation: SOUTH



Name: Rear Window (107 s.f.), U: 0.330, SHGC: 0.22, Orientation: WEST



Name: Left Window (12 s.f.), U: 0.330, SHGC: 0.22, Orientation: NORTH

## Skylight

None Present

## Mechanical Ventilation

None Present

# Energy Code Inspection Checklist

## Property

TBD Grove Township Way  
Angier, NC 27501  
Model: Russell 9'  
Community: Langdon Preserve

Mungo Homes Langdon Preserve Lot 16  
TBD Grove Township Way Lot 16

## Organization

Builder i Group  
Noe Montalvo

## Builder

Mungo Homes

## Inspection Status

Results are projected

## Mechanical Equipment



Heating Equipment • Natural Gas • 100% Heating Load @ 80 AFUE



Cooling Equipment • Electric • 100% Cooling Load @ 14 SEER



Water Heater • Natural Gas • 100% Hot Water Load @ 0.82 Energy Factor

## Air Leakage Control



Test Status: Blower-door tested

House is air-sealed as to achieve 1,896 CFM50 (5.00 ACH50) or less at final blower-door test.

### Infiltration Requirements for IECC in Climate Zone 4

2009 IECC Infiltration limit for the design home is 7 ACH50.

2012 IECC Infiltration limit for the design home is 3 ACH50.

2015 IECC Infiltration limit for the design home is 3 ACH50.

2018 IECC Infiltration limit for the design home is 3 ACH50.

2021 IECC Infiltration limit for the design home is 5 ACH50.

Note: Under IECC 2021, this home is considered to be in Climate Zone 3

## Duct Leakage

### Duct System 1

NOT entirely within conditioned space, testing required

Leakage to Outside specified as: 4 CFM25 / 100 ft<sup>2</sup>

Total Leakage specified as: 6 CFM25 / 100 ft<sup>2</sup> (Post-Construction)

# Energy Code Inspection Checklist

## Property

TBD Grove Township Way  
Angier, NC 27501  
Model: Russell 9'  
Community: Langdon Preserve

Mungo Homes Langdon Preserve Lot 16  
TBD Grove Township Way Lot 16

## Organization

Builder i Group  
Noe Montalvo

## Builder

Mungo Homes

## Inspection Status

Results are projected

## Duct Leakage Code Requirements for IECC

### 2009 IECC:

Postconstruction Leakage Test: Duct Leakage to Outdoors  $\leq 8$  CFM25 / 100 sq ft CFA.

Rough in Test with AHU: Total Duct Leakage  $\leq 6$  CFM25 / 100 sq ft CFA.

Rough in Test without AHU: Total Duct Leakage  $\leq 4$  CFM25 / 100 sq ft CFA.

### 2012 IECC Mandatory, 2015, 2018, & 2021 IECC Prescriptive Paths:

Postconstruction Leakage Test: Total Duct Leakage  $\leq 4$  CFM25 / 100 sq ft CFA.

Rough in Test with AHU: Total Duct Leakage  $\leq 4$  CFM25 / 100 sq ft CFA.

Rough in Test without AHU: Total Duct Leakage  $\leq 3$  CFM25 / 100 sq ft CFA.

\* Note: IECC 2021 requires Total Duct Leakage  $\leq 8$  CFM25 / 100 sq ft CFA when all ducts and air handlers are within the building thermal envelope.

### 2015 and 2018 IECC Performance Paths (Cost Compliance):

Leakage testing is required UNLESS all ducts and air handlers are located entirely within the thermal envelope.

There is no pass/fail threshold for duct leakage on the performance path.

## Project Notes