



Permit Inspections

Harnett County

Permit Number: SFD2501-0066

Description: 59x38 sfd 3 beds 2 baths

Applied: 1/17/2025

Approved: 2/6/2025

Site Address: 114 CAMP ROCK RD

Issued: 2/7/2025

Finaled: 6/17/2025

City, State Zip Code: LILLINGTON, NC 27546

Status: FINALED

Applicant: LGI Homes-NC, LLC

Parent Permit:

Owner: LGI HOMES NC LLC

Parent Project:

Contractor: LGI Homes-NC, LLC

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			GAS PIPING	Steven Gazlay		

Notes:

	3/10/2025	3/10/2025	ADDRESS	GIS Bucket	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	---------	------------	----------	----------------------------

Notes:

3/7/2025 11:01 AM LGI Homes-NC, LLC

Contact Name: LGI Homes-NC, LLC

Site Address: 114 CAMP ROCK RD

Phone: 9197953922

e-Mail: oliver.hudson@lgihomes.com

114 CAMP ROCK RD LILLINGTON 27546.

	3/10/2025	3/10/2025	FOOTING	John B Kokoszka	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	---------	-----------------	----------	----------------------------

Notes:

3/7/2025 11:18 AM LGI Homes-NC, LLC

Contact Name: LGI Homes-NC, LLC

Site Address: 114 CAMP ROCK RD

Phone: 9197953922

e-Mail: oliver.hudson@lgihomes.com

Eng letter in attachments.

	3/10/2025	3/10/2025	T-POLE	John B Kokoszka	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	--------	-----------------	----------	----------------------------

Notes:

3/7/2025 11:02 AM LGI Homes-NC, LLC

Contact Name: LGI Homes-NC, LLC

Site Address: 114 CAMP ROCK RD

Phone: 9197953922

e-Mail: oliver.hudson@lgihomes.com



Permit Inspections

Harnett County

	3/11/2025	3/11/2025	FOUNDATION	Daniel L Floyd	APPROVED	eTRAKiT Inspection Request
Notes: 3/10/2025 8:40 AM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com						
	3/19/2025	3/19/2025	WATER CONNECTION	John B Kokoszka	APPROVED	eTRAKiT Inspection Request
Notes: 3/18/2025 10:18 AM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com						
	3/19/2025	3/19/2025	UNDER SLAB TRADES	John B Kokoszka	APPROVED	eTRAKiT Inspection Request
Notes: 3/18/2025 10:17 AM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com						
	3/21/2025	3/21/2025	SLAB	John B Kokoszka	APPROVED	eTRAKiT Inspection Request
Notes: 3/19/2025 3:11 PM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com						
	4/29/2025	4/29/2025	ROUGH IN	John B Kokoszka	DISAPPROVED	eTRAKiT Inspection Request
Notes: 4/28/2025 10:27 AM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com 1. Missing each clip in laundry room, A22. A5 trust at attic access brokenOK to insulate as long as we can see everything						



Permit Inspections

Harnett County

	5/6/2025	5/6/2025	ROUGH IN REINSPECT	John B Kokoszka	APPROVED	eTRAKiT Inspection Request
Notes: 5/5/2025 8:50 AM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com						
	6/5/2025	6/5/2025	TEMP POWER CERTIFICATION	Daniel L Floyd	APPROVED	
Notes:						
	6/5/2025	6/5/2025	SEWER CONNECTION	Daniel L Floyd	APPROVED	eTRAKiT Inspection Request
Notes: 6/4/2025 11:59 AM LGI Homes-NC, LLC Contact Name: LGI Homes-NC, LLC Site Address: 114 CAMP ROCK RD Phone: 9197953922 e-Mail: oliver.hudson@lgihomes.com						
20	5/5/2025	5/5/2025	AS BUILT SURVEY	Donna Johnson	APPROVED	NEEDED
Notes:						
30	5/6/2025	5/6/2025	INSULATION	John B Kokoszka	APPROVED	
Notes:						
40	5/19/2025	5/19/2025	ENVIR OPERATIONS PERMIT	Mark Osborne	APPROVED	
Notes:						
50			FINAL SFD STEMWALL**	Steven Gazlay		
Notes:						
50	6/16/2025	6/16/2025	FINAL SFD STEMWALL**	John B Kokoszka	DISAPPROVED	
Notes: 1. Need to clean out hvac pan2. Need to seal master backsplash and around shower 3. Seal left bathroom backsplash and tub area4. Left and right side grade 6 inches within 10 feet slope away5. Clean out the grade						
50	6/17/2025	6/17/2025	FINAL SFD STEMWALL**	John B Kokoszka	APPROVED	
Notes:						