



July 1, 2025

Jason Pope
81 Beaver Creek Drive
Dunn, NC 28334
Email: probuiltgcinc@hotmail.com

Reference: Engineering Services
93 Big J St.
Erwin, NC 28339
TE&D Project No.: 2501-020522

To Whom It May Concern:

As requested, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following item(s):

- 1) Analyze and inspect the tall foundation walls at the front porch.

The following conclusions and recommendations were noted:

- 1) We observed the 12" thick masonry/CMU foundation walls were constructed to maximum heights of 7'-0" above the footing. We also understand that unbalanced fill at final grade will be no greater than 5'-0". Based on our observations and analysis, the "as-built" walls remain suitable and will provide the required support for the anticipated loading conditions.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design

Tripp Amos
TA | 2501-020522

Prentice Tyndall Jr., P.E.

