

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.

ENOCH ENGINEERS, P.A.
1403 NC Highway 50 South
Benson, North Carolina 27504
919.894.7765

Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION

FIELD REPORT

PROJECT

CLIENT: GAMMON CONST

DATE: 4.22.25

PROJECT: RESI FOOTINGS

CONTRACTOR: D. GAMMON

ADDRESS: 444 SENTER LN

TECHNICIAN: BLH

LOT #: BUNNLEVEL NC

TEST SUMMARY

PERFORMED SOIL BEARING CAPACITY EVALUATION OF SITE NOTED ABOVE.
RECOMMEND REMOVAL OF UNSUITABLE MATERIAL AT MARKED FIELD LOCATIONS.
BACKFILL AREAS WITH WASHED #57 STONE OR ADDITIONAL CONCRETE.
SOILS CONFIRMED A MINIMUM ALLOWABLE BEARING CAPACITY OF 2000PSF
ONCE REPAIRED PER ABOVE DESIGN.

TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %

RETURN VISIT REQUIRED

YES

☐

NO

☒

TECHNICIAN:

BLH

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.