

North Carolina 2018 - Simulated Performance Alternative (N1105)



Property

83 Sagamore Avenue
Angier, NC 27501
Model: Telfair 9'
Community: Cambridge Reserve

Organization

Builder i Group
Noe Montalvo

Inspection Status

Results are projected



Builder

Mungo Homes

Mungo Homes Cambridge Reserve Lot 31
83 Sagamore Avenue

This report is based on a proposed design and does not confirm field enforcement of design elements.

Annual Energy Cost

Design	North Carolina 2018 Performance	As Designed
Heating	\$869	\$819
Cooling	\$293	\$246
Water Heating	\$606	\$606
Mechanical Ventilation	\$0	\$0
SubTotal - Used to determine compliance	\$1,768	\$1,670
Lights & Appliances w/out Ventilation	\$650	\$650
Onsite generation	\$0	\$0
Total	\$2,418	\$2,321

Source Energy Exception: The proposed home uses 8.56 MBtu LESS source energy than the reference home.


Requirements

✓	R405.3	Performance-based compliance passes by 7.7%	The proposed house meets the North Carolina 2018 Performance reference energy bill requirement by \$97.32 (8.56 MBtu).
✓	R402.4.2.2	Air Leakage Testing	Air sealing is 5.00 ACH at 50 Pa. It must not exceed 5.00 ACH at 50 Pa.
✓	R402.5	Area-weighted average fenestration SHGC	Area-weighted average fenestration SHGC is 0.19. The maximum allowed value is [No Limit].
✓	R402.5	Area-weighted average fenestration U-Factor	
✓	R404.1	Lighting Equipment	
✓	Mandatory Checklist	Mandatory code requirements that are not checked by Ekotrope must be met.	2015 IECC Mandatory Checklist must be checked as complete.
✓	R403.3.1	Duct Insulation	Duct insulation meets the requirements specified in North Carolina 2018 Code Section 403.3.1.

Design exceeds requirements for North Carolina 2018 Performance compliance by 7.7%.

As a 3rd party extension of the code jurisdiction utilizing these reports, I certify that this energy code compliance document has been created in accordance with the requirements of Chapter 4 of the adopted International Energy Conservation Code based on HARNETT County. If rating is Projected, I certify that the building design described herein is consistent with the building plans, specifications, and other calculations submitted with the permit application. If rating is Confirmed, I certify that the address referenced above has been inspected/tested and that the mandatory provisions of the IECC have been installed to meet or exceed the intent of the IECC or will be verified as such by another party.

Name: Noe Montalvo
Organization: Builder i Group

Signature: 
Digitally signed: 2/6/25 at 5:39 PM

Ekotrope RATER - Version 4.2.2.3565

North Carolina 2018 Performance compliance results calculated using Ekotrope RATER's energy and code compliance algorithm, including appropriate amendments.
Ekotrope RATER is a RESNET Accredited HERS Rating Tool. All results are based on data entered by Ekotrope users.
Ekotrope disclaims all liability for the information shown on this report.

Energy Code Inspection Checklist

Property

83 Sagamore Avenue
Angier, NC 27501
Model: Telfair 9'
Community: Cambridge Reserve

Organization

Builder i Group
Noe Montalvo

Inspection Status

Results are projected



Mungo Homes Cambridge Reserve Lot 31
83 Sagamore Avenue

General Building Information


Conditioned Area (sq ft)	2,817
Conditioned Volume (cubic ft)	25,380
Insulated Shell Area (sq ft)	5,998.5


The building energy model in Ekotrope reflects the building assemblies and energy features listed below. Sometimes energy features will change in the field from what has been modeled. The inspection process should identify any changes and ensure that the home continues to meet the applicable energy code.

Slab

None Present

Framed Floor


 Name: Floor Over Crawlspace (1,221 s.f.)
R-0 continuous insulation, R-19 cavity insulation
Insulation Grade: II


 Name: Floor Over Garage (375 s.f.)
R-0 continuous insulation, R-38 cavity insulation
Insulation Grade: II

Foundation Wall

None Present

Above Grade Wall

 Name: Exterior Wall (2,248 s.f.)
R-0 continuous insulation, R-15 cavity insulation
Insulation Grade: II

 Name: Garage Wall (312 s.f.)
R-0 continuous insulation, R-15 cavity insulation
Insulation Grade: II

Rim Joist

Energy Code Inspection Checklist

Property

83 Sagamore Avenue
Angier, NC 27501
Model: Telfair 9'
Community: Cambridge Reserve

Organization

Builder i Group
Noe Montalvo

Inspection Status

Results are projected



Mungo Homes Cambridge Reserve Lot 31
83 Sagamore Avenue



Name: Rim (160 s.f.)
R: 15.00

Ceiling / Roof



Name: Roof (1,490 s.f.)
R-40 continuous insulation, R-10 cavity insulation
Insulation Grade: I



Name: Mechanical Platform (182.5 s.f.)
R-0 continuous insulation, R-38 cavity insulation
Insulation Grade: I



Name: Attic PDS (10 s.f.)
R-10 continuous insulation, R-0.5 cavity insulation
Insulation Grade: I

Opaque Door



Name: Opaque Door - Entry (20 s.f.)
R: 3.50



Name: Opaque Door - Garage entry (17.8 s.f.)
R: 3.50

Glazing



Name: Front Windows (105 s.f.), U: 0.330, SHGC: 0.19, Orientation: NORTH_WEST



Name: Right Window (15 s.f.), U: 0.330, SHGC: 0.19, Orientation: NORTH_EAST



Name: Rear Window (119 s.f.), U: 0.330, SHGC: 0.19, Orientation: SOUTH_EAST



Name: Left Window (30 s.f.), U: 0.330, SHGC: 0.19, Orientation: SOUTH_WEST

Skylight

None Present

Energy Code Inspection Checklist

Property

83 Sagamore Avenue
Angier, NC 27501
Model: Telfair 9'
Community: Cambridge Reserve

Organization

Builder i Group
Noe Montalvo

Inspection Status

Results are projected



Mungo Homes Cambridge Reserve Lot 31
83 Sagamore Avenue

Mechanical Ventilation

None Present

Mechanical Equipment



Heating Equipment • Natural Gas • 100% Heating Load @ 80 AFUE



Cooling Equipment • Electric • 100% Cooling Load @ 14 SEER



Water Heater • Propane • 100% Hot Water Load @ 0.82 Energy Factor

Air Leakage Control



Test Status: Blower-door tested
House is air-sealed as to achieve 2,115 CFM50 (5.00 ACH50) or less at final blower-door test.

Infiltration Requirements for IECC in Climate Zone 4

2009 IECC Infiltration limit for the design home is 7 ACH50.

2012 IECC Infiltration limit for the design home is 3 ACH50.

2015 IECC Infiltration limit for the design home is 3 ACH50.

2018 IECC Infiltration limit for the design home is 3 ACH50.

2021 IECC Infiltration limit for the design home is 5 ACH50.

Note: Under IECC 2021, this home is considered to be in Climate Zone 3

Duct Leakage

Duct System 1

NOT entirely within conditioned space, testing required

Leakage to Outside specified as: 112 CFM @ 25Pa (3.98 / 100 ft²)

Total Leakage specified as: 169 CFM @ 25Pa (Post-Construction)

Energy Code Inspection Checklist

Property

83 Sagamore Avenue
Angier, NC 27501
Model: Telfair 9'
Community: Cambridge Reserve

Organization

Builder i Group
Noe Montalvo

Inspection Status

Results are projected

Builder

Mungo Homes

Mungo Homes Cambridge Reserve Lot 31
83 Sagamore Avenue



Duct Leakage Code Requirements for IECC

2009 IECC:

Postconstruction Leakage Test: Duct Leakage to Outdoors ≤ 8 CFM25 / 100 sq ft CFA.
Rough in Test with AHU: Total Duct Leakage ≤ 6 CFM25 / 100 sq ft CFA.
Rough in Test without AHU: Total Duct Leakage ≤ 4 CFM25 / 100 sq ft CFA.

2012 IECC Mandatory, 2015, 2018, & 2021 IECC Prescriptive Paths:

Postconstruction Leakage Test: Total Duct Leakage ≤ 4 CFM25 / 100 sq ft CFA.
Rough in Test with AHU: Total Duct Leakage ≤ 4 CFM25 / 100 sq ft CFA.
Rough in Test without AHU: Total Duct Leakage ≤ 3 CFM25 / 100 sq ft CFA.

* Note: IECC 2021 requires Total Duct Leakage ≤ 8 CFM25 / 100 sq ft CFA when all ducts and air handlers are within the building thermal envelope.

2015 and 2018 IECC Performance Paths (Cost Compliance):

Leakage testing is required UNLESS all ducts and air handlers are located entirely within the thermal envelope.
There is no pass/fail threshold for duct leakage on the performance path.

Project Notes