

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: Y N	Commercial Project: Y N
Code Enforcement Project No: N/A	Permit No: SfD2503-0036
Project Name: 123 MAPLE DRIVE ERWIN NC	Owner: WELLONS REALTY, INC.
Project Address: 123 MAPLE DR. ERWIN, NC 28339	Suite No:
Date Inspected: 03.19.25	Contractor Name: WELLONS REALTY, INC.
Component Inspected: FOOTINGS	

Responsible Licensed NC Architect or NC Engineer

Name:	JOE E GODWIN SR.		
Firm Name:	ENOCH ENGINEERS P.A.		
Phone Numbers:	Office: 919-894-7765	Mobile:	
Email Address:	JASON@ENOCHENGINEERS.COM		
Mailing Address:	1403 NC HWY 50 SOUTH, BENSON, NC 27504		

APPLICABLE CODE: 2018 NCRC-SECTION R403


2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: COMPLETE FOOTINGS INSPECTED TO BE OK PER 2018 NCBC. SOIL BEARING CAPACITY 2000PSF MIN,


*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.



Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.