

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460


August 26, 2025

Subject: 123 Basin Street  
Fuquay Varina, NC 27526  
Plan Revision Letter  
Harnett County Permit #: SFD2503-0073

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The Contractor modified the interior foundation wall of the Garage to install a room. A double 1 3/4"x 9 1/4" LVL beam was installed in the ceiling to span the gap between the new corners of the modified interior foundation wall. The new stud wall is attached to the concrete slab of the Garage. This stud wall is not load bearing. This plan change is acceptable.

The revision noted above meets all the requirements of the 2018 North Carolina Building Code for Residences.



08 26 2025 EDT