

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM  
(Complete all fields in full)

OWNER: Dream Finders DATE EVALUATED: \_\_\_\_\_  
ADDRESS: 669 Blossom St  
PROPOSED FACILITY: SP PROPOSED DESIGN FLOW (.0400): 480 GPD PROPERTY SIZE: \_\_\_\_\_  
LOCATION OF SITE: \_\_\_\_\_ PROPERTY RECORDED: \_\_\_\_\_  
WATER SUPPLY: Public Single Family Well Shared Well Spring Other \_\_\_\_\_ WATER SUPPLY SETBACK: \_\_\_\_\_  
EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Domestic High Strength IPWW

P R O F I L E  #	.0502 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				.0509 PROFILE CLASS & LTAR*	.0503 SLOPE CORRE CTION
			.0503 STRUCTURE/ TEXTURE	.0503 CONSISTENCE/ MINERALOGY	.0504 SOIL WETNESS/ COLOR	.0505 SOIL DEPTH	.0506 SAPRO CLASS	.0507 RESTR HORIZ		
1	LSS 15%	0-39	W,F,G+LS	VF,F,MS,M,SEXP	48"	48"			S 0.8	5"
		39-48	W,C,G+LS	VF,F,MS,M,SEXP						
2	LSS 15%	0-34	W,F,G+LS	VF,F,MS,M,SEXP	48"	48"			S 0.6	5"
		34-46	W,C,G+LS	VF,F,MS,M,SEXP						
		46-48	W,M,SBK/SL	FI,SS,SP,SEXP						
3	LSS 10%	0-30	M,M,SBK/SL	FI,SS,SP,SEXP	48"	48"			S 0.4	4"
		30-43	M,M,SBK/SL	FI,SS,SP,SEXP						
		43-48	W,F,G+SL	VF,F,MS,M,SEXP						
4										

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	SITE CLASSIFICATION (.0509): EVALUATED BY: _____ OTHER(S) PRESENT: <u>WU-REHS /AT</u>
Available Space (.0508)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>✓</u>	<u>✓</u>	
Site LTAR	<u>0.6</u>	<u>0.6</u>	
Maximum Trench Depth	<u>28"</u>	<u>28"</u>	
Comments: _____			
_____			
_____			

# Harnett County Environmental Health

## SITE SKETCH

PIN 9596-56-4324

Permit Number SFD2503 - 0134

Dream Finder Homes, LLC

Magnolia Ridge / Lot 46

Applicant's Name

Subdivision/Section/Lot Number

Mark Osborne REHS

5/2/25

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

