

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: Dhona Fidelity Home LLC DATE EVALUATED: _____
ADDRESS: 652 Decker Hwy Lot 49
PROPOSED FACILITY: SFD PROPOSED DESIGN FLOW (.0400): 410 GPD PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: Public Single Family Well Shared Well Spring Other _____ WATER SUPPLY SETBACK: _____
EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Domestic High Strength IPWW

P R O F I L E #	.0502 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				.0509 PROFILE CLASS & LTAR*	.0503 SLOPE CORRE CTION
			.0503 STRUCTURE/ TEXTURE	.0503 CONSISTENCE/ MINERALOGY	.0504 SOIL WETNESS/ COLOR	.0505 SOIL DEPTH	.0506 SAPRO CLASS	.0507 RESTR HORIZ		
1	L.S.S. 8%	0-2"	W/C Gr/SL	VFr, NS, MP, Sep	48"	48"			S 0.8	MTB:33"
		2-48	W/C Gr/LS	VFr, NS, MP, Sep						
2	L.S.S. 10%	0-20	W/C Gr/LS	VFr, NS, MP, Sep	48"	48"			S 0.6	MTB:33"
		20-48	W/C Gr/SL	VFr, NS, MP, Sep						
3	L.S.S. 8%	0-3	W/C Gr/SL	VFr, NS, MP, Sep	28"	28"			0.4	MTB 12"
		3-15	W/C Gr/SL	VFr, NS, MP, Sep						
		15-28	M, M, SBK/SL	Fi, SP, SP, Sep						
		28	Mass/C	VFr, US, VP, Sep						
4	L.S.S. 10%				15"	15"			Un	
		0-15	M, M, ABK/C	VFr, US, VP, Sep						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	SITE CLASSIFICATION (.0509): EVALUATED BY: <u>MTB RETN</u> OTHER(S) PRESENT: _____
Available Space (.0508)			
System Type(s)			
Site LTAR			
Maximum Trench Depth			
Comments:			

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

(Complete all fields in full)

OWNER: Dream Finders Homes, LLC DATE EVALUATED: _____

ADDRESS: 652 Blossom Trail LOT 49

PROPOSED FACILITY: SFD PROPOSED DESIGN FLOW (.0400): 480 GPD PROPERTY SIZE: _____

LOCATION OF SITE: _____ PROPERTY RECORDED: _____

WATER SUPPLY: Public Single Family Well Shared Well Spring Other _____ WATER SUPPLY SETBACK: _____

EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Domestic High Strength IPWW

P R O F I L E #	.0502 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				.0509 PROFILE CLASS & LTAR*	.0503 SLOPE CORRE CTION
			.0503 STRUCTURE/ TEXTURE	.0503 CONSISTENCE/ MINERALOGY	.0504 SOIL WETNESS/ COLOR	.0505 SOIL DEPTH	.0506 SAPRO CLASS	.0507 RESTR HORIZ		
5	L.S.S. 10%	0-2	W, C, GH SL	VFr, NS, MP, S exp					S 0.8	MTB 33"
		2-48	W, C, Gr/LS	VFr, NS, MP, S exp		48"				
2										
3										
4										

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.0508)	S	S
System Type(s)	IIb	IIb
Site LTAR	0.6	0.6
Maximum Trench Depth	33"	33"

SITE CLASSIFICATION (.0509): Suitable
EVALUATED BY: Alex Thompson
OTHER(S) PRESENT: _____

Comments: _____

Harnett County Environmental Health

SITE SKETCH

PIN 9596-46-9144

Permit Number SFD2503 - 0138

Dream Finder Homes, LLC

Magnolia Ridge / Lot 49

Applicant's Name

Subdivision/Section/Lot Number

Mark Osborne REHS

5/9/25

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

