

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: Deam Finner Homes, LLC DATE EVALUATED: _____
ADDRESS: 632 Blossom Trail
PROPOSED FACILITY: SFO PROPOSED DESIGN FLOW (.0400): 360 GPD PROPERTY SIZE: _____
LOCATION OF SITE: Lot 50 PROPERTY RECORDED: _____
WATER SUPPLY: Public Single Family Well Shared Well Spring Other _____ WATER SUPPLY SETBACK: _____
EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Domestic High Strength IPWW

P R O F I L E #	.0502 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				.0509 PROFILE CLASS & LTAR*	.0503 SLOPE CORRE CTION
			.0503 STRUCTURE/ TEXTURE	.0503 CONSISTENCE/ MINERALOGY	.0504 SOIL WETNESS/ COLOR	.0505 SOIL DEPTH	.0506 SAPRO CLASS	.0507 RESTR HORIZ		
1	LSS 8%	0-48	W, G, L/S	VF, NS, NP, Sexp					S	
									0.8	3'
2	LSS 8%	0-34	W, M, SBK/SC	VF, NS, NP, Sexp					S	
		34-37	M/C	VF, US, NP, Sexp	10 yr 8/2 @ 37	37"			0.6	3"
3	R 10%	0-40	W, L, SBK/SC	VF, NS, NP, Sexp					S	
		40-48	M, M, SBK/SC	F, S, P, Sexp	10 yr 8/2 @ 40	48"			0.6	4"
4										

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.0508)	S	S
System Type(s)	IIb	IIb
Site LTAR	0.6	0.6
Maximum Trench Depth	22"	22"

SITE CLASSIFICATION (.0509): Suitable
EVALUATED BY: Mark Osborne / AT
OTHER(S) PRESENT: _____

Comments: _____

Harnett County Environmental Health

SITE SKETCH

PIN **9596-46-9203**

Permit Number **SFD2503-0139**

Dream Finder Homes, LLC

Applicant's Name

Mark Osborne REHS

Authorized State Agent

Magnolia Ridge / Lot 50

Subdivision/Section/Lot Number

5/13/25

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = **NTS**

