

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: Dream Finder DATE EVALUATED: _____
ADDRESS: 700 Plosson Trl
PROPOSED FACILITY: SFD PROPOSED DESIGN FLOW (.0400): 480 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: Public Single Family Well Shared Well Spring Other WATER SUPPLY SETBACK: _____
EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Domestic High Strength IPWW

P R O F I L E #	.0502 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				.0509 PROFILE CLASS & LTAR*	.0503 SLOPE CORRE CTION
			.0503 STRUCTURE/ TEXTURE	.0503 CONSISTENCE/ MINERALOGY	.0504 SOIL WETNESS/ COLOR	.0505 SOIL DEPTH	.0506 SAPRO CLASS	.0507 RESTR HORIZ		
1	LSS 15%	0-30	W, F, Gt/LS	VF, NS, NP, Sexp	10YR 8/1 @ 38"	40"			S 0.7	5"
		30-38	W, G, Gt/SL	VF, NS, NP, Sexp						
		38-40	M/C	VF, VS, VP, Exp						
2	LSS 15%	0-34	W, F, Gt/LS	VF, NS, NP, Sexp		48"			S 0.6	5"
		34-46	W, C, Gt/LS	VF, NS, NP, Sexp						
		46-48	W, M, SBK/FSCL	FI, S, SP, Sexp						
3	MBS R 8% over	0-26	W, F, Gt/LS	VF, NS, NP, Sexp	10YR 8/2 @ 28"	30"			S 0.4	3"
		26-28	W, C, Gt/SL	VF, NS, NP, Sexp						
		28-30	M, M, SBK/SC	FI, S, P, Sexp						
4										

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.0508)	✓	✓
System Type(s)	✓	✓
Site LTAR	0.6	0.6
Maximum Trench Depth	20"	20"

SITE CLASSIFICATION (.0509): Suitable
EVALUATED BY: M. K. NETH /AT
OTHER(S) PRESENT: _____

Comments: _____

Harnett County Environmental Health

SITE SKETCH

PIN 9596-56-4149

Permit Number SFD2503 - 014C

Dream Finder Homes, LLC

Magnolia Ridge / Lot 47

Applicant's Name

Subdivision/Section/Lot Number

Mark Osborne REHS

5/5/25

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

