# **Harnett County Environmental Health**

File/Permit Number: SFD 2503-0160

#### **IMPROVEMENT PERMIT**

County: Harnett			
PIN/Lot Identifier: 9596 - 46 - 8872			
Owner: Dream Finders Homes Applicant: Dream Finders Homes			
Property Location: 536 Blossom Trail			
Subdivision (if applicable) Magnolia Ridge Lot #: 54 Block: Section:			
New ☑ Expansion ☐ System Relocation ☐ Change of Use ☐			
Facility Type: 38'x44' SFD			
Number of bedrooms: 4 Number of Occupants: 8 _ Other:			
Design Wastewater Strength: 🔀 Domestic 🔲 High Strength 🔲 Industrial Process Wastewater			
Proposed Design Daily Flow: 480 GPD Proposed LTAR (Initial):6 Proposed LTAR (Repair):5			
Proposed Wastewater System Type*: 25% reduction (Initial) Pump Required: Yes No May be required			
Proposed Wastewater System Type*: 25% reduction (Repair) Pump Required: Yes No May be required			
*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII			
Effluent Standard: DSE  HSE NSF/ANSI 40 TS-I TS-II RCW			
Saprolite System (Initial): ☐ Yes 🔯 No Saprolite System (Repair): ☐ Yes 🔼 No			
Fill System (Initial): Yes 🔀 No-If yes, specify: New 🗎 Existing (when adding more than 6 inches of fill to system area provide a fill plan)			
Fill System (Repair): Yes 🔀 No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)			
Usable Depth to LC (Initial)*:			
Max. Trench Depth (Initial) <sup>‡</sup> : 26 Max. Trench Depth (Repair) <sup>‡</sup> : 26 *Measured on the downhill side of the trench			
Artificial Drainage Required: Yes 🕅 No If yes, please specify details:			
Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other:			
Drainfield location meets requirements of Rule .0508: Yes 🔀 No 🗌 Drainfield location meets requirements of Rule .0601: Yes 🔁 No 🗌			
Permit valid for: Five years [site plan submitted pursuant to GS 130A-334(13a)] 🔲 No expiration [plat submitted pursuant to GS 130A-334(7a)]			
Permit conditions:			
NO GUTTER OR FOUNDATION DRAINS SHALL EMPTY ONTO DRAIN FIELD			
Mark Others PEUC			
Authorized Agent's Printed Name: Mark Osborne REHS Expiration Date: 4-23-30			
Authorized Agent's Signature: Mob W REHS /AT Date: 4-23-25			
*See attached site sketch*			

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. <u>This permit is subject to revocation if the site plan, plat, or the intended use changes</u>. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

### Harnett County Environmental Health

File/Permit Number: SFD 2503-0160

CONSTRUCTION AUTHORIZATION County: Harnett PIN/Lot Identifier: 9596 - 46 - 8872 Applicant: Dream Finder Property Location: 536 Blossom Trail Facility Type: 38'x44' SFD Number of bedrooms: 4 Number of Occupants: 8 Other: Change of Use Repair New Expansion System Relocation ☐ Yes X No Basement Fixtures? Yes No Basement? No No Yes ☐ No ☐ Yes Slab Foundation? Crawl Space? 25% reduction Type of Wastewater System\* 25% reduction (Initial) \*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII Design Daily Flow: 480 GPD Wastewater Strength: 🖸 Domestic 🗆 High Strength 🗀 Industrial Process Wastewater (if yes, please provide engineering documentation) Effluent Standard: Standard: Standard: Standard: NSF/ANSI 40 TS-I TS-II RCW Type of Water Supply: Private wel: Public well Shared well Municipal Supply Spring Other: Installation Requirements/Conditions Septic Tank Size: 1000 gallons Total Trench/Bed Length: 225 feet Trench/Bed Spacing: 9 feet on center Trench/Bed Width: 36 inches LTAR: 6 gpd/ft<sup>2</sup> Usable Depth to LC (Initial)<sup>x</sup>: 48 xLimiting condition Soil Cover: 6 inches Slope Corrected Maximum Trench/Bed Depth<sup>‡</sup>: 26 inches \* Measured on the downhill side of the trench Pump Tank Size (if applicable): 1000 gallons Requires more than one pump? Yes No Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Grease Trap Size (if applicable): \_\_\_\_\_ gallons Distribution Method: Serial D-Box or Parallel Pressure Manifold(s) LPP Other:\_\_\_\_\_ Artificial Drainage Required: Yes No 🔀 If yes, please specify details: Legal Agreements (If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.) Multi-party Agreement Required [Rule .0204(g)]: Yes No Easement, Right-of-Way, or Encroachment Agreement Required [Rule .0204(d)]: Yes No Declaration of Restrictive Covenants: Yes No Pre-Construction Conference Required: Yes No Management Entity Required: Yes No Minimum O&M Requirements: Conditions: The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit. Authorized Agent's Printed Name: Mark Osborne REHS Expiration Date: 4-23-30 Date: 4-23-25 Authorized Agent's Signature: \*See attached site sketch\*

# **Harnett County Environmental Health**

# SITE SKETCH

PIN _	9596-46-887Z Permit Number SFD 2503-0160	
Do	9596-46-8872 Permit Number SFD 2503-0160  Ram Finders Homes Magnolia Ridge /54	
Applic	Sant's Name Subdivision/Section/Lot Number 4-23-25	
	rized State Agent Date	
	in components represent approximate contours only. The contractor must flag the system prior to beginning the ation to ensure that the proper grade is maintained. $Scale = \frac{NTS}{S}$	
	159.1'	
	38'×44'  48-  1-1-	125.9"
	Blossom Trail	