



May 8, 2025

Chuck Michno  
David Weekley Homes  
1901 Harrison Avenue, Suite 200  
Cary, NC 27513  
Email: [cmichno@dwhomes.com](mailto:cmichno@dwhomes.com)

Reference: Engineering Services  
Serenity – Lot 1004  
Permit #2504-0002  
1053 Serentiy Walk Parkway  
Fuquay Varina, NC 27526  
TE&D Project No.: 2501-020350

To Whom It May Concern:

As requested by the client, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following items:

- 1) Observe the materials/conditions of the monolithic slab foundation bearing soils.
- 2) 3<sup>rd</sup> Party footing excavation observations.

The following conclusions and recommendations were noted:

- 1) The materials/condition of the monoslab foundation bearing soils were visually observed, qualitatively probed, and subjected to Static Cone Penetrometer (SCP) testing. Based on our observations and analysis, the in-situ soils were noted as being adequate to support the anticipated loading conditions (2000 PSF) provided that the footing soils have not been exposed to inclement weather after our visit.
- 2) The existing excavated monolithic slab footing was visually observed with regards to compliance with the project plans and applicable provisions of the 2018 North Carolina Residential Building Code. Based on our visual observations and analysis, the existing footings and slab were prepared in general accordance with the project plans and applicable provisions of the 2018 North Carolina Residential Building Code.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,  
Tyndall Engineering & Design



Scott Pyrch, PE

Tripp Amos  
PT III | 2501-020350

