

Harnett County Department of Public Health

PERMIT # SFD 2504-0018

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion
PROPERTY LOCATION: 366 Bunker Hill Place

Name: (owner) Clayton Properties Group SUBDIVISION Cambridge Reserve LOT # 33

System Installer: David Brantley

Basement with plumbing: Garage Num

Type of Water Supply: Community Public Well Distance from


Type of Water Supply: Community Public Well Distance from well _____ feet
System Type: ~~25%~~ Residential, ~~75%~~ Industrial, ~~100%~~ Sanitary, ~~0~~ Irrigation, ~~0~~ Other

System Type: 25% Reduction Type III(b) vault chambers Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



~~Needs prompt & clear
For Final~~

PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

_____ D-Box _____ Pump _____ Alarm _____ H2OLine _____ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other **TYPE III (b) 14x1 Chamber(s)** Septic Tank: **1,000** gallons Pump Tank: **1,000** gallons

Subsurface No. of exact length depth from width of pump tank depth of gain

Drainage Field ditches 5 of each ditch 70' feet ditches 3 feet ditches 18" inches

French Drain Required: _____ Linear feet

Authorized State Agent John W. REED

Date 10-28-25