

# DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

## Project Information:

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: <input type="radio"/> Y <input type="radio"/> N
Code Enforcement Project No:	Permit No: SFD2504-0128
Project Name: New Single Family Dwelling	Owner: JATWHIT LLC
Project Address: 300 Avery Rd. Erwin, NC 28339	Suite No:
Date Inspected: 7-9-25	Contractor Name: Whittenton Builders Enterprise
Component Inspected: Footings	

## Responsible Licensed NC Architect or NC Engineer

Name:	Mark E. Jones, PE
Firm Name:	
Phone Numbers:	Office: Mobile: 919-395-5618
Email Address:	markejonespe@gmail.com
Mailing Address:	6425 Glen Dean Ct. Raleigh, NC 27603


**APPLICABLE CODE:** 2018 NCRC


2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: \*Footings were inspected for a new single family dwelling, particularly over excavated areas filled with water. Footings were inspected for sizes, locations, soil bearing (min. 2000 psf), and clean of debris. Note the contractor encountered soft/organic soils in a couple of areas and over excavated 36"-42" to obtain suitable soils. Due to the high water table some ground water was seeping into the over excavation. The contractor was instructed to pump the water out and fill the areas with stone. All footings met the requirements of the 2018 NCRC and were approved for concrete placement

## Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

  
\_\_\_\_\_  
Licensed Architect or Engineer



## Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.