

Owner: Dream Finders Applicant: Dream Finders

Address: 89 Hoise Trot
Proposed Facility: SFD

Date Evaluated:
Design Flow (.1949): 360 GPD

Property Size:

Location of Site:

Property Recorded:

Water Supply:

☒ Public☐ Individual☐ Well☐ Spring☐ OtherEvaluation Method: ☒ Auger Boring☐ Pit☐ Cut

Type of Wastewater:

☒ Sewage☐ Industrial Process☐ Mixed

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>SMH</i> Others Present: <i>REHS</i>
Available Space (.1945)	<i>✓</i>	<i>✓</i>	
System Type(s)	<i>✓</i>	<i>✓</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	

COMMENTS: _____

LANDSCAPE POSITIONS

R-RIDGE
S-SHOULDER SLOPE
L-LINEAR SLOPE
FS-FOOT SLOPE
N-NOSE SLOPE
H-HEAD SLOPE
CC-CONCLAVE SLOPE
CV-CONVEX SLOPE
T-TERRACE
FP-FLOOD PLAN

GROUPTEXTURES.1955 LTARCONSISTENCE MOISTWET

I

S-SAND
LS-LOAMY SAND

1.2 - 0.8

VFR-VERY FRIABLE
FR-FRIABLE

NS-NON-STICKY
SS-SLIGHTLY STICKY

II

SL-SANDY LOAM
L-LOAM

0.8 - 0.6

FI-FIRM
VFI-VERY FIRM
EFI-EXTREMELY FIRM

S-STICKY
VS-VERY STICKY
NP-NON-PLASTIC
SP-SLIGHTLY STICKY
P-PLASTIC
VP-VERY PLASTIC

III

SI-SILT
SIL-SILT LOAM
CL-CLAY LOAM
SCL-SANDY CLAY LOAM

0.6 - 0.3

IV

SIC-SILTY CLAY
C-CLAY
SC-SANDY CLAY

0.4 - 0.1

STRUCTURE

SG-SINGLE GRAIN
M-MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY

SLIGHTLY EXPANSIVE
EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

