

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: <input type="radio"/> Y <input checked="" type="radio"/> N
Code Enforcement Project No:	Permit No: Harnett County Permit SFD2505-0046
Project Name: Single Family Dwelling	Owner: D. R. Horton
Project Address: 60 Charles Bend Way. Spring Lake, N.C.	Suite No:
Date Inspected: October 24, 2025	Contractor Name: Manta Masonry
Component Inspected: Foundation Excavation	

Responsible Licensed NC Architect or NC Engineer

Name:	Ronald B. Wilkins, P.E.
Firm Name:	Wilkins Engineering, PC
Phone Numbers:	Office: 919.772.3540 Mobile: 919.601.4924
Email Address:	wilkinsengr@aol.com
Mailing Address:	Post Office Box 37446, Raleigh, NC 27627

APPLICABLE CODE: 2018 North Carolina Residential Building Code

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: * The foundation excavation was inspected on this date. The subgrade material was a tan sandy material with no evidence of water or deleterious organic material. The entire perimeter footing and all individual spread footings were probed and determined to be consistent with the requirements of R401.4.1. Concrete placement for all footings should proceed as soon as practical.


**(subgrade form/letter may also be required)*

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A- 352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code.

Ronald B. Wilkins, P.E.

Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.