



# HAYES STRUCTURAL

Consulting & Design, PLLC

1501 Lakestone Village Ln. #103  
Fuquay-Varina, NC 27526  
NC Firm License No.: P-2854

**Date:** July 31, 2025

**To:** Tyler Appel  
Drees Homes  
8521 Six Forks Road, Suite 500  
Raleigh, NC 27615

**Re:** 25-FRM-155  
Framing Deviation  
Lot 39 Tobacco Road  
108 Golden Leaf Farms Rd.  
Angier, NC 27501  
Permit No.: SFD2505-0049

Mr. Appel:

At your request, the plans and provided information were reviewed for the above referenced single family residence under construction to address framing deviations between the approved plans and roof truss layout.

**Observations:**

The "end joist" specified above the rear porch in the approved plans was omitted. The roof above the rear porch is constructed with engineered roof trusses.

**Analysis and Recommendations:**

The "as-built" roof framing installed per the roof truss layout is adequate. The plan specified "end joist" is not required.

Please contact us if you have any questions.

Respectfully submitted,  
Hayes Structural Consulting & Design, PLLC



Digitally signed  
by Zachary H.  
Hayes, PE  
Date: 2025.07.31  
15:46:13 -04'00'

Garrett Scott  
Structural Engineering Technician  
(919) 980-2756  
[garrett@hayesstructural.com](mailto:garrett@hayesstructural.com)

Zachary H. Hayes, PE  
President & Principal Engineer  
(919) 210-3480  
[zach@hayesstructural.com](mailto:zach@hayesstructural.com)