

J.S. THOMPSON
ENGINEERING, INC

August 13, 2025

Ron Sherpinkas
JSJ Builders, Inc.
1135 Robeson St.
Fayetteville, NC 28305

Dear Mr. Sherpinkas:

The plan was reviewed for lot #3 Ilas Way subdivision in Dunn, North Carolina to address the framing at the transom window in the master bathroom.

Per the builder, the window was raised above the shower to be tight beneath the top plates. The nailer is to be removed and a 2 x 10 SPF #2 ply is to be fastened to the bottom chord of the gable end truss above with (2) rows of 12d nails at 6" o.c. The added ply is to extend a minimum of 4" past the window. This configuration will provide the required support for all applied loads.

Please contact me with any questions.

Sincerely,

J.S. Thompson Engineering, Inc.
N.C. License No. C-1733



Matthew G. Strother, P.E.



8/13/2025