#### Adams Soil Consulting, PLLC 1676 Mitchell Road Angier, NC 27501 919-414-6761

alexadams@bcsoil.com

October 7th 2025

RE: Magnolia Acres Lot # 56. 341 Magnolia Acres Ln. Fuquay Varina 27526 (Harnett County) PIN# (0633-15-1163)

#### OWNER ACCEPTANCE OF SEPTIC SYSTEM

I certify that <u>Caruso Homes is accepting the subsurface</u> wastewater (septic) system installed at 341 Magnolia Acres Ln. (Harnett County) The acceptance includes the AOWE permit as issued and designed by Adams Soil Consulting, PLLC and installed by Brantley & Sons.						
Owner's Representative (print): James Rumley						
Owner's Representative – (Signature Date): James Rumley	10-8-2025					

#### Adams Soil Consulting, PLLC 1676 Mitchell Road Angier, NC 27501 919-414-6761

October 7th, 2025

This document is submitted in addition to the "Notice of Intent to Construct" submittal package previously supplied to the local health department in pursuant to G.S. 130A-336.1

RE: Magnolia Acres Lot # 56. 341 Magnolia Acres Ln. Fuquay Varina 27526 (Harnett County) PIN# (0633-15-1163)

To whom it may concern:

This letter is to notify the Harnett County Environmental Health Department that the construction of the wastewater system has been completed. The system was installed to acceptable construction standards. The installation was installed in conformance with the original construction documents as shown on the attached NOI. This document may serve as "Authorization to Operate" the installed system. The installed accepted status system utilized EZFLOW product by Infiltrator.

#### **Operation and Management Program**

Have the effluent filter in the septic tank cleaned periodically by a professional. Have the solids pumped out of the septic tank every 3-5 years by a professional. Maintain adequate vegetative cover over the drainfield. Keep surface waters away from the tank and drainfield. Do not pour grease or oil down the sink. Contact a professional for periodic maintenance.

Alex Adams

Adams Soils Consulting, PLLC NC Licensed Soil Scientist #1247



#### North Carolina Onsite Wastewater Contractor Inspector Certification Board Authorized Onsite Wastewater Evaluator Permit Option for Non-Engineered Systems Notice of Intent (NOI) to Construct

x_New ExpansionRepair RelocationRelocation of Repair Area
Owner or Legal Representative Information: James Rumley Name: Caruso Homes
Mailing address: 110 Horizon Drive - Suite 320 City: Raleigh State: NC Zip: 27615  Phone: 240-886-3229 Email: jrumley@carusohomes.com
Authorized Onsite Wastewater Evaluator Information:  Name: Alex Adams  Certification #: AOWE# 10021E  Mailing address: 1676 Mitchell Road  City: Angier  State: NC Zip: 27501  Phone: 919-414-6761  Email: alexadams@bcsoil.com
Phone: 919-414-6761 Email: alexadams@bcsoil.com  Site Location Information:  Site address: Lot #56 (Magnolia Acres) 341 Magnolia Acres Ln - Fuquay-Varina NC 27501  Tax parcel identification number or subdivision lot, block number of property: PIN# 0633-15-1163  County: Harnett
System Information: Accepted Status  Wastewater System Type: Type III (b)  Daily Design Flow: 480 gallons/day  Saprolite System:YesXNo
Facility Type: X_Residential4 # Bedrooms8 Maximum # of Occupants Business
Requird_Attachments:x_Plat_or_Siteplanx_ Evaluation of Soil and Site Features by Licensed Soil Scientist
Attest: On this the 6th day of April by signature below I hereby attest that the information required to be included with this NOI to Construct is accurate and complete to the best of my knowledge. Furthermore, I hereby attest that I have adhered to the laws and rules governing onsite wastewater systems in the state of North Carolina.  This NOI shall expire on 6th day of April 2030.
Signature of Authorized Onsite Wastewater Evaluator:
Disclosure: The owner may apply for a building permit for the project upon submitting a complete NOI to Construct and the fee required (if any) to the local health department. An onsite wastewater system authorized by an authorized onsite wastewater evaluator shall be transferable to a new owner with the consent of the authorized onsite wastewater evaluator.
Local Health Department Receipt Acknowledgement:  Signature of Local Health Department Representative:  Date:

#### Adams Soil Consulting, PLLC 1676 Mitchell Road Angier, NC 27501 919-414-6761

alexadams@bcsoil.com

\_\_\_\_\_

April 30, 2025 Project #2110

"This AOWE/PE submittal is pursuant to and meets the requirements of G.S. 130A-336.2

RE: Magnolia Acres -Lot #56 – 341 Magnolia Acres Ln. – Fuquay-Varina, NC - 4-bedroom Single Family Residence (PIN# 0633-15-1163)

To whom it may concern:

Adams Soil Consulting (ASC) conducted a preliminary soil evaluation on the above referenced parcel to determine the areas of soils which are suitable for subsurface wastewater disposal systems (conventional & LPP). The soil/site evaluation was performed using hand auger borings during moist soil conditions based on the criteria found in the State Subsurface Rules 15ANCAC 18E. From this evaluation, ASC is providing the attached septic system design for a new single-family home sized for a 480 gallon/day septic system.

The suitable soils found on the subject property were somewhat variable in the initial and repair areas. The area designated for the initial/primary septic system (see attached septic plan) was found to contain soils with greater than 24 inches in depth before a restrictive horizon was encountered.

The initial and primary septic fields for the new home were sized based on a flow rate of 480 gallons/day and utilizing Accepted Status system for the initial and a PPBPS repair system. Any unauthorized site disturbance, filling, soil removal, or layout changes may result in the permit being revoked.

The septic installer contractor shall install the repair (if needed) system on contour, see attached site plan for the primary system and repair. No underground utilities, water lines, or sprinkler systems shall be placed into the initial or repair septic areas. Installation must meet all state and local county regulations for septic system installation. The trenches must be installed in the same location as the site plan. If flags trench flags are missing at the time of installation, they must be remarked by Adams Soil Consulting staff. Contact Alex Adams at 919-414-6761. A preconstruction conference is required with the septic installer prior to construction activities at least 14 days in advance of construction activities.

This report does not guarantee the future function of any waste water disposal system installed.

If you have any questions regarding the findings on the attached site plan or in this report, please feel free to contact me anytime.

Sincerely,

Alex Adams

NC Licensed Soil Scientist #1247 AOWE Certification: 10021E





House footprint to be field staked by surveyor and system verified prior to any construction


\*Septic area must not be altered by construction activities.

\*\*No cuts of 2' or greater within within 15' of septic area

\*\*\* Recommend protective barrier around septic field during construction.

\*If plumbing is not sufficient a pump tank will be required to septic field


# Magnolia Acres Lot 56 4 BR Harnett County



## MAGNOLIA ACRES LANE

50' PUBLIC R/W

INITIAL: 18 TB Lines 2-4 (405') Accepted Status Pressure Manifold REPAIR: Lines 1,5-7 (295') PPBPS Pressure Manifold



Adams Soil Consulting 919—414—6761 LT Tre

LT

Tre

House footprint to be field staked by surveyor and system verified prior to any construction

\*Septic area must not be altered by construction activities.

\*\*No cuts of 2' or greater within within 15' of septic area

\*\*\* Recommend protective barrier around septic field during construction.


\*If plumbing is not sufficient a pump tank will be required to septic field

## Magnolia Acres Lot 56

4 BR

Harnett County


Area to be disturbed for septic purposes only.



## MAGNOLIA ACRES LANE

50' PUBLIC R/W

INITIAL:18 TB Lines 2-4 (405') Accepted Status Pressure Manifold REPAIR: Lines 1,5-7 (295') PPBPS Pressure Manifold



Adams Soil Consulting 919—414—6761 LT Tre

LT

Tre

#### PRESSURE MANIFOLD DESIGN - REPAIR SYSTEM

# of BDR: 4 Daily Flow: 480 gal/day L.T.A.R.: 0.3000 gal/day/sq.ft

Septic Tank: 1200 gals Pump Tank: 1200 gals Sq. Foot: 885 System Type: PPBPS-Horizontal

Number of Taps:  $\underline{4}$  Length of Trenches:  $\underline{295}$  ft(See Tap Chart for Details)

Depth of Trenches: 18 in Manifold Length: 42 in

Manifold Diameter: 4in sch 80pvc Tap Configuration: 6 in spacing 1 side(s) of manifold

Supply Line: length: 160 ft Diameter: 2 in sch 40pvc

Friction Loss + Fitting Loss: 8.11 ft(supply line length + 70' for fittings in pump tank)

Design Head: 2 ft Elevation Head: 6.00 ft

Total Head: 16.11 ft Pump to Deliver: 39.81 gals/min at 16.11 ft head

Dosing Volume: <u>245</u> gals,

Drawdown: 245 gals divided by  $\underline{20}$  gals/in =  $\underline{12.2}$  inches

Simplex Control Panel required; elapsed time meter and cycle counter required; Floats to be determined by type of pump tank used. A septic tank filter is required.

#### **TAP CHART**

Benchma	rk <u>0</u>	is = 100.00	set at				Design Head:	2		
Pump tank e	lev.	<u>0</u>	100.00	Pump elev.	95.00		Manifold elev.	101.00		# of Panels
line	color	rod read	Elevation	length	hole size	flow/tap	gal/day	trench area	LINE LTAR	(PPBPS)
1	Orange		100.00	70	3/4in SCH 80	10.1	121.78	210	0.5799	16
5	Orange		100.00	95	3/4in SCH 40	12.5	150.72	285	0.5288	22
6	Red		100.00	80	3/4in SCH 80	10.1	121.78	240	0.5074	18
7	Blue		100.00	50	1/2in SCH 40	7.11	85.73	150	0.5715	12
			100.00			0	0.00	0	#DIV/0!	0
			100.00			0	0.00	0	#DIV/0!	0
			100.00			0	0.00	0	#DIV/0!	0
			100.00			0	0.00	0	#DIV/0!	0
			100.00			0	0.00	0	#DIV/0!	0
			100.00			0	0.00	0	#DIV/0!	0
			Total Feet =	295	gal/min =	39.81		LTAR =	0.3000	
			Feet Required =	267	Velocity =	3.81		(Itar + 5%)	0.3150	
Total # of Pa	nels (PPBPS)	68		Des. Flow	480			(Itar w/50% red)	0.6000	
% of Dose V	ol.	0		Pump Run=	12.06			(Itar + 5%)	0.6300	
Dose Volume	е	245		Tank Gal/IN	<u>20</u>					
Dose Pump	Time	6.15		Elev. Head	6.00					
Drawdown in	n Inches	12.2								
Comment	s:									

Page 1 of 1 PROPERTY ID #: 0633-15-1163 COUNTY: Harnett


#### SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

(Complete all fields in full) DATE EVALUATED: 4/25/2025 OWNER: Caruso Homes ADDRESS: PROPOSED FACILITY: Single Family 4 BR PROPOSED DESIGN FLOW (.0400): 480 gpd PROPERTY SIZE: LOCATION OF SITE: 341 Magnolia Acres Ln. Fuquay Varina 27526 PROPERTY RECORDED: Y WATER SUPPLY: ☑ Public ☐ Single Family Well ☐ Shared Well ☐ Spring ☐ Other \_\_\_\_\_ WATER SUPPLY SETBACK: EVALUATION METHOD: X Auger Boring Pit Cut TYPE OF WASTEWATER: V Domestic High Strength IPWW

EVALUATION METHOD: Auger Boring Pit Cut TYPE OF WASTEWATER: Domestic High Strength IPWW								PWW		
P R O F I			SOIL MO	RPHOLOGY	OTHER PROFILE FACTORS					
L E #	.0502 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	.0503 STRUCTURE/ TEXTURE	.0503 CONSISTENCE/ MINERALOGY	.0504 SOIL WETNESS/ COLOR	.0505 SOIL DEPTH	.0506 SAPRO CLASS	.0507 RESTR HORIZ	.0509 PROFILE CLASS & LTAR*	.0502(d) SLOPE CORRE CTION
		0-6	GR/LS	VFR,SEXP,NS						
	Linear	6-32	SBK C	FI,SEXP,S						
1	12%	32-40	SICL B/C	FR,SEXP,S	N.O	40"	N.O	N.O	P.S .3	5"
									.ა	
		0-10	GR/LS	VFR,SEXP,NS						
	Linear 12%	10-35	SBK C	FI,SEXP,S		34"	N.O	N.O	U/P.S	
2		35	AR		N.O				.3	5"
		0-6	GR/LS	VFR,SEXP,NS		40"	N.O	N.O	P.S .3	
	Linear	6-40	SBK C	FI,SEXP,S	N.O					5"
3	12%				N.O					
		0-4	GR/LS	VFR,SEXP,NS		40"	N.O	N.O		
	Linear	4-30	SBK C	FI,SEXP,S	N.O				P.S	-"
4	12%	30-40	WKSBKCL	FR,SEXP,S	14.0				.3	5"

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	
Available Space (.0508)	S	S	SITE CLASSIFICATION (.0509): U/P.S
System Type(s)	III B	III B	EVALUATED BY: Bobby Weaver/Alex Adams
Site LTAR	.3	.3	OTHER(S) PRESENT:
Maximum Trench Depth	18"	18"	
Comments:			

NCDHHS/DPH/EHS/OSWP Revised January 2024



VICINITY MAP

Not To Scale

#### SETBACKS: (ZONE RA-30)


FRONT - 35' REAR - 25' SIDE - 10'


CORNER SIDE - 20'




IMPERVIOUS SURF	FACE AREA
DESCRIPTION	AREA
HOUSE w/ PORCH	2,366 S.F.
HVAC/MISC	9 S.F.
DRIVEWAY & WALKS	1,365 S.F.
TOTAL (PROPOSED)=	3,740 S.F.
*TOTAL (ALLOWED)=	3,850 S.F.

\*PB 2025 PG 139





N/F ZONE 4 PROPERTIES, LLC DB 2022 PG 301



## MAGNOLIA ACRES LANE


50' PUBLIC R/W

CURVE RADIUS ARC LENGTH CH LENGTH CH BEARING
C1 333.98' 47.70' 47.66' \$44\*32'48"W

THIS PROPERTY MAY BE SUBJECT TO ANY AND ALL APPLICABLE DEED RESTRICTIONS, EASEMENTS, RIGHT-OF-WAY, UTILITIES AND RESTRICTIVE COVENANTS WHICH MAY BE OF RECORD OR IMPLIED

THIS DRAWING DOES NOT REFLECT AS-BUILT INFORMATION

PRELIMINARY PLAT NOT FOR RECORDATION, CONVEYANCES, OR SALES.



## LAND SERVICES, PLLC.

1917 Evans Road Cary, North Carolina 27513 Phone (919) 378—9316 Firm License # P-0873

HOUSE	LOCATION	PLOT	PLAN

FOR

#341 MAGNOLIA ACRES LANE

LOT 56, MAGNOLIA ACRES SUBDIVISION

Hector's Creek Township, Harnett County, North Carolina

CARUSO HOMES PROPERTY OF: \_

MAP BOOK \_\_\_\_\_\_ PAGE \_\_\_ 139 \_\_DEED REFERENCE.

DRAWN: JWW SURVEYED: N/A CHECKED: DMR DATE: APRIL 4, 2025



#### **CERTIFICATE OF LIABILITY INSURANCE**

DATE (MM/DD/YYYY) 1/22/2025

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to

the terms and conditions of the policy, c certificate holder in lieu of such endorse			rsemer	nt. A stateme	ent on this ce	ertificate does not confer righ	its to the	
PRODUCER	ment(3).	•	CONTAC	T Angela	Sensenia			
Wade Associates, LLC				PHONE (252) 631 - 5269 FAX (252) 649 - 2443				
250 Pollock St.			E-MAIL	SS: asensen:		(A/C, NO):		
						RDING COVERAGE	NAIC #	
New Bern NC 28560				RA: Lloyd's			A1122J	
INSURED	INSURE							
Alex Adams, DBA: Adams Soil Con	sulting	3	INSURE					
1676 Mitchell Rd.	INSURE							
			INSURE					
Angier NC 275	01		INSURE					
COVERAGES CER	TIFICATI	E NUMBER: 25-26				REVISION NUMBER:		
C RTI ICAT A B ISS D OR A P RT CL SIONS AND CONDITIONS O S CH P	IR NT TAIN TH	FTR OR CONDITION O AN INS RANC A ORD DB T LI ITS SHO N A HAV B	I CONT	RACT OR OTH	RDOC BDHRINI	DABOV ORTH POLIC PR NT ITHR SPCTTO HICHT SSBCTTOALLTH TRS	HIS	
LTR TYPE OF INSURANCE	INSD WVD			(MM/DD/YYYY)	(MM/DD/YYYY)	LIMITS		
COMMERCIAL GENERAL LIABILITY						ACH OCC RR NC DA A TOR NT D		
CLAI S- AD OCC R						PR IS S ( a occurrence)		
						D P (Any one person)		
						P RSONAL ADV IN R		
N'LA R AT LI ITAPPLI S P R:						N RALA R AT		
POLIC CT LOC						PROD CTS-CO P/OPA		
OTH R: AUTOMOBILE LIABILITY	$\vdash$					ÇO BIŅ DSIN L LI IT		
AN A TO						( a accident)  BODIL IN R (Per person)		
ALLOND SCHOLD						BODIL IN R (Per accident)		
A TOS A TOS NON-O N D A TOS A TOS						PROP RT DA A		
HIR DA TOS A TOS						(Per accident)		
UMBRELLA LIAB OCC R	$\vdash$					ACH OCC RR NC		
EXCESS LIAB CLAI S- AD						A R AT		
D D R T NTION	1							
WORKERS COMPENSATION						P R OTH- STAT T R		
AND EMPLOYERS' LIABILITY  AN PROPRI TOR/PARTN R/ C TIV	i					.L. ACH ACCID NT		
O IC R/ B R CL D D (Mandatory in NH)	N/A					.L. DIS AS - A PLO		
If yes describe under D SCRIPTION O OP RATIONS below						.L. DIS AS - POLIC LI IT		
A Errors & Omissions		PSN0040221161		1/31/2025	1/31/2026	ach Occurrence	\$1,000,000	
						eneral Aggregate	\$1,000,000	
DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES	S (ACORD 1	101, Additional Remarks Schedule, m	ay be atta	ched if more spac	ce is required)			
CERTIFICATE HOLDER			CANC	ELLATION				
*FOR INFORMATIONAL PURPOSES ONLY* XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX				SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.				
xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	xxxxx		AUTHORIZED REPRESENTATIVE					
xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx				N Whitsett/RACHEL N Page 1				

House footprint to be field staked by surveyor and system verified prior to any construction


Septic area must not be altered by construction activities.

\*No cuts of 2' or greater within within 15' of septic area

Recommend protective barrier around septic field during construction.

\*If plumbing is not sufficient a pump tank will be required to septic field

## Magnolia Acres ASBUILTS Lot 56 4BR Harnett County



### MAGNOLIA ACRES LANE

50' PUBLIC R/W

INITIAL: 18" TB Lines 1-4 (405') **Accepted Status** Pressure Manifold REPAIR: 18" TB Lines 5-8 (275') **PPBPS** Pressure Manifold



Adams Soil Consulting 919-414-6761