

North Carolina 2018 - R402.1.5 Total UA

**Property**

, NC 27546
Model: CC 1584
Community: NA

Organization

Southern Energy Management
Justin Smith

Inspection Status

Results are projected

Builder

Template - Caviness & Cates - CC 1584 - C: Caviness and Cates
CC 1584 slab

This report is based on a proposed design and does not confirm field enforcement of design elements.

Building UA

Elements	NC Reference	As Designed
Ceilings	47.5	41.8
Above-Grade Walls	112.0	86.6
Windows, Doors and Skylights	64.6	58.9
Slab Floor:	88.6	115.7
Framed Floors	0.0	0.0
Foundation Walls	0.0	0.0
Rim Joists	0.0	0.0
Overall UA (Design must be equal or lower):	312.7	303.0

Requirements

✓	R402.1.5	Total UA alternative compliance passes by 3.1%.	The proposed home meets the UA requirement by 3.1%
✓	R402.3.2	Average SHGC: 0.30 Max SHGC: 0.30	Average SHGC of 0.30 is greater than the maximum of 0.30.
✓	R402.4.2.2	Air Leakage Testing	Air sealing is 0.24 CFM50 / ft ² Shell Area. It must not exceed 0.30 CFM50 / ft ² Shell Area.
✓	R402.5	Area-weighted average fenestration SHGC	Area-weighted average fenestration SHGC is 0.3. The maximum allowed value is [No Limit].
✓	R402.5	Area-weighted average fenestration U-Factor	
✓	R404.1	Lighting Equipment	
✓	Mandatory Checklist	Mandatory code requirements that are not checked by Ekotrope must be met.	2015 IECC Mandatory Checklist must be checked as complete.
✓	R403.3.1	Duct Insulation	Duct insulation meets the requirements specified in North Carolina 2018 Code Section 403.3.1.
✓	403.3.3	Duct Testing	

Design exceeds requirements for North Carolina 2018 Prescriptive compliance by 3.1%.

Name:	Justin Smith	Signature:	<i>Justin Smith</i>
Organization:	Southern Energy Management	Digitally signed:	9/5/25 at 3:22 PM

Ekotrope RATER - Version 4.1.2.3703

North Carolina 2018 Prescriptive compliance results calculated using Ekotrope RATER's energy and code compliance algorithm, including appropriate amendments.
Ekotrope RATER is a RESNET Accredited HERS Rating Tool. All results are based on data entered by Ekotrope users.
Ekotrope disclaims all liability for the information shown on this report.

Building Summary

Property
 , NC 27546
 Model: CC 1584
 Community: NA

Organization
 Southern Energy Management
 Justin Smith

Inspection Status
 Results are projected



Template - Caviness & Cates - CC 1584 - CZ 4 slab - H
 CC 1584 slab

Builder
 Caviness and Cates

General Building Information

Number Of Bedrooms: 3	Number Of Floors: 1
Conditioned Floor Area [sq. ft.]: 1,584	Has Electric Vehicle Ready Space: No
Unconditioned, attached garage? Yes	Conditioned Volume [cu. ft.]: 14,256
Total Units in Building: 1	Residence Type: Single family detached
Number of Floors in Building: N/A	Floor Number: N/A
Model: CC 1584	Community: NA
RESNET/IECC 2006-2018 Climate Zone: 4A	IECC 2021 Climate Zone: 3A

Envelope Components

Slab

Name	Library Type	Perimeter	Floor Grade	Carpet R	Exposed Masonry Area	Surface Area	Location	Enclosing
slab	Uninsulated	182	On Grade	1	0	1,584.0 ft²	Exposed Exterior	Conditioned Space

Slab Library List

Name	Wall Construction Type	Slab Completely Insulated?	Underslab Insulation Width [ft]	Perimeter Insulation Depth [ft]	Perimeter Insulation R Value	Perimeter Insulation Is Exterior	Thermal Break	Effective R-value
Uninsulated	Wood Frame / Other	No	0	0	0	No	No	0.00

Wall

Name	Library Type	Surface Color	Solar Absorptance	Surface Area	Location	Effective R-value
1st floor ambient	R 19 FG G1 16" O.C	Medium	0.75	1,427.0 ft²	Exposed Exterior	16.805
1st floor garage	R 19 FG G1 16" O.C	Medium	0.75	212.0 ft²	Unconditioned, attached garage	16.805

Glazing

Name	Library Type	Wall Assignment	Foundation Wall Assignment	Is Operable	Overhang Depth	Overhang Ft To Top	Overhang Ft To Bottom	Orientation	Surface Area
front unshaded	35/30	1st floor ambient		Yes	0	0	0	Southeast	30.0 ft²
left unshaded	35/30	1st floor ambient		Yes	0	0	0	Southwest	23.0 ft²
rear unshaded	35/30	1st floor ambient		Yes	0	0	0	Northwest	63.5 ft²
right unshaded	35/30	1st floor ambient		Yes	0	0	0	Northeast	30.0 ft²

Glazing Library List

Name	Shgc	U-factor
35/30	0.3	0.350

Building Summary

Property NC 27546 Model: CC 1584 Community: NA	Project & Plan Template - Caviness & Cates - CC 1584 - CZ 4 slab - HE CC 1584 slab	Organization Southern Energy Management Justin Smith	Inspection Status Results are projected Builder Caviness and Cates
--	---	---	---

Opaque Door									
Name	Library Type	Wall Assignment	Foundation Wall Assignment	Emittance	Solar Absorptance	Surface Color	Surface Area	Location	Effective U-factor
front entry	Fiberglass R-5	1st floor ambient		0.9	0.75	Medium	20.0 ft²	Exposed Exterior	0.200
garage entry	Fiberglass R-5	1st floor garage		0.9	0.75	Medium	18.0 ft²	Unconditioned, attached garage	0.200

Roof Insulation									
Name	Library Type	Attic Exterior Area [ft²]	Clay or Concrete Roof Tiles	Does the Roof have Eaves?	Effective R-Value after eaves	Surface Color	Solar Absorptance	Surface Area	Location
attic	R 38 Attic BLOWN FG G1 2x6 16"OC NO Radiant Barrier	2,328.48	No	No	-	Dark	0.9	1,584.0 ft²	Vented Attic

Roof Insulation Library List			Whole House Infiltration		
Name	Has Radiant Barrier	Effective R-value	Infiltration	Measurement Type	Shelter Class
R 38 Attic BLOWN FG G1 2x6 16"OC NO Radiant Barrier	No	37.887	1140 CFM at 50 Pa	Blower-door tested	4

Mechanicals, Lights & Water

Lighting					
% Interior Fluorescent Lighting	% Interior LED Lighting	% Exterior Fluorescent Lighting	% Exterior LED Lighting	% Garage Fluorescent Lighting	% Garage LED Lighting
0	100	0	100	0	100

Conditioning Equipment						
Name	Library Type	Serial Number	Heating Percent Load	Cooling Percent Load	Hot Water Percent Load	Location
Water Heating	z 50 gal. 0.92 EF Elec		0%	0%	100%	Unspecified
whole house heat pump	z 24k 14.3 SEER2 7.5 HSPF2		100%	100%	0%	Unspecified

Equipment Type: z 24k 14.3 SEER2 7.5 HSPF2		Equipment Type: z 50 gal. 0.92 EF Elec	
Equipment Type	Air Source Heat Pump	Equipment Type	Residential Water Heater
Fuel Type	Electric	Fuel Type	Electric
Distribution Type	Forced Air	Distribution Type	Hydronic Delivery (Radiant)
Motor Type	ECM (Variable Speed)	Hot Water Efficiency	0.92 Energy Factor
Heat Pump System Type	Ducted Split System	Tank Capacity (gal.)	50
Heating Efficiency	7.5 HSPF2	Hot Water Capacity [kBtu/h]	40
Heating Capacity [kBtu/h]	24	Recovery Efficiency	0.98
Backup Fuel Type	Electric		
Switchover Temperature [°F]	0		
Backup Heating Efficiency	1 COP		
Use default Supplemental Heat	Yes		
Cooling Efficiency	14.3 SEER2		
Cooling Capacity [kBtu/h]	24		

Building Summary

Property

, NC 27546
Model: CC 1584
Community: NA

Project & Plan

Template - Caviness & Cates - CC 1584 - CZ 4 slab - HE
CC 1584 slab

Organization

Southern Energy Management
Justin Smith

Inspection Status

Results are projected
Builder
Caviness and Cates

Distribution System

Distribution Type	Forced Air
Heating Equipment	whole house heat pump
Cooling Equipment	whole house heat pump
Sq. Feet Served	1,584
# Return Grilles	2
Supply Duct R Value	8
Return Duct R Value	8
Supply Duct Area [ft²]	427.68
Return Duct Area [ft²]	158.4
Leakage to Outdoors	63 CFM @ 25Pa (3.98 / 100 ft²)
Total Leakage	63 CFM25
Total Leakage Duct Test Conditions	Post-Construction
Use Default Flow Rate	Yes
Duct 1	
Duct Location	Attic (well vented)
Percent Supply Area	100
Percent Return Area	100

Water Distribution

Water Fixture Type	Standard
Use Default Hot Water Pipe Length	No
Hot Water Pipe Length [ft]	89
At Least R3 Pipe Insulation?	No
Hot Water Recirculation System?	No
Drain Water Heat Recovery?	No

Appliances & Notes

Clothes Dryer

Cef	3.01
Fuel Type	Electric
Field Utilization	Timer Controls
Is Outside Conditioned Space	No
Defaults Type	HERS Reference
Is Ventless	No
Is Heat Pump	No
Clothes Dryer Available	Yes

Clothes Washer

Label Energy Rating	153 kWh/Year
Annual Gas Cost	\$12.00
Electric Rate	\$0.11/kWh
Gas Rate	\$1.22/Therm
Capacity	3.31
Imef	2.1547
Defaults Type	Custom
Load Type	Front-load
Loads Per Week	6
Is Outside Conditioned Space	No
Clothes Washer Available	Yes

Dishwasher

Dishwasher Defaults Type	Custom
Dishwasher Size	Standard
Dishwasher Efficiency	270 kWh
Annual Gas Cost	\$22.23
Electric Rate	\$0.12/kWh
Gas Rate	\$1.09/Therm
Is Outside Conditioned Space	No
Dishwasher Available	Yes

Appliances and Controls

Thermostat Cooling Setpoint	*** 75.0
Thermostat Heating Setpoint	*** 70.0
Range/Oven Fuel	Electric
Convection Oven?	No
Induction Range?	No
Range/Oven Outside Conditioned Space?	No
Refrigerator Consumption	538 kWh/Year
Refrigerator Outside Conditioned Space?	No

Notes

initial inputs JSm 09/05/25

- confirm HVAC specs
- modeled to worst case orientation
- confirm cfl lighting %

Building Summary

Property , NC 27546 Model: CC 1584 Community: NA	Project & Plan Template - Caviness & Cates - CC 1584 - CZ 4 slab - HE CC 1584 slab	Organization Southern Energy Management Justin Smith	Inspection Status Results are projected Builder Caviness and Cates
--	---	---	---

Components Not Found: Foundation Wall, Foundation Wall Library List, Framed Floor, Rim Joist, Skylight, Mechanical Ventilation, Onsite Generation, Solar Generation, Dehumidifier, Whole House Fan, Whole House Fan Library List, HVAC Grading (Not Conducted), Ceiling Fan