

Dimension Notes

1. All exterior wall to wall dimensions are to face of sheathing unless noted otherwise
2. All interior wall dimensions are to face of stud unless noted otherwise
3. All exterior wall to truss dimensions are to face of stud unless noted otherwise

Roof Area = 2531.1 sq.ft.
Ridge Line = 66 ft.
Hip Line = 0 ft.
Horiz. OH = 132 ft.
Raked OH = 97.35 ft.
Decking = 87 sheets

All Walls Shown Are Considered Load Bearing

▲ = Indicates Left End of Truss


(Reference Engineered Truss Drawing)

Do Not Erect Trusses Backwards



Products							
PlotID	Length	Product	Plies	Net Qty			
GDH	13' 0"	1-3/4"x 11-7/8" LVL Kerto-S	3	3			

Truss Placement Plan SCALE: NTS = Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards



	BUILDER	Cates Building, Inc.	CITY / CO.	Lillington / Harnett	THIS I These t the build sheets f	
	JOB NAME	Lot 25 Duck Landing	ADDRESS	355 Hookbill Lane	is respoi the over walls, an regardin or online Bearing prescrip	
	PLAN	CC1584	MODEL	Roof		
	SEAL DATE	Seal Date	DATE REV.	7/21/25	( derived foundate than 300 be retain	
	QUOTE#	B0725-3572	DRAWN BY	Johnnie Baggett	specifie retained	
	JOB#	J0725-3561	SALES REP.	Scot Duncan	Sign	

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables ( derived from the prescriptive Code requirements ) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Johnnie Baggett

Johnnie Baggett



Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444