

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

July 29, 2025

Subject: Lot 1
3180 Oakridge River Road
Fuquay Varina, NC 27526
Plan Revision Letter
Harnett County Permit #: SFD2505-0171

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The 2 - #4 bars shown on the plans for the continuous footings will not be installed. Removing the rebar from the footings is acceptable.

The footings without the rebar meet all the requirements of the 2018 North Carolina Building Code for Residences.



07 29 2025 EDT