

**HARNETT COUNTY ENVIROMENTAL HEALTH**File/Permit #: SFD2505-0172

CDP #: \_\_\_\_\_

**IMPROVEMENT PERMIT (IP)**☐ New☐ Expansion☐ Repair☐ System Relocation☐ Change of UseOwner: GRIFFIN JONATHAN VAN JR & GRIFFIN KELLY TApplicant: GRIFFIN JONATHAN VAN JR & GRIFFIN KELLY TProperty Location: 79 MILL BEND DR FUQUAY-VARINA, NC 27526PIN/Lot Identifier: 0644-56-4523.000 Lot 65Subdivision: OLD MILL VILLAGELot #: 65 Block: \_\_\_\_\_ Section: \_\_\_\_\_Facility Type: SFD 69' x 58' Number of bedrooms: 4 Number of Occupants: 8 Other: \_\_\_\_\_Design Daily Flow: 480 GPD LTAR (Initial): .35 gpd/ft<sup>2</sup> LTAR (Repair): .35 gpd/ft<sup>2</sup>Wastewater System Type: 25% Reduction System (Initial)Pump Required: ☐ Yes ☐ No ☒ May be required Usable Depth to Limiting Condition (Initial): 37"Wastewater System Type 50% Reduction System (Repair)Pump Required: ☒ Yes ☐ No ☐ May be required Usable Depth to Limiting Condition (Repair): 37"Effluent Standard: ☒ DSE ☐ HSE ☐ Other: \_\_\_\_\_ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: \_\_\_\_\_**Permit conditions:**No Foundation or Gutter Drains to be Directed Towards Septic System.  
No Cutting or Grading of Soil in Septic or Septic Repair Area.

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Ren LevoczDate: 06/12/2025Authorized Agent's Signature: *Ren Levocz*Expiration Date: 06/12/2030**CONSTRUCTION AUTHORIZATION (CA)**☐ New☐ Expansion☐ Repair☐ System Relocation☐ Change of UseOwner: GRIFFIN JONATHAN VAN JR & GRIFFIN KELLY TApplicant: GRIFFIN JONATHAN VAN JR & GRIFFIN KELLY TProperty Location: 79 MILL BEND DR FUQUAY-VARINA, NC 27526PIN/Lot Identifier: 0644-56-4523.000 Lot 65Subdivision: OLD MILL VILLAGELot #: 65 Block: \_\_\_\_\_ Section: \_\_\_\_\_Facility Type: SFD 69' x 58' Number of bedrooms: 4 Number of Occupants: 8 Other: \_\_\_\_\_Design Daily Flow: 480 GPD LTAR: .35 gpd/ft<sup>2</sup>Effluent Standard: ☒ DSE ☐ HSE ☐ Other: \_\_\_\_\_ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: \_\_\_\_\_**Installation Requirements/Conditions**Wastewater System Type: 25% Reduction SystemPump Required: ☐ Yes ☐ No ☒ May be requiredSeptic Tank Size: 1,000 gallons Total Trench Length: 390' feet Trench Spacing: 9' feet on centerPump Tank Size: \_\_\_\_\_ gallons Maximum Trench Depth: 18"-22" inches Soil Cover: 6" inchesTrench Width: 36" inches Distribution Method: ☒ Serial ☐ D-Box or Parallel ☐ Pressure Manifold ☐ Other: \_\_\_\_\_Artificial Drainage Required: Yes ☐ No ☒ If yes, please specify details: \_\_\_\_\_Management Entity Required: ☐ Yes ☒ No Minimum O&M Requirements: \_\_\_\_\_**Permit conditions:**No Foundation or Gutter Drains to be Directed Towards Septic System.  
No Cutting or Grading of Soil in Septic or Septic Repair Area.

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Ren LevoczDate: 06/12/25Authorized Agent's Signature: *Ren Levocz*Expiration Date: 06/12/2030

Owner/Legal Representative Signature: \_\_\_\_\_

Date: \_\_\_\_\_

**\*See attached site sketch**

# Harnett County Environmental Health

## SITE SKETCH

PIN 0644-56-4523.000

Permit Number SFD2505-0172

GRIFFIN JONATHAN VAN JR & GRIFFIN KELLY T

OLD MILL VILLAGE Lot 65

Applicant's Name

Ren Levocz

Subdivision/Section/Lot Number

06/12/2025

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

