



YES

CRAWL SPACE AREA: 1280 S.F.  
1500 S.F. PER 1 S.F. VENTS = 0.05 S.F.  
REQUIRED VENTS W/ V.B. + ONE VENT  
WITHIN 3' OF EA. CORNER @ 122 S.I.

1. DOWEL JOISTS UNDER ALL PARTITIONS
2. SUBLE TO BE MINIMUM P.T. WOOD 2TB
3. MAINTAIN MIN 12" BELOW GRADE
4. 18" BELOW JOISTS TO STUDS OR AS REQUIRED FOR MECHANICAL EQUIPMENT
5. PROVIDE VAPOR BARRIER AT CRANFL SPACE
6. FOUNDATION VENTS TO BE 8"X16"X16" (FIELD LOCATE)
7. CRANFL SPACE ACCESS TO BE 22"X36" (FIELD LOCATE)
8. NOTED TO BE FLUSH FRAMING (1" AS GUIDED)
9. ANCHOR BOLTS 8 6'-0" O.C. AND 15'-0" FROM EACH CORNER (EMBED 8" MIN IN SLAB GROUT)
10. GC TO REVIEW TRUSS SHOP DRAWINGS & NOTIFY DESIGNER IF REQUIRED POINT LOAD PERS OR BEARING WALLS ARE ADDED TO FOUNDATION PLAN
11. FRAMING SPANS BASED ON #2 SFF

