# KATHRYN-A, B, C, D

PLAN ID: 2290 - RIGHT HAND - NORTH CAROLINA

DATE: REVISION:

01/16/2018 INITIAL RELEASE OF PLANS


02/25/2019 ADDED LUXURY SHOWER TO SET


02/28/2020 CLIENT REVISIONS

07/02/2020 CLIENT REVISIONS

02/22/2021 CLIENT REVISIONS

04/16/2025 ELEVATION A/B REVISIONS





MODEL '2290' SQUARE FOOTAGES		
AREA	ELEV 'A'	
Ist FLOOR	2291 SF	
TOTAL LIVING	2291 SF	
GARAGE	609 SF	
PORCH	15 SF	
COVERED PATIO	202 SF	

Eagle Creek
Lot 16
210 Gilmer Street
Fuquay Varina, NC 27526

FHORM

finerica's Builder


8025 Arrowidge Blvd., Charlotte, NC 28273 704.377.2006


'K A THR VN'

LAN REV DATE

COPYRIGHT PROPERTY OF DR HORTON NOT TO BE REPRODUCED


SHEET NUMBER











Front Elevation 'D'

SCALE: 1/4"=1'-0" AT 22"X34" LAYOUT 1/8"=1'-0" AT 11"X17" LAYOUT


SCALE: |/4"=|'-0" AT 22"X34" LAYOUT |/8"=|'-0" AT ||"X|7" LAYOUT

QUICK VIEW

N REV DATE

COPYRIGHT PROPERTY OF DR HORTON NOT TO BE REPRODUCED

SHEET NUMBER



GRADE CONDITIONS MAY VARY FOR INDIVIDUAL SITE FROM THAT SHOWN. BUILDER SHALL VERIFY AND COORDINATE PER ACTUAL SITE CONDITIONS. WINDOW HEAD HEIGHTS: IST FLOOR = 7'-6" U.N.O. ON ELEVATIONS. 2ND FLOOR = 7'-0" U.N.O. ON ELEVATIONS. ROOFING: PITCHED SHINGLES PER DEVELOPER. WINDOWS: MANUFACTURER PER DEVELOPER. DIVIDED LITES AS SHOWN ON THE EXTERIOR ELEVATIONS ENTRY DOOR: AS SELECTED BY DEVELOPER. GARAGE DOORS: AS SELECTED BY DEVELOPER, RAISED PANEL AS SHOWN. ALL EXTERIOR MATERIALS TO BE INSTALLED PER MANUFACTURER'S WRITTEN INSTRUCTIONS. PROTECTION AGAINST DECAY: (ALL PORTIONS OF A PORCH, SCREEN PORCH OR DECK FROM THE BOTTOM OF THE HEADER DOWN, INCLUDING POST, RAILS, PICKETS, STEPS AND FLOOR STRUCTURE.) INSULATION: PER TABLE NIIO2.I.2. R-15 BATTS MINIMUM. VERIFY CEILING WITH ATTIC ABOVE: R-38 BATTS MINIMUM. VERIFY FLOOR OVER GARAGE: R-19 BATTS MINIMUM. VERIFY ATTIC KNEEWALL: R-19 BATTS MINIMUM. VERIFY CRAWL SPACE FLOORING: R-19 BATTS MINIMUM. VERIFY

# KEY NOTES:

MASONRY:

ADHERED STONE VENEER AS SELECTED BY DEVELOPER. HEIGHT AS NOTED.

MASONRY FULL BRICK AS SELECTED BY DEVELOPER. HEIGHT AS NOTED.

3 MASONRY FULL STONE AS SELECTED BY DEVELOPER. HEIGHT AS NOTED.

4 8" SOLDIER COURSE. 5 ROWLOCK COURSE

# TYPICALS:

7 CORROSION RESISTANT SCREEN LOUVERED VENTS, SIZE AS NOTED.

8 CODE APPROVED TERMINATION CHIMNEY CAP.

9 CORROSION RESISTANT ROOF TO WALL FLASHING. CODE COMPLIANT FLASHING PER NCRC R905.2.8.3

O STANDING SEAM METAL ROOF, INSTALL PER MANUFCATURER'S WRITTEN INSTRUCTIONS.

III DECORATIVE WROUGHT IRON. SEE DETAILS.

2 VINYL SHAKE SIDING PER DEVELOPER WITH VINYL CORNER TRIM PER DEVELOPER. (AT SPECIFIED LOCATIONS: FIBER CEMENT SHAKE SIDING PER DEVELOPER W/ IX4 CORNER TRIM BOARD.)

13 VINYL LAP SIDING PER DEVELOPER WITH VINYL CORNER TRIM PER DEVELOPER. (AT SPECIFIED LOCATIONS:

FIBER CEMENT LAP SIDING PER DEVELOPER W/ IX4 CORNER TRIM BOARD.) 14 VINYL WAVY SIDING PER DEVELOPER WITH VINYL CORNER TRIM PER DEVELOPER. (AT SPECIFIED LOCATIONS:

FIBER CEMENT WAYY SIDING PER DEVELOPER W IX4 CORNER TRIM BOARD.)

15 VINYL BOARD AND BATT SIDING PER DEVELOPER WITH VINYL CORNER TRIM PER DEVELOPER. (AT SPECIFIED LOCATIONS: FIBER CEMENT PANEL SIDING W IX3 BATTS AT 12" O.C. PER DEVELOPER W IX4 CORNER TRIM BOARD.)

16 VINYL TRIM SIZE AS NOTED (AT SPECIFIC LOCATIONS:

IX FIBER CEMENT TRIM OR EQUAL, U.N.O. SIZE AS NOTED

FYPON SHUTTERS, TYPE AS SHOWN. SIZE AS NOTED.  $\frac{11}{2}$  (AT SPECIFIC LOCATIONS: FALSE VINYL SHUTTERS, TYPE AS SHOWN. SIZE AS NOTED.)

ALL WINDOWS WHOSE OPENING IS LESS THAN 24" ABOVE THE FINISH FLOOR AND WHOSE OPENING IS GREATER THAN 72" ABOVE THE OUTSIDE WALKING SURFACE MUST HAVE WINDOW OPENING LIMITING DEVICES COMPLYING WITH THE NCRC SECTION R312.2.1 AND R312.2.2.


TRUSS MANUFACTURE TO VERIFY HEELS PER COMMUNITY STANDARDS, BUILDER TO VERIFY PRIOR TO CONSTRUCTION


AT SINGLE FAMILY DETACHED PLANS:
PREFINISHED VENTED
SOFFIT AT EAVE PER MANUFACTURER.
(VERIFY FIRE SEPARATION DISTANCE FOR SOFFIT PROTECTION PER NCRC
SECTION R302.1.1 AND TABLE R302.1)


## N.C ATTIC VENT CALCULATION FOR MODEL '2290': 1:150 RATIO. THE NET FREE VENTILATING AREA SHALL NOT BE LESS THAN (PER NCRC SECTION R806.2) 1/150 OF THE AREA OF THE SPACE VENTILATED, PROVIDED SQUARE INCH VENT FOR EVERY 150 SQUARE INCHES OF CEILING THAT AT LEAST 50 PERCENT AND NOT MORE THAN 80 PERCENT OF THE REQUIRED VENTILATING AREA IS PROVIDED BY VENTILATORS LOCATED IN THE UPPER PORTION OF THE SPACE \*144 SQ. IN. = 1 SQ. FT. BLDG. CEILING (SF) X 144 = BLDG (SQ. IN.) BLDG. (SQ. IN.) / 150 = SQ. IN. OF VENT REQUIRED TO BE VENTILATED AT LEAST 3 FEET ABOVE THE EAVE OR CORNICE VENTS WITH THE BALANCE OF THE REQUIRED VENTILATION PROVIDED BY EAVE OR CORNICE VENTS. SQ. IN. OF VENT REQUIRED / 2 = 50% AT HIGH & 50% AT LOW. **ROOF AREA I:** = 3116 SF I. EXCLOSED ATTIC/RAFTER SPACES REQUIRING LESS THAN I SO FT OF VENTILATION MAY BE VENTED WITH CONTINUOUS SOFFIT VENTILATION ONLY. 3116 SQ. FT. X 144 = 448704 SQ. IN. 448704 SQ. IN. / 150 = 2991.36 SQ. IN. OF VENT REQ'D 2. ENCLOSED ATTIC/RAFTER SPACES OVER UNCONDITIONED SPACE MAY BE VENTED WITH CONTINUOUS SOFFIT VENT ONLY 2291.36 Sq. IN. / 2 = 1495.68 Sq. IN 1495.68 SQ. IN. OF VENT AT HIGH & 1495.68 SQ. IN. OF VENT AT LOW REQUIRED. GENERAL CONTRACTOR SHALL VERIFY THE NET FREE VENTILATION OF THE VENT PRODUCT SELECTED BY OWNER. VERIFY WITH MANUFACTURER OF HIGH AND LOW VENTS TO BE USED FOR MINIMUM CALCULATED VENTS REQUIRED. THE REQUIRED VENTILATION SHALL BE MAINTAINED. PROVIDE INSULATION STOP SUCH THAT INSULATION DOES NOT OBSTRUCT FREE AIR MOVEMENT AS REQUIRED BY THE BUILDING OFFICIAL. ALL OVERLAP FRAMED ROOF AREAS SHALL HAVE OPENINGS BETWEEN THE ADJACENT ATTICS IN THE ROOF SHEATHING (AS ALLOWED BY THE STRUCTURAL ENGINEER) TO ALLOW PASSAGE AND ATTIC VENTILATION BETWEEN THE TWO OR ISOLATED ATTIC SPACES SHALL BE VENTED INDEPENDENTLY TO CBC REQUIREMENTS. PER DEVELOPER, AT ALL CANTILEVERED FLOORS, CANTILEVERED ARCHITECTURAL POP-OUTS, AND ANY DOUBLE FRAMING PROJECTIONS THAT ARE SEPARATED FROM THE VENTING CALCULATIONS SHOWN ABOVE, PROVIDE A CONTINUOUS 2" CORROSION RESISTANT SOFFIT VENT AT UNDERSIDE OF FRAMED ELEMENT. NOTES: - ALL ROOF DRAINAGE SHALL BE PIPED TO STREET OR APPROVED DRAINAGE FACILITY. - TRUSS MANUFACTURER SHALL SUBMIT STRUCTURAL CALCS AND SHOP DRAWINGS TO THE BUILDER'S GENERAL CONTRACTOR AND BUILDING DEPARTMENT FOR REVIEW PRIOR TO FABRICATIONS. - DASHED LINES INDICATE WALL BELOW. - ALL PLUMBING VENTS SHALL BE COMBINED INTO A MINIMUM AMOUNT OF ROOF PENETRATIONS, ALL ROOF PENETRATIONS SHALL OCCUR TO THE REAR OF THE MAIN RIDGE. - LOCATE GUTTER AND DOWNSPOUTS PER BUILDER. - PITCHED ROOFS AS NOTED. N.C ATTIC VENT CALCULATION FOR MODEL '2290': 1:300 RATIO. (PER NCRC SECTION R806.2) AS AN ALTERNATE TO THE 1/150 RATIO LISTED ABOVE, THE NET FREE CROSS-VENTILATION AREA MAY BE REDUCED TO 1/300 WHEN A CLASS I OR II VAPOR RETARDER IS INSTALLED I SQUARE INCH VENT FOR EVERY 300 SQUARE INCHES OF CEILING ON THE WARM - IN - WINTER SIDE OF THE CEILING. \*144 SQ. IN. = 1 SQ. FT. BLDG. CEILING (SF) X 144 = BLDG (SQ. IN.) BLDG. (SQ. IN.) / 300 = SQ. IN. OF VENT REQUIRED GENERAL CONTRACTOR SHALL VERIFY THE NET FREE VENTILATION OF THE VENT PRODUCT SELECTED BY OWNER. SQ. IN. OF VENT REQUIRED / 2 = 50% AT HIGH & 50% AT LOW. VERIFY WITH MANUFACTURER OF HIGH AND LOW VENTS TO BE USED FOR MINIMUM CALCULATED VENTS REQUIRED. THE REQUIRED VENTILATION SHALL BE MAINTAINED. PROVIDE INSULATION STOP SUCH THAT INSULATION DOES NOT OBSTRUCT FREE AIR MOVEMENT AS REQUIRED ROOF AREA I: = 3116 SF 3116 SQ. FT. X 144 = 448704 SQ. IN. 448704 SQ. IN. / 300 = 1495.68 SQ. IN. OF VENT REQ'D BY THE BUILDING OFFICIAL. 1495.68 Sq. In. / 2 = 747.84 Sq. In ALL OVERLAP FRAMED ROOF AREAS SHALL HAVE 747.84 SQ. IN. OF VENT AT HIGH & 747.84 SQ. IN. OF VENT AT LOW REQUIRED. OPENINGS BETWEEN THE ADJACENT ATTICS IN THE ROOF SHEATHING (AS ALLOWED BY THE STRUCTURAL ENGINEER) TO ALLOW PASSAGE AND ATTIC VENTILATION BETWEEN THE TWO OR ISOLATED ATTIC SPACES SHALL BE VENTED INDEPENDENTLY TO CBC REQUIREMENTS. PER DEVELOPER, AT ALL CANTILEVERED FLOORS, CANTILEVERED ARCHITECTURAL POP-OUTS, AND ANY DOUBLE FRAMING PROJECTIONS THAT ARE SEPARATED FROM THE VENTING CALCULATIONS SHOWN ABOVE, PROVIDE A CONTINUOUS 2" CORROSION RESISTANT SOFFIT VENT AT UNDERSIDE OF FRAMED ELEMENT.

BUILDER TO PROVIDE (2) LAYERS OF UNDERLAYMENT AT

ANY ROOF W/ A SLOPE FROM 2:12 TO LESS THAN 4:12







# NOTES

- PROVIDE GROUNDING ELECTRICAL ROD PER LOCAL CODES.
- PROVIDE AND INSTALL ARC FAULT CIRCUIT-INTERRUPTERS (AFCI) AS REQUIRED BY NATIONAL
- ELECTRICAL CODE (NEC) AND MEETING THE REQUIREMENTS OF ALL GOVERNING CODES.
   ALL EXHAUST FANS SHALL HAVE BACKDRAFT DAMPERS.
- FAN/LIGHTS IN WET/DAMP LOCATIONS SHALL BE LABLED "SUITABLE FOR WET OR DAMP LOCATIONS."
   ELECTRICAL SYSTEMS ARE SHOWN FOR INTENT ONLY. THESE SYSTEMS SHALL BE ENGINEERED BY OTHERS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROPER INSTALLATION AND PLACEMENT.
- PROVIDE AND INSTALL LOCALLY CERTIFIED SMOKE DETECTORS AND CO2 DETECTORS AS REQUIRED BY NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) AND MEETING THE REQUIREMENTS OF ALL GOVERNING CODES.
- NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) AND MEETING THE REQUIREMENTS OF ALL GOVERNING CODE
   PROVIDE AND INSTALL GROUND FAULT CIRCUIT-INTERRUPTERS (GFI) AS REQUIRED BY NATIONAL ELECTRICAL
  CODE (NEC) AND MEETING THE REQUIREMENTS OF ALL GOVERNING CODES.
- ELECTRICAL CONTRACTOR TO PROVIDE REQUIRED DIRECT HOOK-UPS/CUTOFFS.
- HVAC CONTRACTOR TO VERIFY THERMOSTAT LOCATIONS.
- ALL ELECTRICAL AND MECHANICAL EQUIPMENT (FURNACES, A/C UNITS, ELECTRICAL PANELS, SANITARY SUMP PITS, DRAIN TILE SUMP, AND WATER HEATERS) ARE SUBJECT TO RELOCATION DUE TO FIELD CONDITIONS.
- PROVIDE POWER, LIGHT AND SWITCH AS REQUIRED FOR ATTIC FURNACE PER CODE AND MANUFACTURER'S WRITTEN INSTRUCTIONS.

# I FGEND:

ф	DUPLEX OUTLET	ф	CEILING MOUNTED INCANDESCENT LIGHT FIXTURE
₩P/GFI	WEATHERPROOF GFI DUPLEX OUTLET	Ю	WALL MOUNTED INCANDESCENT
∯ 6FI	GROUND-FAULT CIRCUIT-INTERRUPTER DUPLEX OUTLET	Ι Υ	RECESSED INCANDESCENT LIGHT FIXTURE
ф	HALF-SWITCHED DUPLEX OUTLET	Ф	(VP) = VAPOR PROOF
<b>\$</b> 220∨	220 VOLT OUTLET	•	CEILING MOUNTED LED LIGHT FIXTURE (VP) = VAPOR PROOF
0	REINFORCED JUNCTION BOX	•	EXHAUST FAN (VENT TO EXTERIOR)
\$	WALL SMITCH		EXHAUST FAN/LIGHT COMBINATION (VENT TO EXTERIOR)
\$ 3	THREE-WAY SWITCH		ELIOPECCENT LIGHT ELVIDE
\$4	FOUR-WAY SWITCH		FLUORESCENT LIGHT FIXTURE
СН	CHIMES		TECH HUB SYSTEM
무	PUSHBUTTON SWITCH		CEILING FAN (PROVIDE ADEQUATE SUPPORT)
(SD)	IIOV SMOKE ALARM W BATTERY BACKUP	✓	CEILING FAN WITH INCANDESCENT
6/0	IIOV SMOKE ALARM CO2 DETECTOR COMBO		LIGHT FIXTURE (PROVIDE ADEQUATE SUPPORT)
T	THERMOSTAT	$\vdash$ $\otimes$	GAS SUPPLY WITH VALVE
PH	TELEPHONE		
TV	TELEVISION	— <del>∤</del> B	HOSE BIBB
	ELECTRIC METER	-+ <sub>CM</sub>	I/4" WATER STUB OUT
	ELECTRIC PANEL	У	
	DISCONNECT SWITCH	<del> </del>	WALL SCONCE

# SHEET INDEX:

S-0	COVER SHEET	
S-0.1	GENERAL STRUCTURAL NOTES	
S 3MS A	MONOLITHIC SLAB FOUNDATION PLAN	elevation 'a
S 3MS B	MONOLITHIC SLAB FOUNDATION PLAN	ELEVATION 'E
S 3MS C	MONOLITHIC SLAB FOUNDATION PLAN	ELEVATION 'C
S 3MS D	MONOLITHIC SLAB FOUNDATION PLAN	ELEVATION 'C
S 3SW A	STEM WALL SLAB FOUNDATION PLAN	ELEVATION 'A
S 3SW B	STEM WALL SLAB FOUNDATION PLAN	ELEVATION 'E
S 3SW C	STEM WALL SLAB FOUNDATION PLAN	ELEVATION 'C
S 3SW D		ELEVATION 'C
3 33W D	STEW WALL SLAD FOUNDATION FLAN	LLLVATION L
S 3CS A	CRAWL SPACE FOUNDATION PLAN	ELEVATION 'A
S 3CS B	CRAWL SPACE FOUNDATION PLAN	ELEVATION 'E
S 3CS C	CRAWL SPACE FOUNDATION PLAN	ELEVATION 'C
S 3CS D	CRAWL SPACE FOUNDATION PLAN	ELEVATION 'C
S 4 A	ROOF FRAMING PLAN	ELEVATION 'A
S 4 B	ROOF FRAMING PLAN	ELEVATION 'E
S 4 C	ROOF FRAMING PLAN	ELEVATION 'C
S 4 D	ROOF FRAMING PLAN	ELEVATION 'C
DS-1	BRACED WALL DETAILS	
DS-2	HOLD DOWN DETAILS	
DS-3	BRACED WALL NOTES & DETAILS	
DS-4	PORTAL FRAME DETAILS	

DS-2 HOLD DOWN DETAILS

DS-3 BRACED WALL NOTES & DETAILS

DS-4 PORTAL FRAME DETAILS

DS-5 MISCELLANEOUS FRAMING DETAILS

DS-6 MISCELLANEOUS FRAMING DETAILS


DS-7 MONOLITHIC SLAB FOUNDATION DETAILS

DS-8 STEM WALL SLAB FOUNDATION DETAILS

DS-9 CRAWL SPACE FOUNDATION DETAILS

DS-10 NOT USED

DS-11 NOT USED



1900 AM DRIVE, SUITE 201, QUAKERTOWN, PA 18951 www.kse-eng.com (215) 804-4449

# KATHRYN PLAN ID: 2290

# NORTH CAROLINA

THESE DRAWINGS ARE TO BE USED IN CONJUNCTION WITH AND COORDINATED WITH THE ARCHITECTURAL, CIVIL, MECHANICAL, ELECTRICAL, AND PLUMBING DRAWINGS. THIS COORDINATION IS NOT THE RESPONSIBILITY OF THE STRUCTURAL ENGINEER OF RECORD (SER). SHOULD ANY DISCREPANCIES BECOME APPARENT, THE CONTRACTOR SHALL NOTIFY KSE ENGINEERING, P.C. BEFORE CONSTRUCTION BEGINS. IT IS THE INTENT OF THE ENGINEER LISTED ON THESE DOCUMENTS THAT THESE DOCUMENTS BE ACCURATE, PROVIDING LICENSED PROFESSIONALS CLEAR INFORMATION. EVERY ATTEMPT HAS BEEN MADE TO PREVENT ERROR. THE BUILDER AND ALL SUBCONTRACTORS ARE REQUIRED TO REVIEW ALL OF THE INFORMATION CONTAINED IN THESE DOCUMENTS PRIOR TO THE COMMENCEMENT OF ANY WORK. THE ENGINEER IS NOT RESPONSIBLE FOR ANY PLAN ERRORS, OMISSIONS, OR MISINTERPRETATIONS UNDETECTED AND NOT REPORTED TO THE ENGINEER PRIOR TO CONSTRUCTION. ALL CONSTRUCTION MUST BE IN ACCORDANCE TO THE INFORMATION FOUND IN THESE DOCUMENTS.

THIS PLAN HAS BEEN DESIGNED PER THE 2018 EDITION OF THE NC RESIDENTIAL CODE. WHERE FRAMING, FOUNDATION, OR OTHER STRUCTURAL ITEMS DO NOT COMPLY WITH THE PRESCRIPTIVE METHODS OF THE CODE, THOSE ITEMS HAVE BEEN DESIGNED IN ACCORDANCE WITH ACCEPTED ENGINEERING PRACTICE PER NCRC R301.1.3.

**DESIGN SPECIFICATIONS:** 

DESIGN BUILDING CODE (REFERRED TO HEREIN AS 'THE BUILDING CODE'):

• 2018 NORTH CAROLINA RESIDENTIAL CODE AND ENGINEERED DESIGN

DESIGN LIVE LOADS:

■ ROOF = 20 PSF (LOAD DURATION FACTOR=1.25)

• UNINHABITABLE ATTICS WITH LIMITED STORAGE = 20 PSF (WHERE SPECIFIED ON PLANS)

• HABITABLE ATTICS AND ATTICS SERVED WITH FIXED STAIRS = 30 PSF

• FLOOR = 40 PSF

• FLOOR (SLEEPING AREAS) = 30 PSF

■ DECK = 40 PSF ■ BALCONY = 40 PSF

• STAIRS = 40 PSF

# DESIGN DEAD LOADS:

■ ROOF TRUSS = 17 PSF (TC=7, BC=10)

• FLOOR TRUSS = 15 PSF (TC=10, BC=5)

• FLOOR JOIST = 10 PSF

• STANDARD BRICK = 40 PSF

QUEEN ANNE BRICK = 25 PSF

■ TILE = 10 PSF (WHERE NOTED ON PLANS)

\*NOTE: STRUCTURAL FRAMING HAS NOT BEEN DESIGNED FOR GRANITE, MARBLE OR OTHER MATERIALS HEAVIER THAN THE ABOVE LOADING UNLESS SPECIFICALLY NOTED ON PLANS.\*.

DESIGN WIND LOADS:

• ULTIMATE WIND SPEED = 115 MPH

• EXPOSURE CATEGORY = B

ASSUMED SOIL BEARING CAPACITY = 2000 PSF

ASSUMED LATERAL SOIL PRESSURE = 60 PCF

FROST DEPTH = 12"

SEISMIC DESIGN CATEGORY = B

ENGINEERED LUMBER SHALL HAVE THE FOLLOWING MINIMUM DESIGN VALUES:

• PRI-40s SERIES (DEPTH, SERIES AND SPACING PER PLANS)

■ LVL: E=2,000,000 PSI, F<sub>B</sub>=3,100 PSI, F<sub>V</sub>=285 PSI, F<sub>C</sub>=750 PSI

KSE
ENGINEER

AM DRIVE, SUITE 201, QUAKERTOWN,



ID: 2290

ryn, Plan ID

, Kathr 115 N


Project #: 088-18001

Designed By: JPS

Checked By:

Issue Date: 1/24/19

Re-Issue: 8/3/20 Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34





# GENERAL STRUCTURAL NOTES:

- 1. THE DESIGN PROFESSIONAL WHOSE SEAL APPEARS ON THESE DRAWINGS IS THE STRUCTURAL ENGINEER OF RECORD (SER) FOR THIS PROJECT. THE SER BEARS THE RESPONSIBILITY OF THE PRIMARY STRUCTURAL ELEMENTS AND THE PERFORMANCE OF THIS STRUCTURE. NO OTHER PARTY MAY REVISE, ALTER, OR DELETE ANY STRUCTURAL ASPECTS OF THESE CONSTRUCTION DOCUMENTS WITHOUT WRITTEN CONSENT OF KSE ENGINEERING, P.C. OR THE SER. FOR THE PURPOSES OF THESE CONSTRUCTION DOCUMENTS, THE SER AND KSE ENGINEERING SHALL BE CONSIDERED THE SAME ENTITY
- 2. THE STRUCTURE IS ONLY STABLE IN ITS COMPLETED FORM. THE CONTRACTOR SHALL PROVIDE ALL REQUIRED TEMPORARY BRACING DURING CONSTRUCTION TO STABILIZE THE STRUCTURE
- 3. THE SER IS NOT RESPONSIBLE FOR CONSTRUCTION SEQUENCES, METHODS, OR TECHNIQUES IN CONNECTION WITH THE CONSTRUCTION OF THIS STRUCTURE. THE SER WILL NOT BE HELD RESPONSIBLE FOR THE CONTRACTOR'S FAILURE TO CONFORM TO THE CONTRACT DOCUMENTS, SHOULD ANY NON-CONFORMITIES OCCUR.
- 4. THE SER DOES NOT CERTIFY DIMENSIONAL ACCURACY OR ARCHITECTURAL LAYOUT INCLUDING ROOF GEOMETRY. THE SER ASSUMES NO LIABILITY FOR CHANGES MADE TO THESE PLANS BY OTHERS, OR FOR CONSTRUCTION METHODS, OR FOR ANY DEVIATION FROM THE PLANS. THE SER SHALL BE NOTIFIED PRIOR TO CONSTRUCTION IF ANY DISCREPANCIES ARE NOTED ON THE PLANS.
- 5. ANY STRUCTURAL ELEMENTS OR DETAILS NOT FULLY DEVELOPED ON THE CONSTRUCTION DRAWINGS SHALL BE COMPLETED UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER. THESE SHOP DRAWINGS SHALL BE SUBMITTED TO KSE ENGINEERING FOR REVIEW BEFORE ANY CONSTRUCTION BEGINS. THE SHOP DRAWINGS WILL BE REVIEWED FOR OVERALL COMPLIANCE AS IT RELATES TO THE STRUCTURAL DESIGN OF THIS PROJECT. VERIFICATION OF THE SHOP DRAWINGS FOR DIMENSIONS, OR FOR ACTUAL FIELD CONDITIONS, IS NOT THE RESPONSIBILITY OF THE SER OR KSE ENGINEERING, P.C.
- RESPONSIBILITY OF THE SER. THE CONTRACTOR SHALL VERIFY THE FIELD CONDITIONS FOR ACCURACY AND REPORT ANY DISCREPANCIES TO KSE ENGINEERING, P.C. BEFORE CONSTRUCTION BEGINS 7. THE SER IS NOT RESPONSIBLE FOR ANY SECONDARY STRUCTURAL

VERIFICATION OF ASSUMED FIELD CONDITIONS IS NOT THE

- ELEMENTS OR NON-STRUCTURAL ELEMENTS, EXCEPT FOR THE ELEMENTS SPECIFICALLY NOTED ON THE STRUCTURAL DRAWINGS 8. THIS STRUCTURE AND ALL CONSTRUCTION SHALL CONFORM TO ALL APPLICABLE SECTIONS OF THE BUILDING CODE AND ANY LOCAL
- CODES OR RESTRICTIONS. 9. DO NOT SCALE DRAWINGS. WRITTEN DIMENSIONS TAKE PRECEDENCE OVER SCALED DIMENSIONS. ALL DIMENSIONS ARE TO FACE OF STUD OR TO FACE OF FRAMING UNLESS OTHERWISE NOTED
- 10. PROVIDE MOISTURE PROTECTION AND FLASHING PER ARCHITECTURAL DETAILS.

- 1. FOUNDATIONS SHALL BE CONSTRUCTED IN ACCORDANCE WITH CHAPTER 4 OF THE BUILDING CODE.
- 2. CONTRACTOR IS SOLELY RESPONSIBLE FOR VERIFYING THE SUITABILITY OF THE SITE SOIL CONDITIONS AT THE TIME OF CONSTRUCTION. THE BUILDER SHALL FURNISH ANY AND ALL REPORTS RECEIVED FROM THE GEOTECHNICAL ENGINEER ON THE STUDY OF THE PROPOSED SITE TO THE DESIGNER, STRUCTURAL ENGINEER, AND GENERAL
- 3. MAXIMUM DEPTH OF UNBALANCED FILL AGAINST MASONRY WALLS TO BE AS SPECIFIED IN THE BUILDING CODE.
- 4. THE SER HAS NOT PERFORMED A SUBSURFACE INVESTIGATION. OWNER OR THE CONTRACTOR. SHOULD ANY ADVERSE SOIL CONDITION BE ENCOUNTERED, THE SER MUST BE CONTACTED BEFORE PROCEEDING.
- 5. THE BOTTOM OF ALL FOOTINGS SHALL EXTEND BELOW THE FROST LINE FOR THE REGION IN WHICH THE STRUCTURE IS TO BE CONSTRUCTED, BUT NOT LESS THAN A MINIMUM OF 12" BELOW GRADE. ALL FOOTINGS TO HAVE A MINIMUM PROJECTION OF 2" ON EACH SIDE OF FOUNDATION WALLS. MAXIMUM FOOTING PROJECTION SHALL NOT EXCEED THE THICKNESS OF THE FOOTING.
- 6. WOOD SILL PLATES SHALL BE ANCHORED TO THE FOUNDATION WITH 1/2" ANCHOR BOLTS WITH MINIMUM 7" EMBEDMENT, SPACED A MAXIMUM of 6'-0" o.c. install minimum 2 anchor bolts per section, 12" MASONRY MAXIMUM FROM CORNERS. ½" DIAMETER x 8" LONG SIMPSON TITEN HD OR USP SCREW-BOLT+ SCREWS MAY BE SUBSTITUTED ON A 1 FOR 1 BASIS.
- 7. ANY FILL SHALL BE PLACED UNDER THE DIRECTION OR RECOMMENDATION OF A LICENSED PROFESSIONAL ENGINEER. THE RESULTING SOIL SHALL BE COMPACTED TO A MINIMUM OF 95% MAXIMUM DRY DENSITY.
- 8. EXCAVATIONS OF FOOTINGS SHALL BE LINED TEMPORARILY WITH A 6 MIL POLYETHYLENE MEMBRANE IF PLACEMENT OF CONCRETE DOES NOT OCCUR WITHIN 24 HOURS OF EXCAVATION.
- 9. NO CONCRETE SHALL BE PLACED AGAINST ANY SUBGRADE CONTAINING WATER, ICE, FROST, OR LOOSE MATERIAL.
- 10. PROVIDE FOUNDATION WATERPROOFING AND DRAIN WITH POSITIVE SLOPE TO OUTLET AS REQUIRED BY SITE CONDITIONS (SEE ARCHITECTURAL PLANS AND DETAILS).
- 11. NONE OF THE FOUNDATION DESIGNS IN THESE DOCUMENTS ARE SUITABLE FOR INSTALLATION IN SHRINK/SWELL CONDITIONS. REFER TO GEOTECHNICAL ENGINEER FOR APPROPRIATE DESIGN.
- 12. LOTS SHALL BE GRADED TO DRAIN SURFACE WATER AWAY FROM FOUNDATION WALLS. THE GRADE SHALL FALL A MINIMUM OF 6 INCHES WITHIN THE FIRST TEN FEET.
- 13. CRAWL SPACE TO BE GRADED LEVEL AND CLEAR OF ALL DEBRIS.
- 14. PROVIDE MINIMUM 6 MIL APPROVED VAPOR BARRIER. ALL JOINTS TO BE LAPPED MINIMUM 12" AND SEALED.

# CONCRETE & REINFORCING

- 1. CONCRETE DESIGN BASED ON ACI 318 AND ACI 318.1 OR ACI 332. CONCRETE SHALL HAVE A NORMAL WEIGHT AGGREGATE AND A MINIMUM COMPRESSIVE STRENGTH (f'c) = 3,000 PSI MINIMUM AT 28 DAYS PER CODE (VARIES W/ WEATHER), UNLESS OTHERWISE NOTED ON THE PLAN.
- 2. CONCRETE SHALL BE PROPORTIONED, MIXED, AND PLACED IN ACCORDANCE WITH THE LATEST EDITIONS OF ACI 318: "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE" AND ACI 301: "SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS".
- 3. AIR ENTRAINED CONCRETE MUST BE USED FOR ALL STRUCTURAL ELEMENTS EXPOSED TO FREEZE/THAW CYCLES AND DEICING CHEMICALS. AIR ENTRAINMENT AMOUNTS (IN PERCENT) SHALL BE WITHIN -1% TO +2% OF 5% FOR FOOTINGS AND EXTERIOR SLABS.
- 4. NO ADMIXTURES SHALL BE ADDED TO ANY STRUCTURAL CONCRETE WITHOUT WRITTEN PERMISSION OF THE SER. WATER ADDED TO CONCRETE ON SITE SHALL NOT EXCEED THAT ALLOWED BY THE MIX
- 5. CONCRETE SLABS-ON-GRADE SHALL BE CONSTRUCTED IN ACCORDANCE WITH ACI 302.1R: "GUIDE FOR CONCRETE SLAB AND SLAB CONSTRUCTION".
- CONTROL OR SAW CUT JOINTS (CUT OR TOOLED) SHALL BE SPACED IN INTERIOR SLABS-ON-GRADE AT A MAXIMUM OF 15'-0" O.C. AND IN EXTERIOR SLABS-ON-GRADE AT A MAXIMUM OF 10'-0" UNLESS OTHERWISE NOTED. CARE SHALL BE TAKEN TO AVOID RE-ENTRANT
- 7. CONTROL OR SAW CUT JOINTS SHALL BE PRODUCED USING CONVENTIONAL CUT OR TOOLED PROCESSES WITHIN 4 TO 12 HOURS AFTER THE SLAB HAS BEEN FINISHED.
- 8. ALL WELDED WIRE FABRIC (W.W.F.) FOR CONCRETE SLABS-ON-GRADE SHALL BE PLACED AT MID-DEPTH OF SLAB. THE W.W.F. SHALL BE SECURELY SUPPORTED DURING THE CONCRETE POUR. FIBROUS CONCRETE REINFORCEMENT, OR POLYPROPYLENE FIBERS MAY BE USED IN LIEU OF W.W.F. APPLICATION OF POLYPROPYLENE FIBERS PER CUBIC YARD OF CONCRETE SHALL BE PER MANUFACTURER AND COMPLY WITH ASTM C1116, ANY LOCAL BUILDING CODE REQUIREMENTS AND SHALL MEET OR EXCEED CURRENT INDUSTRY STANDARD
- 9. POLYPROPYLENE REINFORCING TO BE 100% VIRGIN, CONTAINING NO REPROCESSED OLEFIN MATERIALS AND SPECIFICALLY MANUFACTURED FOR USE AS CONCRETE SECONDARY REINFORCEMENT
- 10. STEEL REINFORCING BARS SHALL BE NEW BILLET STEEL CONFORMING TO ASTM A615, GRADE 60.
- 11. DETAILING, FABRICATION, AND PLACEMENT OF REINFORCING STEEL SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF ACI 315: "MANUAL OF STANDARD PRACTICE FOR DETAILING CONCRETE STRUCTURES".
- 12. HORIZONTAL FOOTING AND WALL REINFORCEMENT SHALL BE CONTINUOUS AND SHALL HAVE 90° BENDS, OR CORNER BARS WITH
- THE SAME SIZE/SPACING AS THE HORIZONTAL REINFORCEMENT. 13. PROVIDE REINFORCEMENT LAP AS NOTED BELOW, UNLESS NOTED
- OTHERWISE: #4 BARS - 30" LENGTH #5 BARS - 38" LENGTH
- #6 BARS 45" LENGTH
- 14. WHERE REINFORCING DOWELS ARE REQUIRED, THEY SHALL BE EQUIVALENT IN SIZE AND SPACING TO THE VERTICAL REINFORCEMENT. THE DOWEL SHALL EXTEND 48 BAR DIAMETERS VERTICALLY AND 20 BAR DIAMETERS INTO THE FOOTING. SEE KSE FOUNDATION DETAILS.
- 15. WHERE FOOTING BOTTOMS ARE TO BE STEPPED AT SLOPING GRADE CONDITIONS, PROVIDE CONTINUOUS REINFORCING WITH Z BARS (TO MATCH FOOTING REINFORCING) AS REQUIRED.
- VERIFICATION OF THE ASSUMED VALUE IS THE RESPONSIBILITY OF THE 16. BAR SUPPORT ACCESSORIES SHALL BE PROVIDED IN ACCORDANCE WITH THE LATEST ACI MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCED CONCRETE STRUCTURES, EXCEPT THAT REINFORCING SHALL BE CHAIRED ON THE BOTTOM AND/OR THE SIDES ON BOLSTERS SPACED NOT MORE THAN 4 FEET ON CENTER. NO ROCKS, CMU, CLAY TILE, OR BRICK SHALL BE USED TO SUPPORT REINFORCING.
  - 17. FOR GRADE SUPPORTED SLABS, SLAB REINFORCING SHALL BE HELD IN PLACE BY BAR SUPPORTS AND ACCESSORIES AS DESCRIBED IN THE CRSI MANUAL OF STANDARD PRACTICE. BAR SUPPORTS SHALL BE SPACED A MAXIMUM OF 4'-0" O.C. BOTH WAYS IN STRAIGHT LINES ON THE MESH GRID.

- 1. ALL MASONRY SHALL CONFORM TO ASTM C-90, F'm=1500 PSI. ALL BRICK SHALL CONFORM TO ASTM C-216, F'm=1500 PSI. ALL MORTAR SHALL BE TYPE 'S' (TYPE 'M' BELOW GRADE) AND CONFORM TO ASTM C-270. COARSE GROUT SHALL CONFORM TO ASTM C-476 WITH A MAXIMUM AGGREGATE SIZE OF 36" AND A MINIMUM COMPRESSIVE STRENGTH OF 2,000 2. RAFTERS SHALL BE SUPPORTED BY PURLINS AND PURLIN BRACES PSI.
- 2. ALL MASONRY WORK SHALL BE IN ACCORDANCE WITH "BUILDING CODE REQUIREMENTS FOR MASONRY STRUCTURES" ACI 530/ASCE 5/TMS 402 AND "SPECIFICATIONS FOR MASONRY STRUCTURES" ACI 530.1/ ASCE 6/TMS 602.
- THE UNSUPPORTED HEIGHT OF SOLID MASONRY PIERS SHALL NOT EXCEED TEN TIMES THEIR LEAST DIMENSION. UNFILLED HOLLOW PIERS MAY BE USED IF THE UNSUPPORTED HEIGHT IS NOT MORE THAN FOUR TIMES THEIR LEAST DIMENSION.
- 4. EACH CRAWL SPACE PIER SHALL BEAR IN THE MIDDLE THIRD OF ITS RESPECTIVE FOOTING AND EACH GIRDER SHALL BEAR IN THE MIDDLE THIRD OF THE PIERS. PILASTERS TO BE BONDED TO PERIMETER FOUNDATION WALL.
- 5. TOP COURSE OF MASONRY SHALL BE GROUTED SOLID. 6. HORIZONTAL WALL JOINT REINFORCEMENT SHALL BE STANDARD 9 GAGE GALVANIZED LADDER OR TRUSS TYPE SPACED AT 16" O.C., UNLESS SHOWN OTHERWISE ON THE DRAWINGS.
- 7. SPLICED WIRE REINFORCEMENT SHALL BE LAPPED AT LEAST 6" AND CONTAIN AT LEAST ONE CROSS WIRE OF EACH PIECE OF REINFORCEMENT WITHIN THE 6". LAP WITH STANDARD 'T' AND 'L' SHAPED PIECES AT INTERSECTIONS AND CORNERS.

# WOOD FRAMING

- 1. SOLID SAWN WOOD FRAMING MEMBERS SHALL CONFORM TO THE SPECIFICATIONS LISTED IN THE LATEST EDITION OF THE "NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION": (NDS). UNLESS OTHERWISE NOTED, ALL WOOD FRAMING MEMBERS ARE DESIGNED TO
  - SPRUCE-PINE-FIR (SPF) WITH THE FOLLOWING MINIMUM DESIGN
- $E=1,400,000 \text{ PSI}, F_b=875 \text{ PSI}, F_v=135 \text{ PSI}$
- 1.1. FRAMING: SPF #2.
- 1.2. PLATES: SPF #2. 1.3. STUDS: SPF STUD GRADE.
- 2. ALL LUMBER EXPOSED TO WEATHER OR IN CONTACT WITH CONCRETE SHALL BE PRESERVATIVE TREATED SOUTHERN YELLOW PINE #2 OR
- 3. ANCHOR SILL PLATES IN ACCORDANCE W/ GENERAL STRUCTURAL NOTES.
- 4. ALL BEAMS SPECIFIED ARE MINIMUM SIZES ONLY. LARGER MEMBERS MAY BE SUBSTITUTED AS NEEDED FOR EASE OF CONSTRUCTION.
- 5. NAILS SHALL BE COMMON WIRE NAILS UNLESS OTHERWISE NOTED. 6. BOLT HOLES AND LEAD HOLES FOR LAG SCREWS SHALL BE IN
- ACCORDANCE WITH NDS SPECIFICATIONS. 7. INDIVIDUAL STUDS FORMING A COLUMN SHALL BE ATTACHED WITH (2) ROWS 10d NAILS @ 6" O.C. STAGGERED. THE STUD COLUMN SHALL BE FULLY BLOCKED AT ALL FLOOR LEVELS TO ENSURE PROPER LOAD TRANSFER. WALL SHEATHING SHALL BE NAILED TO EDGE OF EACH STUD.
- 8. FACE NAIL ALL MULTI-PLY BEAMS AND HEADERS WITH (2) ROWS 16d COMMON NAILS @ 16" O.C., STAGGERED, OR PER MANUFACTURER'S SPECIFICATIONS FOR ENGINEERED LUMBER. APPLY NAILING FROM BOTH FACES FOR (3) OR MORE PLIES.
- 9. FASTEN 4-PLY BEAMS WITH (1)  $\frac{1}{2}$ " DIAMETER THROUGH BOLT W/ NUTS AND WASHERS AT 12" O.C. STAGGERED TOP AND BOTTOM, 11/2" MINIMUM EDGE DISTANCE. (UNLESS OTHERWISE NOTED)
- 10. ALL BEAMS AND HEADERS SHALL HAVE (1)2x JACK STUD & (1)2x KING STUD UNLESS OTHERWISE NOTED. THE NUMBER OF STUDS INDICATED ON PLANS ARE THE TOTAL NUMBER OF JACK STUDS REQUIRED, UNLESS OTHERWISE NOTED.
- 11. PROVIDE KING STUDS AT EACH END OF HEADERS AS NOTED BELOW. (1) STUD UP TO 6' OPENING (2) STUDS UP TO 8' OPENING
- (3) STUDS UP TO 9' OPENING 12. ALL BEAMS TO BE CONTINUOUSLY SUPPORTED LATERALLY AND SHALL BEAR FULL WIDTH ON THE SUPPORTING WALLS OR COLUMNS INDICATED WITH A MINIMUM OF TWO STUDS, UNLESS OTHERWISE NOTED. ALL BEAM SPLICES SHALL OCCUR OVER SUPPORTS.
- 13. SOLID BLOCKING TO BE PROVIDED AT ALL POINT LOADS THROUGH FLOOR LEVELS TO THE FOUNDATION OR TO OTHER STRUCTURAL COMPONENTS. 14. ALL LUMBER SPECIFIED ON DRAWINGS IS INTENDED FOR DRY USE ONLY
- (MOISTURE CONTENT <19%) UNLESS OTHERWISE NOTED. 15. ALL WATERPROOFING AND FIRE SAFETY SYSTEMS ARE THE
- RESPONSIBILITY OF THE CONTRACTOR AND ARE TO BE DESIGNED AND DETAILED BY OTHERS. 16. ANY WOOD FRAME INTERIOR BEARING WALL STUDS THAT HAVE HOLES IN
- THE CENTER OF THE STUD UP TO 1" DIAMETER SHALL HAVE STUD PROTECTION SHIELDS. ALL HOLES OVER 1" IN DIAMETER FOR PLUMBING LINES, ETC. SHALL BE REPAIRED WITH SIMPSON HSS2 OR USP STS1 STUD SHOES, TYPICAL, UNLESS OTHERWISE NOTED.
- 17. BEARING WALLS SHALL BE SHEATHED ON NOT LESS THAN ONE SIDE WITH OSB OR GYPSUM BOARD. BRIDGING SHALL BE INSTALLED NOT GREATER THAN 4 FEET APART MEASURED VERTICALLY FROM EITHER END OF THE STUD IN LIEU OF SHEATHING.
- 18. DIAGONAL BRACING SHALL BE INSTALLED AT EACH END OF BASEMENT BEARING WALLS AND NOT MORE THAN 20' ON CENTER.

# EXTERIOR WOOD FRAMED DECKS:

- 1. DECKS ARE TO BE FRAMED IN ACCORDANCE WITH APPLICABLE BUILDING CODES AND AS REFERENCED ON THE STRUCTURAL PLANS.
- EITHER THROUGH CODE REFERENCES OR CONSTRUCTION DETAILS. 2. PRESERVATIVE TREATED WOOD FRAMING TO BE SOUTHERN YELLOW PINE #2 OR BETTER.
- 3. GUARD RAILS REQUIRED AT DECKS. DESIGN BY OTHERS TO MEET MINIMUM CODE REQUIREMENTS.
- 4. PROVIDE DECK LATERAL LOAD AND BRACING CONNECTIONS PER BUILDING

# RAFTER FRAMED ROOF CONSTRUCTION:

- PROVIDE 2x4x4'-0" RAFTER TIES AT 48" O.C. AS SHOWN ON THE PLAN. PURLIN BRACES SHALL NOT BEAR ON ANY CEILING JOIST, STRONGBACK OR HEADER UNLESS SPECIFICALLY
- SHOWN ON PLAN. RAFTERS MAY BE SPLICED AT PURLIN LOCATIONS. 3. CEILING JOISTS SHALL HAVE LATERAL SUPPORT W/ 1x4 FLAT BRACING ON TOP EDGE OF JOIST AT LOOSE JOIST ENDS (WHERE JOISTS NOT FASTENED TO RAFTERS) OR FULL DEPTH BLOCKING.
- FASTEN END OF BRACING TO RAFTER OR GABLE END FRAMING. 4. FASTEN RAFTER AND CEILING JOIST WITH (6) 12d NAILS UNLESS
- OTHERWISE NOTED. 5. PROVIDE VERTICAL 2x6 STRONGBACKS AT CEILING JOISTS @ 8'-0" O.C. TIE STRONGBACK ENDS TO GABLE STUDS OR RAFTERS WHERE POSSIBLE. PROVIDE BLOCKING BETWEEN TOP PLATES AND STRONGBACKS. PROVIDE 2x4 FLAT FASTENED TO EACH JOIST WITH (2) 12d NAILS. FASTEN STRONGBACK TO 2x4 FLAT WITH 12d NAILS @ 12" O.C. AND FASTENED TO EACH JOIST WITH (1) 12d TOENAIL.

# WOOD TRUSSES (FLOOR & ROOF):

- 1. THE WOOD TRUSS MANUFACTURER/FABRICATOR IS RESPONSIBLE FOR THE DESIGN OF THE WOOD TRUSSES. SUBMIT SEALED SHOP DRAWINGS AND SUPPORTING CALCULATIONS TO THE SER FOR REVIEW PRIOR TO FABRICATION. THE SER SHALL HAVE A MINIMUM OF (5) DAYS FOR REVIEW. THE REVIEW BY THE SER SHALL BE FOR OVERALL COMPLIANCE OF THE DESIGN DOCUMENTS. THE SER SHALL ASSUME NO RESPONSIBILITY FOR THE CORRECTNESS OF THE STRUCTURAL DESIGN FOR THE WOOD TRUSSES.
- 2. THE WOOD TRUSSES SHALL BE DESIGNED FOR ALL REQUIRED LOADINGS AS SPECIFIED IN THE LOCAL BUILDING CODE, THE ASCE STANDARD "MINIMUM DESIGN LOADS FOR BUILDINGS AND OTHER STRUCTURES." (ASCE 7), AND THE LOADING REQUIREMENTS SHOWN ON THESE SPECIFICATIONS. THE TRUSS DRAWINGS SHALL BE COORDINATED WITH ALL OTHER CONSTRUCTION DOCUMENTS AND PROVISIONS PROVIDED FOR LOADS SHOWN ON THESE DRAWINGS INCLUDING BUT NOT LIMITED TO HVAC EQUIPMENT, PIPING, AND ARCHITECTURAL FIXTURES ATTACHED TO
- 3. THE TRUSSES SHALL BE DESIGNED, FABRICATED, AND ERECTED IN ACCORDANCE WITH THE LATEST EDITION OF THE ANSI/TPI 1: "NATIONAL DESIGN STANDARD FOR METAL PLATE CONNECTED WOOD TRUSS CONSTRUCTION".
- 4. THE TRUSS MANUFACTURER SHALL PROVIDE ADEQUATE BRACING INFORMATION IN ACCORDANCE WITH "BUILDING COMPONENT SAFETY INFORMATION GUIDE TO GOOD PRACTICE FOR HANDLING, INSTALLING, RESTRAINING & BRACING OF METAL PLATE CONNECTED WOOD TRUSSES" (BCSI). THIS BRACING, BOTH TEMPORARY AND PERMANENT, SHALL BE SHOWN ON THE SHOP DRAWINGS. ALSO, THE SHOP DRAWINGS SHALL SHOW THE REQUIRED ATTACHMENTS FOR THE TRUSSES
- 5. THE CONTRACTOR IS RESPONSIBLE FOR INSTALLING TEMPORARY BRACING AND SHORING FOR THE FLOOR AND ROOF TRUSSES AS REQUIRED DURING CONSTRUCTION. AT A MINIMUM, CONTRACTOR SHALL FOLLOW THE REQUIREMENTS OF THE LATEST BCSI. THE CONTRACTOR SHALL KEEP A
- COPY OF THE BCSI SUMMARY SHEETS ON SITE. THE CONTRACTOR IS RESPONSIBLE FOR INSTALLING ALL PERMANENT TRUSS BRACING SHOWN IN THE STRUCTURAL DRAWINGS AND IN THE TRUSS DESIGNS. ALL CONTINUOUS LATERAL BRACING OF WEBS REQUIRES BRACES. REFER TO BCSI SUMMARY SHEET B3 FOR TYPES OF DIAGONAL BRACES TO PROVIDE AT EACH CONTINUOUS LATERAL BRACE LINE. SUCH DIAGONAL BRACES SHALL NOT BE SPACED MORE THAN 20 FEET O.C. DIAGONAL BRACES SHALL BE FASTENED TO EACH TRUSS WEB WITH A MINIMUM OF TWO 10d FACE NAILS. WHERE CONTINUOUS LATERAL BRACING CANNOT BE INSTALLED, DUE TO A MINIMUM OF THREE ADJACENT TRUSSES NOT BEING IDENTICAL, THE CONTRACTOR SHALL COORDINATE WITH THE TRUSS SPECIALTY ENGINEER/MANUFACTURER TO DETERMINE WHAT TYPE OF ALTERNATE BRACE (I.E., T OR L BRACE, ETC.) IS REQUIRED.
- ANY CHORDS OR TRUSS WEBS SHOWN ON THESE DRAWINGS HAVE BEEN SHOWN AS A REFERENCE ONLY. THE FINAL DESIGN OF THE TRUSSES SHALL BE PER THE MANUFACTURER.
- 8. TRUSS LAYOUT AND PLACEMENT BY MANUFACTURER TO COINCIDE WITH THE SUPPORT LOCATIONS SHOWN ON THE SEALED STRUCTURAL DRAWINGS. TRUSS PROFILES TO BE SEALED BY THE TRUSS MANUFACTURER. TRUSS PLANS TO BE COORDINATED WITH THE SEALED STRUCTURAL DRAWINGS.
- 9. TRUSS MANUFACTURER TO PROVIDE REQUIRED UPLIFT CONNECTORS FOR ALL TRUSSES 10. PROVIDE SIMPSON H2.5A, USP RT7 OR EQUIVALENT AT EACH TRUSS TO

# WOOD STRUCTURAL PANELS:

1. FABRICATION AND PLACEMENT OF STRUCTURAL WOOD SHEATHING SHALL BE IN ACCORDANCE WITH THE APA DESIGN/CONSTRUCTION GUIDE "RESIDENTIAL AND COMMERCIAL," AND ALL OTHER APPLICABLE APA STANDARDS.

TOP PLATE CONNECTION, UNLESS OTHERWISE NOTED.

- 2. ALL REQUIRED WOOD SHEATHING SHALL BEAR THE MARK OF THE
- 3. WOOD WALL SHEATHING SHALL COMPLY WITH THE REQUIREMENTS OF LOCAL BUILDING CODES FOR THE APPROPRIATE STATE AS INDICATED ON THESE DRAWINGS. REFER TO WALL BRACING NOTES IN PLAN SET FOR MORE INFORMATION. EXTERIOR WALLS TO BE FULLY SHEATHED USING  $\%_6$ " OSB OR PLYWOOD MINIMUM. AT BRACED WALL PANELS, PROVIDE BLOCKING AT ALL SHEET EDGES NOT FALLING ON STUDS OR PLATES.
- 4. ROOF SHEATHING SHALL BE APA RATED SHEATHING EXPOSURE 1 OR 2. ROOF SHEATHING SHALL BE CONTINUOUS OVER TWO SUPPORTS MINIMUM AND ATTACHED TO ITS SUPPORTING ROOF FRAMING WITH 8d NAILS AT 6" O.C. AT PANEL EDGES AND AT 12" O.C. IN PANEL FIELD UNLESS OTHERWISE NOTED ON THE PLANS. SHEATHING SHALL BE APPLIED WITH THE LONG DIRECTION PERPENDICULAR TO FRAMING. SHEATHING SHALL HAVE A SPAN RATING CONSISTENT WITH THE FRAMING SPACING. PROVIDE SUITABLE EDGE SUPPORT BY USE OF PLYWOOD CLIPS OR LUMBER BLOCKING UNLESS OTHERWISE NOTED PANEL END JOINTS SHALL OCCUR OVER FRAMING. ROOF SHEATHING
- TO BE  $\frac{7}{16}$ " OSB MINIMUM. 5. WOOD FLOOR SHEATHING SHALL BE APA RATED SHEATHING EXPOSURE 1 OR 2. ATTACH SHEATHING TO ITS SUPPORTING FRAMING WITH (1) 10d NAIL AT 6" O.C. AT PANEL EDGES AND AT 12" O.C. IN PANEL FIELD UNLESS OTHERWISE NOTED ON THE PLANS. SHEATHING SHALL BE APPLIED PERPENDICULAR TO FRAMING. SHEATHING SHALL HAVE A SPAN RATING CONSISTENT WITH THE FRAMING SPACING. PROVIDE SUITABLE EDGE SUPPORT BY USE OF T&G PLYWOOD OR LUMBER BLOCKING UNLESS OTHERWISE NOTED. PANEL END JOINTS SHALL OCCUR OVER FRAMING.
- 6. SHEATHING SHALL HAVE A  $\frac{1}{8}$ " GAP AT PANEL ENDS AND EDGES AS RECOMMENDED IN ACCORDANCE WITH THE APA.

# STRUCTURAL FIBERBOARD PANELS

- STRUCTURAL FIBERBOARD SHEATHING SHALL ONLY BE USED WHERE SPECIFICALLY NOTED ON THE STRUCTURAL PLANS.
- 2. FABRICATION AND PLACEMENT OF STRUCTURAL FIBERBOARD SHEATHING SHALL BE IN ACCORDANCE WITH THE APPLICABLE AFA
- SHEATHING SHALL HAVE A  $lak{1}{8}$ " GAP AT PANEL ENDS AND EDGES AS RECOMMENDED IN ACCORDANCE WITH THE AFA.


# STRUCTURAL STEEL

UNLESS OTHERWISE NOTED.

- 1. STRUCTURAL STEEL SHALL BE FABRICATED AND ERECTED IN ACCORDANCE WITH THE AMERICAN INSTITUTE OF STEEL CONSTRUCTION "CODE OF STANDARD PRACTICE FOR STEEL BUILDINGS AND BRIDGES" AND OF THE MANUAL OF STEEL CONSTRUCTION "LOAD RESISTANCE FACTOR DESIGN" LATEST EDITIONS. 2. ALL STEEL SHALL HAVE A MINIMUM YIELD STRESS  $(F_v)$  OF 50 KSI
- 3. WELDING SHALL CONFORM TO THE LATEST EDITION OF THE AMERICAN WELDING SOCIETY'S STRUCTURAL WELDING CODE AWA D1.1. ELECTRODES FOR SHOP AND FIELDING WELDING SHALL BE CLASS E70XX. ALL WELDING SHALL BE PERFORMED BY A CERTIFIED WELDER PER THE ABOVE STANDARDS
- 4. ALL STEEL BEAMS TO BE SUPPORTED AT EACH END WITH A MINIMUM BEARING LENGTH OF 31/2" AND FULL FLANGE WIDTH UNLESS OTHERWISE NOTED. BEAMS MUST BE ATTACHED AT EACH END WITH A MINIMUM OF FOUR 16d NAILS OR (2) 1/2" x 4" LAG SCREWS UNLESS OTHERWISE NOTED.
- 5. INSTALL 2x WOOD PLATE ON TOP OF STEEL BEAMS, RIPPED TO MATCH BEAM WIDTH. FASTEN PLATE TO BEAM W/ HILTI X-DNI 52 P8 PINS AT 12" O.C. STAGGERED OR 1/2" DIAMETER BOLTS AT 24" O.C.

# MECHANICAL FASTENERS

- 1. ALL METAL HARDWARE AND FASTENERS TO BE SIMPSON STRONG-TIE OR APPROVED EQUIVALENT
- 2. ALL HARDWARE AND FASTENERS IN CONTACT WITH PRESERVATIVE PRESSURE AND/OR FIRE RETARDANT TREATED LUMBER SHALL BE HOT DIPPED GALVANIZED IN ACCORDANCE WITH ASTM A 153, G-185.
- 3. MANY OF THE NEW PRESSURE TREATED WOODS USE CHEMICALS THAT ARE CORROSIVE TO STEEL. IT IS THE CONTRACTOR'S RESPONSIBILITY TO VERIFY THE TYPE OF WOOD TREATMENT AND SELECT APPROPRIATE CONNECTORS THAT WILL RESIST THE APPLICABLE CORROSIVE CHEMICALS.



BRICK	VENEER LINTEL SC	HEDULE
SPAN	LINTEL SIZE	END BEARING
UP TO 3'-0"	3½"x3½"x¾"	4"
UP TO 6'-3"	5"x3½"x⁵₁ <sub>6</sub> " L.L.V.	8"
UP TO 9'-6"	6"x3½"x5⁄ <sub>16</sub> " L.L.V.	12"
LINTELS ARE NOT DESIGNED TO BE BOLTED TO HEADERS UNLESS SPECIFIED ON UNIT PLANS.		
SPANS OVER 4'-0" SHALL BE SHORED UP UNTIL CURED.		

**D-R-HORTO** 

 $\bigcirc$  $\sim$ 

Notes

ural

 $\odot$ 


s t  $\leftarrow$  Z

rolin

Project #: 088-18001 Designed By: JPS Checked By: Issue Date: 1/24/19


Re-Issue: 8/3/20

Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34





LEGEND



PROVIDE SOLID BLOCKING


WITHIN FLOOR SYSTEM TO

MATCH POST SIZE ABOVE.

======= ⇒ BEARING WALL ABOVE ПШШІШІІ ⇒ INTERIOR BEARING WALL 48"WSP

⇒ BRACED WALL PANEL (SEE KSE STRUCTURAL DETAILS SET FOR BRACED WALL PANEL SHEATHING FASTENING & BLOCKING DETAILS)

REFER TO KSE STRUCTURAL DETAILS SET FOR GENERAL STRUCTURAL NOTES AND TYPICAL DETAILS



Foundation  $\sim$ Monolithic Elevation 'Kathryn' 115 M.P.H North Card

Plan

 $\stackrel{\perp}{\simeq}$ 

290

Carolina

Project #: 088-18001 Designed By:JPS Checked By: Issue Date: 1/31/18

Re-Issue: 8/3/20 Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34



CS-ESW(2) DESIGNED TO REPLACE

62" OF CS-WSP. STRAP AROUND


 $\frac{-1}{2}$  (2)13/4"×117/8" LVL CONT.

4 CS-PF





# LEGEND



PROVIDE SOLID BLOCKING ⇒ WITHIN FLOOR SYSTEM TO

ПШШІІІІ  $\Longrightarrow$  INTERIOR BEARING WALL ⇒ BRACED WALL PANEL (SEE KSE STRUCTURAL DETAILS SET FOR BRACED WALL PANEL SHEATHING FASTENING & BLOCKING DETAILS)

REFER TO KSE STRUCTURAL DETAILS SET FOR GENERAL STRUCTURAL NOTES, TYPICAL DETAILS AND ADVANCED FRAMING NOTES AND DETAILS


PLAN DESIGNED WITH 9' NOMINAL WALL PLATE HEIGHT

# <u>KEYNOTES:</u>

(1) IF WOOD FLOOR BELOW, CONNECT STUD AT END OF BRACED WALL PANEL TO FRAMING BELOW WITH A 30" LONG SIMPSON CS20-R (USP RS20-R) COIL STRAP WITH MIN 8-10d NAILS EACH END.

IF SLAB FOUNDATION BELOW, CONNECT STUD TO FOUNDATION w/ SIMPSON DTT1Z (USP LTS19-TZ) w/ SIMPSON 3/8"x6" TITEN HD SCREW (USP 3/8"x6" SCREW BOLT+) ANCHOR AND  $3\frac{1}{2}$  MINIMUM EMBEDMENT.

(4) INSTALL ONE PANEL CS-PF PORTAL FRAME PER DETAIL A OR B/DS-4.



Roof Eleva

 $\stackrel{\perp}{\simeq}$ 

290

 $\sim$ 

Plan

Project #: 088-18001 Designed By: JPS

Checked By: Issue Date: 1/31/18 Re-Issue: 8/3/20

Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34





Details Plan Wall ed

Project #: 088-18001

Designed By: JPS Checked By:

Issue Date: 1/24/19 Re-Issue: 8/3/20

Scale: 1/8"=1'-0" @ 11x17

ROOF TRUSS BEARING/BLOCKING AT BRACED WALL PANELS ONLY REQUIRED AT BRACED WALL PANELS

NAIL OSB SHEATHING TO-ROOF TRUSSES ATTACHED TO BLOCKING, WALL PLATES TOP PLATES WITH 8d NAILS AND TRUSS WEB WITH 8d @ 6" O.C. ALONG LENGTH NAILS AT 6" O.C. TYPICAL. OF BRACED WALL PANELS.

OF BRACED WALL PANELS.

HEEL HEIGHT GREATER THAN 91/4" AND LESS THAN 151/4"

-2x4 BLOCKING BETWEEN

ROOF TRUSSES ATTACHED TO TOP PLATES WITH 8d NAILS @ 6" O.C. ALONG LENGTH

TRUSSES ALONG LENGTH OF BRACED WALL PANELS. LAP MIN 2" WITH OSB.

HEEL HEIGHT GREATER 15"

TYPICAL EXTERIOR CORNER WALL FRAMING

— 8d NAIL @ 6" O.C. AT ALL EDGES AND 12" O.C. TYPICAL

AT ALL OTHER

MEMBERS

@ 12" O.C.

OUTSIDE CORNER PLAN VIEW

-GYPSUM BOARD

2×4 CLEAT WITH (2)10d

NAILS AT CHORDS AND

(4)10d NAILS AT

(3)8d TOENAILS

AT 16" O.C.

WALL PANEL

─BRACED WALL

 $\sim$  (3)16d NAILS AT

16" O.C. ALONG

-LOCATE JOIST

BELOW WALL

TYPICAL BRACED WALL PANEL TO FLOOR/CEILING CONNECTION

BRACED WALL PANEL

PANEL

BRACED WALL PANELS PARALLEL TO I-JOISTS

**EXTERIOR** 

SHEATHING —

ALONG BRACED

BLOCKING (TYP.) 7

-CONTINUOUS RIM LOCATE JOIST

└8d TOENAILS AT 6"

WALL PANEL

-BRACED WALL

/(3)16d NAILS AT

16" O.C. ALONG

BRACED WALL PANEL

-CONTINUOUS RIM

BOARD

GYPSUM BOARD

16d NAIL —

@ 12" O.C.

EXTERIOR -

SHEATHING

PANEL

O.C. ALONG BRACED

ON WALL

-LSL/LVL BLOCKING

AT 16" O.C. ALONG

-(3)8d TOENAILS

ALONG BRACED

ÈÁCH BLOCK

WALL PANEL

-BRACED WALL

-(3)16d NAILS EACH

BRACED WALL PANEL

BLOCK ALONG

PANEL

BRACED WALL PANEL

2x BLOCKING BETWEEN -

BOARD BRACED WALL PANEL -8d TOENAILS AT 6"

WALL PANEL

WALL PANEL

O.C. ALONG BRACED

└8d TOENAILS AT 6"

O.C. ALONG BRACED

-LSL/LVL BLOCKING ALONG

PANEL

BLOCK ALONG

BRACED WALL INTERSECTIONS MAY BE FRAMED USING EITHER THE 3-STUD OR THE T-PLATE METHOD

METHOD GB(1) AND GB(2) INTERSECTION DETAILS

16" O.C. ALONG BRACED WALL PANEL -CONTINUOUS RIM BOARD └8d TOENAILS AT 6" -LSL/LVL BLOCKING O.C. ALONG BRACED ALONG BRACED WALL PANEL WALL PANEL B) TYPICAL BRACED WALL PANEL TO FLOOR/CEILING CONNECTION BRACED WALL PANELS PERPENDICULAR TO I-JOISTS

-LSL/LVL BLOCKING AT 16" O.C. ALONG BRACED WALL PANEL

─BRACED WALL PANEL

-CONTINUOUS RIM

-BRACED WALL

-(3)16d NAILS EACH BRACED WALL PANEL

/ (3)16d NAILS AT

2×4 BLOCKING BTWN — VERTICAL WALL STUDS AT ALL HORIZONTAL GYPSUM BRACED SHEATHING JOINTS. —WALL—

<u>3-STUD WALL</u>

INTERSECTION

 $_{\sim}$  (or 5d cooler nails at 7" o.c.)  $_{
ightarrow}$ /(2x8 STUD AT

1/2" (MIN) GYPSUM WALLBOARD.

FÁSTEN TÓ WALL ALL SUPPORTS (STUDS, PLATES, BLOCKING) WITH 1.25" TYPE W SCREWS AT 7" O.C.

AT WALL INTERSECTION


2x6 FULL HEIGHT STUD INTERSECTING 2x6 WALL)

"T" PLATE WALL


INTERSECTION

Project #: 088-18001 Designed By: JPS


Checked By: Issue Date: 1/24/19 Re-Issue: 8/3/20 Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34








HOLD DOWN AT BASEMENT FOUNDATION MONOLITHIC TURN-DOWN



HOLD DOWN AT STEMWALL SLAB FOUNDATION

G HOLD DOWN AT BASEMENT FOUNDATION STEM WALL



HOLD DOWN SCHEDULE				
HOLD DOWN		ALL THREAD ROD	TACTENEDC .	
SIMPSON	USP	ALL INKLAU KUU	FASTENERS	
LTT20B	LTS20B	½" DIA.	(10)10d NAILS	
HTT4	HTT16	%" DIA.	(18)16dx2½" LONG NAILS	
HTT5	HTT45	%" DIA.	(26)16dx2½" LONG NAILS	

-HOLD DOWN INSTALLED PER HOLD

DOWN SCHEDULE THIS SHEET, SEE


\_A36 ALL THREAD ROD DRILLED AND

EPOXIED 6" INTO FOOTING USING SIMPSON "SET"/"ET" OR USP CIA-GEL ADHESIVE.


PLANS FOR TYPE AND LOCATION.

HOLD DOWN AT MONOLITHIC SLAB FOUNDATION










HOLD DOWN AT CRAWL SPACE FOUNDATION

\METHOD CS-PF: CONTINUOUS PORTAL FRAME PANEL CONSTRUCTION

ノONE BRACED WALL SEGMENT




B METHOD CS-PF: CONTINUOUS PORTAL FRAME PANEL CONSTRUCTION TWO BRACED WALL SEGMENTS


BRACED WALL PANEL AND ENGINEERED SHEAR WALL SCHEDULE			
PANEL TYPES	PANEL TYPE	MATERIAL	FASTENERS
WSP	INTERMITTENT WOOD STRUCTURAL PANEL	7/16" OSB	6D OR 8D COMMON NAILS AT 6" O.C. AT SHEET EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. ENGINEERED ALTERNATIVE: 16 GAGE BY 1.75" LONG STAPLES AT 3" O.C. AT SHEET EDGES AND 6" O.C. AT INTERMEDIATE SUPPORTS
GB(1)	INTERMITTENT GYPSUM BOARD (SHEATHING ONE FACE OF WALL)	1/2" GYPSUM	1.5" LONG GALV. ROOFING NAILS, 6d COMMON NAILS, OR 1.25" LONG TYPE W DRYWALL SCREWS AT 7" O.C. AT SHEET EDGES AND INTERMEDIATE SUPPORTS.
GB(1)-4	INTERMITTENT GYPSUM BOARD (SHEATHING ONE FACE OF WALL)	1/2" GYPSUM	1.5" LONG GALV. ROOFING NAILS, 6d COMMON NAILS, OR 1.25" LONG TYPE W DRYWALL SCREWS AT 4" O.C. AT SHEET EDGES AND INTERMEDIATE SUPPORTS.
GB(2)	INTERMITTENT GYPSUM BOARD (SHEATHING BOTH FACES OF WALL)	1/2" GYPSUM	1.5" LONG GALV. ROOFING NAILS, 6d COMMON NAILS, OR 1.25" LONG TYPE W DRYWALL SCREWS AT 7" O.C. AT SHEET EDGES AND INTERMEDIATE SUPPORTS.
CS-WSP	CONTINUOUS SHEATHED WOOD STRUCTURAL PANEL	7/16" OSB	6D OR 8D COMMON NAILS AT 6" O.C. AT SHEET EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. <u>ENGINEERED ALTERNATIVE: 16 GAGE BY 1.75" LONG</u> STAPLES AT 3" O.C. AT SHEET EDGES AND 6" O.C. AT INTERMEDIATE SUPPORTS
CS-PF	CONTINUOUS SHEATHED PORTAL FRAME	7/16" OSB	NAILING PER DETAIL
PFH	PORTAL FRAME WITH HOLD DOWNS	7/16" OSB	NAILING PER DETAIL
CS-ESW(1)	ENGINEERED SHEAR WALL, TYPE 1	7/16" OSB	8D COMMON NAILS AT 6" O.C. AT SHEET EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. CONTINUOUS OSB AROUND DOOR/WINDOW OPENINGS
CS-ESW(2)	ENGINEERED SHEAR WALL, TYPE 2	7/16" OSB	8D COMMON NAILS AT 4" O.C. AT SHEET EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. CONTINUOUS OSB AROUND DOOR/WINDOW OPENINGS
CS-ESW(3)	ENGINEERED SHEAR WALL, TYPE 3	7/16" OSB	8D COMMON NAILS AT 3" O.C. AT SHEET EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. CONTINUOUS OSB AROUND DOOR/WINDOW OPENINGS

## BRACED WALL PANEL NOTES:

- 1. ALL BRACED WALL PANELS, EXCEPT GB(1) & GB(2), SHALL HAVE 2x BLOCKING BETWEEN WALL STUDS AT ALL HORIZONTAL SHEET EDGES.
- 2. PROVIDE NAILING/BLOCKING ABOVE AND BELOW ALL BRACED WALL PANELS PER KSE BRACED WALL DETAILS.
- 3. SHEATH ALL EXTERIOR WALLS OF THE HOUSE WITH  $\frac{7}{16}$ " O.S.B., OR  $\frac{15}{32}$ " PLYWOOD, FASTENED PER NCRC. AT EXTERIOR CORNERS, SHEATHING SHALL BE FASTENED PER KSE BRACED WALL DETAILS. AT INTERIOR WALL INTERSECTIONS, FASTEN STUDS & WALL BRACING PER KSE BRACED WALL DETAILS.



(C) WINDOW OR DOOR REINFORCEMENT IN ENGINEERED SHEAR WALL ONLY REQUIRED WHERE SPECIFED ON PLANS







Wall Notes & Details ' Plan ID: 2290 - RH

'Kathryn' 115 M.P. North Ca

Carolin

Project #: 088-18001

Designed By: JPS

Checked By:

Checked By:

Issue Date: 1/24/19

Re-Issue: 8/3/20

Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34

DS-3

D.R.HORTON ®

America's Builder

al Frame Details nryn' Plan ID: 2290 – RH


Project #: 088-18001


Designed By: JPS

Designed By: JPS
Checked By:
Issue Date: 1/24/19


Re-Issue: 8/3/20 Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34

NG/NEER STITE





O I-JOIST LADDER BLOCKING AS REQUIRED @ PARALLEL WALLS



BALLOON FRAMED WALL DETAIL N.T.S.



Miscellaneous Framing Details

'Kathryn' Plan ID:

 $\underline{\bot}$ 

29

ENGINEERING
UITE 201, QUAKERTOWN, PA 18951

D-R-HORTON

Project #: 088-18001

Designed By: JPS

Checked By:

Issue Date: 1/24/19

Issue Date: 1/24/19

Re-Issue: 8/3/20

Scale: 1/8"=1'-0" @ 11x17
1/4"=1'-0" @ 22x34

DS-5

E GABLE END WALL DETAIL

WALL ABOVE (6" O.C. AT

NON-SHEAR WALLS)

¼6" OSB WALL−


SHEATHING

- ROOF GIRDER TRUSS TO

BRICK, SEE PLAN

SUPPORT DEAD LOAD OF

TRUSS DETAIL




SIMPSON A35 OR USP MPA1

SPACED PER SHEAR WALL

BELOW ENTIRE GABLE END

WALL



EYEBROW ROOF DETAIL STRAIGHT ROOF



EERING

KERTOWN, PA 18951

(215) 804-4449

Details Framing Miscellaneous

Plan

 $\bigcirc$  $\sim$  $\sim$ 

Project #: 088-18001

Designed By: JPS Checked By: Issue Date: 1/24/19

Re-Issue: 8/3/20 Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34



FOUNDATION SECTION
EXTERIOR WALL

2x STUD WALL W/ P.T. VENEER TIES SHALL BE -PLATE, SEE PLAN. SPACED NOT MORE THAN 24" O.C. HORIZONTALLY -INSTALL  $\frac{1}{2}$ " DIA. ANCHOR AND VERTICALLY AND BOLTS, SEE FOUNDATION SHALL SUPPORT NOT NOTES. MORE THAN 2 SQUARE FEET OF WALL AREA-CONCRETE SLAB POURED MASONRY VENEER-MONOLITHICALLY WITH FOOTING, SEE PLAN. 8" MINIMUM — TO GRADE EXTERIOR GRADE— 4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL -COMPACTED SOIL 12" MINIMUM --MONOLITHIC CONCRETE BELOW GRADE FOOTING W/ 4" LEDGE @ BRICK VENEER, SEE PLAN.

B FOUNDATION SECTION EXTERIOR WALL @ MASONRY VENEER

2x STUD WALL W/ P.T. ∕PLATE, SEE PLAN.́ -INSTALL  $\frac{1}{2}$ " DIA. ANCHOR BOLTS, SEE FOUNDATION NOTES. \_CONCRETE SLAB POURED MONOLITHICALLY WITH CONCRETE SLAB, SEE PLAN -FOOTING, SEE PLAN. EXTERIOR-GRADE 4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL 12" MINIMUM--COMPACTED SOIL BELOW GRADE -MONOLITHIC CONCRETE FOOTING, SEE PLAN.

FOUNDATION SECTION
EXTERIOR WALL AT PORCH

2x STUD WALL W/ P.T. VENEER TIES SHALL BE -PLATE, SEE PLAN. SPACED NOT MORE THAN 24" O.C. HORIZONTALLY -INSTALL 1/3" DIA. ANCHOR AND VERTICALLY AND BOLTS, SEE FOUNDATION SHALL SUPPORT NOT NOTES. MORE THAN 2 SQUARE FEET OF WALL AREA -CONCRETE SLAB POURED MONOLITHICALLY WITH MASONRY VENEER — FOOTING, SEE PLAN. CONCRETE SLAB, SEE PLAN -EXTERIOR GRADE -4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL 12" MINIMUM -COMPACTED SOIL BELOW GRADE --MONOLITHIC CONCRETE FOOTING W/ 4" LEDGE @ BRICK VENÉER, SEE PLAN.

FOUNDATION SECTION

EXTERIOR WALL AT PORCH W/ MASONRY
VENEER

— 2x STUD WALL W/ P.T. PLATE, SEE PLAN. ✓ INSTALL ½" DIA. ANCHOR BOLTS, SEE FOUNDATION NOTES. -6" CONCRETE STEMWALL -CONCRETE SLAB POURED 8" MINIMUM MONOLITHICALLY WITH TO GRADE— FOOTING, SEE PLAN. STEP VARIES EXTERIOR GRADE 4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL 12" MINIMUM BELOW GRADE -COMPACTED SOIL -MONOLITHIC CONCRETE FOOTING, SEE PLAN. \FOUNDATION SECTION

EXTERIOR GARAGE WALL

THICKENED SLAB

VENEER TIES SHALL BE SPACED NOT MORE THAN 2x STUD WALL W/ P.T. 24" O.C. HORIZONTALLY -PLATE, SEE PLAN. AND VERTICALLY AND SHALL SUPPORT NOT -INSTALL  $\frac{1}{2}$ " DIA. ANCHOR MORE THAN 2 SQUARE BOLTS, SEE FOUNDATION FEET OF WALL AREA NOTES. CONCRETE SLAB POURED MONOLITHICALLY WITH MASONRY VENEER-FOOTING, SEE PLAN. STEP VARIES 8" MINIMUM TO GRADE EXTERIOR GRADE ∽4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL COMPACTED SOIL 12" MINIMUM — -MONOLITHIC CONCRETE BELOW GRADE FOOTING W/ 4" LEDGE @ BRICK VENÉER, SEE PLAN. FOUNDATION SECTION EXTERIOR GARAGE WALL @ MASONRY

VENEER


RECESS @ GARAGE DOOR—

WONOLITHICALLY WITH FOOTING, SEE PLAN.

4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL—COMPACTED SOIL—MONOLITHIC CONCRETE FOOTING, SEE PLAN.

G FOUNDATION SECTION

GARAGE DOOR



FOUNDATION SECTION INTERIOR GARAGE WALL

2x STUD WALL W/ P.T. --PLATE, SEE PLAN. -INSTALL  $\frac{1}{2}$ " DIA. ANCHOR BOLTS, SEE FOUNDATION CONCRETE SLAB POURED NOTES. MONOLITHICALLY WITH FOOTING, SEE PLAN. — Δδ -4" GRAVEL FILL OR GROUP 1 CLASSIFIED SOIL -THICKENED SLAB, SEE PLAN. WIDTH FOUNDATION SECTION

POST ABOVE, SEE PLAN

CONCRETE SLAB, SEE PLAN

ISOLATED PAD FOOTING,
SEE PLAN FOR SIZE

WIDTH

K FOUNDATION SECTION
ISOLATED PAD FOOTING

SEAL 025129 8/6/20 NC FIRM #C-2101 Monolithic Slab Foundation Details

Monolithic Slc Monolithic Slc Monolithic Slc Mathryn Plar 115 M.P.H.

X

29

EERING
KERTOWN, PA 18951
(215) 804-4449

D-R-HORTON

Designed By: JPS

Checked By:

Issue Date: 1/24/19

Re-Issue: 8/3/20 Scale: 1/8"=1'-0" @ 11x17 1/4"=1'-0" @ 22x34

DS-7