

HARNETT COUNTY ENVIROMENTAL HEALTH

File/Permit #: SFD2506-0094

IMPROVEMENT PERMIT (IP) CDP #:
Owner: DRB GROUP NORTH CAROLINA LLC System Relocation Change of Use
Property Location: 34 CELTIC LN LILLINGTON, NC 27546 PIN/Lot Identifier: 0680-27-6915.000
Subdivision: BLAKE POND Lot #: 117 Block:
Facility Type: SFD 64.8' x 62' Number of bedrooms: 4 Number of Occupants: 8 Other:
Design Daily Flow: 480 GPD LTAR (Initial): 35 gpd/ft ² LTAR (Repair): 375 gpd/ft ²
Wastewater System Type: 25% Reduction System (Initial)
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Initial): 40"
Wastewater System Type 25% Reduction System (Repair)
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Repair): 40"
Effluent Standard: DSE HSE Other: Type of Water Supply: Private well Municipal Supply Other:
Permit conditions: No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area.
The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. <u>This permit is subject to revocation if the site plan, plat, or the intended use changes.</u> The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.
Authorized Agent's Printed Name: Ren Levocz Date: 07/16/2025
Authorized Agent's Signature: Expiration Date:
CONSTRUCTION AUTHORIZATION (CA) New
Pump Tank Size: 1,000 gallons Maximum Trench Depth: 18"-28 inches Soil Cover: 6" inches
Trench Width: 36" inches Distribution Method: Serial D-Box or Parallel Pressure Manifold Other:
Artificial Drainage Required: Yes No III If yes, please specify details:
Management Entity Required: Yes No Minimum O&M Requirements:
Permit conditions: **Ronte Water Line ** Shown No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area. **Ronte Water Line ** Shown **On 5:4e Skelch**
The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. <u>This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.</u> The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.
Authorized Agent's Printed Name: Ren Levocz Date: 07/16/25
Authorized Agent's Signature: LEHS Expiration Date: 07/16/2030
Owner/Legal Representative Signature: Date:

SITE SKETCH

0680-27-6915.000

Permit Number SFD2506-0094

DRB GROUP NORTH CAROLINA LLC Applicant's Name Ren Levocz	BLAKE POND Lot 117
	Subdivision/Section/Lot Number 07/16/2025
Authorized State Agent	Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

