

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

July 11th, 2025

Salvador Trejo Mejia
38 Margies Lane
Angier, NC 27501

Re: Status of Permit Application-SFD2506-0134

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- ☐ 1. Use pink flags to mark property survey corner irons. Irons need to be exposed. Need property lines flagged every 50' between irons. (25.00 Fee Incurred)
- ☐ 2. House Box needs to be marked/demonstrated clearly. (25.00 Fee Incurred)
- ☐ 3. Directions not clear to property (\$25.00 fee incurred)
- ☐ 4. Clear Vegetation. Do not disturb the soil.
- ☐ 5. Driveway not shown on site plan
- ☐ 6. Backhoe Pits Required
- ☒ **7. Other- Backyard soil is disturbed and had uneven grade elevations. Available space for septic and septic repair layout is limited. Driveway must be marked/flagged on site, width and length to house box. May require bedroom size to change to a 3 bedroom SFD. May require the placement of the house box to move closer to Oxford Woods Dr, and closer to the back property line, the (181.71 total) line.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy: Central Permitting