

**HARNETT COUNTY ENVIROMENTAL HEALTH**

File/Permit #: SFD2507-0005

CDP #:

IMPROVEMENT PERMIT (IP)☒ New☐ Expansion☐ Repair☐ System Relocation☐ Change of UseOwner: DRB GROUP NORTH CAROLINA LLCApplicant: DRB GROUP NORTH CAROLINA LLCProperty Location: 204 BRONZE LEAF DR LILLINGTON, NC 27546PIN/Lot Identifier: 0681-40-1233.000Subdivision: BLAKE PONDLot #: 75 Block: _____ Section: _____Facility Type: SFD 66.4' x 52' Number of bedrooms: 3 Number of Occupants: 6 Other: _____Design Daily Flow: 360 GPD LTAR (Initial): .3 gpd/ft² LTAR (Repair): .3 gpd/ft²Wastewater System Type: 25% Reduction System (Initial)Pump Required: ☒ Yes ☐ No ☐ May be requiredUsable Depth to Limiting Condition (Initial): 27"Wastewater System Type 25% Reduction System (Repair)Pump Required: ☒ Yes ☐ No ☐ May be requiredUsable Depth to Limiting Condition (Repair): 27"Effluent Standard: ☒ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: _____**Permit conditions:**

No Foundation or Gutter Drains to be Directed Towards Septic System.
No Cutting or Grading of Soil in Septic or Septic Repair Area.
Route Water Line as shown on Site Sketch.

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Ren LevoczDate: 10/23/2025Authorized Agent's Signature: [Signature]Expiration Date: 10/23/2030**CONSTRUCTION AUTHORIZATION (CA)**☒ New☐ Expansion☐ Repair☐ System Relocation☐ Change of UseOwner: DRB GROUP NORTH CAROLINA LLCApplicant: DRB GROUP NORTH CAROLINA LLCProperty Location: 204 BRONZE LEAF DR LILLINGTON, NC 27546PIN/Lot Identifier: 0681-40-1233.000Subdivision: BLAKE PONDLot #: 75 Block: _____ Section: _____Facility Type: SFD 66.4' x 52' Number of bedrooms: 3 Number of Occupants: 6 Other: _____Design Daily Flow: 360 GPD LTAR: .3 gpd/ft²Effluent Standard: ☒ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: _____**Installation Requirements/Conditions**Wastewater System Type: 25% Reduction SystemPump Required: ☒ Yes ☐ No ☐ May be requiredSeptic Tank Size: 1,000 gallons Total Trench Length: 300' feet Trench Spacing: 9' feet on centerPump Tank Size: 1,000 gallons Maximum Trench Depth: 15" inches Soil Cover: 6" inchesTrench Width: 36" inches Distribution Method: ☒ Serial ☐ D-Box or Parallel ☐ Pressure Manifold ☐ Other: _____Artificial Drainage Required: Yes ☐ No ☒ If yes, please specify details: _____Management Entity Required: ☐ Yes ☒ No Minimum O&M Requirements: _____**Permit conditions:**

No Foundation or Gutter Drains to be Directed Towards Septic System.
No Cutting or Grading of Soil in Septic or Septic Repair Area.
Route Water Line as shown on Site Sketch.

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Ren LevoczDate: 10/23/25Authorized Agent's Signature: [Signature]Expiration Date: 10/23/2030

Owner/Legal Representative Signature: _____ Date: _____

***See attached site sketch**

Harnett County Environmental Health

SITE SKETCH

PIN 0681-40-1233.000

Permit Number SFD2507-0005

DRB GROUP NORTH CAROLINA LLC

BLAKE POND Lot 75

Applicant's Name

Ren Levocz

Subdivision/Section/Lot Number

10/23/2025

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

