

Space for Architect Seal

REDRAW TO MOVE FROM LOT 21 TO LOT 7

Plan Review: 6/3/25



RESIDENCE FOR: **MARKET**

243 HARVESTER ROAD TORACCO ROAD

	IODACC	OKOAD
Job Number:	Drawing Date:	Coord Name:
TBRD-0007-00	1/27/2024	GREG P.

the PARKETTE

House Name:

Drawing Scale: 1/8" = 1'0"

Coord Phone: 859-578-4355

EXECUTIVE Plan No.:

07/11/23 CDs Drawn By: **HOMES**_{SM}

Elevation "A"

Architecture Plan Review:		Items drawn on any drawings and not written in the contract selctions <u>WILL NOT</u> be included in the site sp	pecific drawings.	Customer Plan Review Signature
Customer Request:	Design Solution:	Reason For Modification:	Comments:	I understand that my new Drees home will be built in general comformance to plans, specifications, selections and the Purchase Agreement, all of which I ha
1. XXX	1. XXX	1. XXX	1. XXX	reviewed and approved. This set of plans may not reflect the elevations or opti for my house. Drees draws the standard plans complete with the most common
2. XXX	2. XXX	2. XXX	2. XXX	options. The subcontractor's sets will show only the options I selected in my selection sheets. I have reviewed the plot plan for my house and understand there may be some field adjustments as to the exact location of the house on the same field adjustments.
3. XXX	3. XXX	3. XXX	3. XXX	lot. I further understand that my home will not be built exactly like any other Dre home or Model and that some minor variations from my plans and specificatio may occur since every home that is built has it's own set of unique construction problems that must be dealt with as the home is being built.
4. XXX	4. XXX	4. XXX	4. XXX	Customer: Date:
				Customer

ice to the h I have or options mmon and that e on the er Drees ications

8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288

FOUNDATION NOTES

CRAWL SPACES:

- SLOPE CONCRETE SLAB 4" MINIMUM TOWARDS GARAGE DOOR

- EXTERIOR FLATWORK/GARAGES SHALL HAVE A MINIMUM CONCRETE SRENGTH OF 4.500 PSI

FOOTINGS TO A MINIMUM CONCRETE STRENGTH OF 2500 PSI, UNLESS OTHERWISE NOTED

ASSUMED ALLOWABLE SOIL BEARING PRESSURE: 2,000 p.s.f.

WATERPROOF FOUNDATION WITH BITUMINOUS SPRAY.

WALL TIES EMBEDDED IN THE HORIZONTAL MORTAR JOINT SHALL BE 16" ON CENTER, TIES IN ALTERNATE COURSES SHALL

BE STAGGERED, THE MAXIMUM VERTICAL DISTANCE BETWEEN TIES SHALL NOT EXCEED 16" AND THE MAXIMUM

HORIZONTAL DISTANCE SHALL NOT EXCEED 16" ADDITIONAL TIES SHALL BE PROVIDED AT ALL OPENINGS, AND WITHIN 12"

CORE FILL ENTIRE BLOCK WALL WHEN THE WALL IS 4'-0" TALL OR HIGHER. INSTALL #4 REBAR IN EACH HOLLOW AREA OF EACH BLOCK FROM FOOTING TO TOP OF WALL, ON THE ENTIRE WALL PRIOR TO CORE FILLING IT.

TOP COURSE OF BLOCK ON ALL WALLS WILL BE FILLED SOLID WITH MORTAR PLACING THE FOUNDATION STRAPS OR

BOLTS IN THE MORTAR 6'-0" ON CENTER, AND 12" FROM EACH CORNER.

- 12"x16" PIERS: HOLLOW MASONRY UP TO 48" HIGH, SOLID MASONRY UP TO 9"0" HIGH

16"x16" PIERS: HOLLOW MASONRY UP TO 64" HIGH, SOLID MASONRY UP TO 12'0" HIGH

BLOCK PIERS SHOULD BE PLACED DIRECTLY ON CONCRETE FOOTINGS PER PLAN. THEY SHOULD BE PLUMBED AND SQUARE WITHIN 1/4"

- SILL PLATES TO BE A MINIMUM OF 2x4 NOMINAL LUMBER.

FRAMING NOTES

DESIGN LOADS:

FLOORS: 40 psf LIVE LOAD + 10 psf DEAD LOAD = 50 psf ROOF:

18 psf LIVE LOAD + 17psf DEAD LOAD = 35 psf DESIGN DEFLECTION LIMITS (BASED ON LIVE LOAD, EXCEPT MASONRY):

> RAFTERS GREATER THAN 3:12 L/180 MASONRY VENEER L/600

NOMINAL LUMBER FLOORS: L/360

MANUFACTURED WOOD FLOORS: DESIGNED TO MINIMUM PRO RATING OF 35 (OR EQUIVALENT).

NO MORE THAN 8 POINT DIFFERENCE BETWEEN ADJACENT SPANS. L/480 FOR SPANS UP TO 16'-0" AND NO GREATER THAN 1/2" DEFLECTION

WIND SPEED: 120 MPH

CEILINGS

GARAGE FLOOR: 50 psf LIVE LOAD

L/240

L/600 FOR SPANS OVER 16'-0" IF SIMPLE SPAN AND NO GREATER THAN 1/2" DEFLECTION

SEISMIC: "A" & "B"

L/840 FOR SPANS OVER 16'-0" IF CONTINUOUS SPAN. AND NO GREATER THAN 1/2" DEFLECTION JOIST SPACING: 19.2" o.c. MAXIMUM SPACING

DOUBLE EVERY OTHER FLOOR JOIST UNDER KITCHEN ISLANDS

INSTALL UNCOUPLING MEMBRANE IN TILE FLOOR AREAS IF 19.2" O.C. FLOOR JOIST SPACING

GLUE AND MECHANICALLY FASTEN [SCREWS] WOOD FLOOR IF 19.2" o.c. FLOOR JOIST SPACING

MANUFACTURED WOOD PRODUCTS (INCLUDING, BUT NOT LIMITED TO, STRUCTURAL WOOD BEAMS AND I-JOISTS) SHALL BE FABRICATED. HANDLED, AND INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.

-JOISTS ARE NOT TO BE PLACED DIRECTLY OVER INTERIOR PARALLEL WALLS. (TO PREVENT UNEVEN FLOOR DEFLECTION FROM OCCURRING)

ALL WOOD BEAMS/HEADERS: 2x6's TO BE SPF STUD GRADE OR BETTER/ 2x8 OR LARGER TO BE SYP #2 [PER NDS 2012] OR BETTER, U.O.N.

ALL HEADERS SHALL BE SUPPORTED BY (1) 2x JACK STUD AND (1) 2x KING STUD MINIMUM. THE NUMBER OF STUDS SPECIFIED AT A SUPPORT INDICATES THE NUMBER OF JACKS REQUIRED, U.N.O. AT FLUSH OR DROPPED BEAMS, THE NUMBER OF STUDS SPECIFIED INDICATES THE TOTAL NUMBER OF STUDS REQUIRED

TO SUPPORT THE BEAM EXTERIOR WALLS TO BE 2x4 SPF STUD GRADE AT 16" O.C. UNLESS OTHERWISE NOTED (10'4-1/2" MAXIMUM WALL HEIGHT)

ALL INTERIOR BEARING WALLS AND WALLS AT BASEMENT & FIRST FLOOR STAIRWELLS, KITCHEN, BATH, & GARAGE TO BE 2x4 SPF STUD GRADE @ 16" o.c.;

ALL OTHER NON-BEARING INTERIOR WALLS TO BE 2x4 SPF STUD GRADE @ 24" o.c. U.O.N.

ALL WALLS TO BE 3 1/2" UNLESS OTHERWISE NOTED.

PROVIDE SOLID BEARING TO FOUNDATION OR BEAM BELOW FOR ALL BEAMS, HEADERS & GIRDER TRUSSES. PROVIDE BLOCKING BETWEEN JOISTS AS REQUIRED.

SEE SELECTION SHEET FOR SIZE AND STYLE OF FIREPLACE. SEE FIREPLACE ELEVATION DETAIL FOR ADDITIONAL FRAMING REQUIREMENTS, IF ANY. CHECK SELECTION SHEETS FOR FLOOR COVERING AT TOP AND BOTTOM OF STAIR RISERS AND ADJUST RISERS AS REQ'D.

PROVIDE BLOCKING AT ALL HANDRAIL TERMINATION AND BRACKET LOCATIONS.

20-MINUTE FIRE RATED DOOR BETWEEN GARAGE AND LIVING AREA.

EXTERIOR WALL TO BE 2x4 SPF STUD G AT 16" o.c., UNLESS OTHERWISE NOTED (10'-0" MAXIMUM UNBRACED WALL HEIGHT).

ALL EXTERIOR WALLS AND INTERIOR BEARING WALLS, FRAMED HIGHER THAN THE STANDARD PLATE HEIGHT, SHALL BE FRAMED WITH CONTINUOUS FULL HEIGHT STUDS TO THE HIGHEST CEILING (I.E. NO INTERMEDIATE BREAKS) TO PREVENT LATERAL HINGE CONDITIONS.

IN THE GARAGE, PROVIDE 1/2" GYP. BOARD AT ALL WALLS COMMON TO LIVING SPACE AND ALL STRUCTURAL MEMBERS SUPPORTING FLOOR/CEILING ASSEMBLY. GARAGE CEILING TO BE 1/2" SAG RESISTANT GYP. BOARD WHEN THERE ARE NO HABITABLE SPACES ABOVE, OR 5/8"

TYPE X GYP. BOARD WHEN HABITABLE SPACES ARE ABOVE. ALL EMERGENCY ESCAPE & RESCUE OPENINGS TO BE A MAXIMUM OF 44" OFF OF FINISHED FLOOR AND HAVE MINIMUM OPENING DIMENSIONS OF 24" IN HEIGHT, 20" IN WIDTH, & HAVE A MINIMUM OPENING AREA OF 5.7 S.F.

ALL DOORS TO BE 6'-8" TALL LINLESS OTHERWISE NOTED

ALL GLASS IN INTERIOR AND EXTERIOR DOORS TO BE TEMPERED (INCLUDING SIDELITES AND TRANSOMS)

ALL LUMBER CONTACTING CONCRETE TO BE PRESSURE TREATED.

ALL FASTENERS, HANGERS, AND OTHER CONNECTORS TO BE USED WITH PRESSURE TREATED WOOD ARE TO HAVE ZMAX COATING (OR EQUIVALENT) HOT-DIPPED GALVANIZED OR STAINLESS STEEL.

AT STAIR HANDRAIL, ON ONE SIDE ONLY, SHALL BE CONTINUOUS FOR THE ENTIRE LENGTH OF THE STAIRWAY, AND ENDS SHALL BE RETURNED TO A WALL OR POST. THE HANDRAIL MAY BE INTERRUPTED AT A NEWEL POST AT A TURN.

- ALL HANDRAIL GRIP PORTIONS SHALL NOT EXCEED 2-1/4" IN CROSS SECTIONAL DIMENSION.

HANDRAILS SHALL BE INSTALLED ON ALL STAIRS WITH 4 OR MORE RISERS, HANDRAIL HEIGHTS SHALL BE A MINIMUM OF 34" AND A MAXIMUM OF 38". - ALL STAIRS TO BE CONSTRUCTED SO AS NOT TO ALLOW A 4" SPHERE TO PASS THROUGH THE RISER.

GUARDRAILS MUST BE A MINIMUM OF 36" HIGH. GUARDRAILS AT THE OPEN SIDES OF STAIRS MUST BE A MINIMUM OF 34" HIGH MEASURED VERTICALLY

FROM THE NOSING AT THE TREADS. THE HORIZONTAL SPACING OF THE VERTICAL BALUSTERS SHALL BE 4" O.C.

- GUARDRAIL DESIGN TO RESIST A MINIMUM OF 200 LBS LATERAL FORCE

BASEMENTS:

- SLOPE CONCRETE SLAB 4" MINIMUM TOWARDS GARAGE DOOR

- EXTERIOR FLATWORK/GARAGES SHALL HAVE A MINIMUM CONCRETE SRENGTH OF 4 500 PSI

- FOOTINGS TO A MINIMUM CONCRETE STRENGTH OF 2500 PSI, UNLESS OTHERWISE NOTED- ALL FOUNDATION WALLS TO BE CAST IN PLACE CONCRETE

3000 PSI MIN. UNLESS OTHERWISE NOTED.

- BASEMENT WINDOW LOCATIONS MAY VARY FROM DRAWING DUE TO LOT CONDITIONS

- BACKFILL ADJACENT TO FOUNDATION WALLS SHALL NOT BE PLACED UNTIL THE WALL HAS SUFFICIENT STRENGTH AND HAS BEEN ANCHORED TO THE FLOOR OR HAS BEEN SUFFICIENTLY BRACED TO PREVENT DAMAGE BY THE BACKFILL.

- ASSUMED ALLOWABLE SOIL BEARING PRESSURE: 2 000 p.s.f.

- WATERPROOF FOUNDATION WITH BITUMINOUS SPRAY.

- VERTICAL CONTROL JOINTS IN BASEMENT FOUNDATION WALLS - STANDARD LOCATION GUIDELINES:

1) PLACE A CONTROL JOINT IN ALL UNBRACED WALLS OVER 30' IN LENGTH. (NOTE: "T" WALLS AND CORNERS COUNT AS A BRACE)

2) WINDOWS THAT ARE LARGER THAN THE STANDARD BASEMENT WINDOW REQUIRE A CONTROL JOINT.

3) CONTROL JOINTS ARE NOT REQUIRED AT EVERY WINDOW THAT IS STANDARD

4) IF THERE IS A STANDARD WINDOW LOCATED IN A WALL SEGMENT THAT REQUIRES A CONTROL JOINT, THEN THE CONTROL JOINT SHOULD BE PLACED ON THE SIDE OF THE WINDOW THAT IS ADJACENT TO THE LONG SIDE OF THE WALL. IF THERE IS MORE THAN ONE WINDOW IN A WALL THEN ONLY ONE WINDOW SHOULD HAVE A CONTROL JOINT.

5) DOORS DO NOT GET CONTROL JOINTS.

6) CONTROL JOINTS SHOULD NOT BE LOCATED WITHIN 3' OF A BEAM POCKET.

7) CONTROL JOINTS ARE REQUIRED AT THE FIRST AND LAST STEP DOWN AT STEPPED BASEMENT FOUNDATION WALLS.

- INTERIOR FLATWORK SHALL HAVE A MINIMUM CONCRETE STRENGTH OF 3.000

- ALL VERTICAL STEEL AND ALL STEEL IN STRUCTURAL SLABS TO BE GRADE 60. ALL HORIZONTAL STEEL IN FOUNDATION WALLS AND FOOTERS TO BE GRADE 40 STEEL. **SLAB ON GRADE:**

- ALL CONCRETE SLABS ON GRADE SHALL BE THE THICKNESS AS INDICATED ON THE DETAILS OVER MINIMUM 6 MIL. POLYETHYLENE (VISQUEEN) VAPOR BARRIER, SLABS SHALL BE REINFORCED WITH 6x6 W1 4 WWE LAPPED 8" AT EDGES AND ENDS IN

CONFORMANCE WITH ASTM-A 185, OR FIRERMESS REINFORCEMENT SHALL BE LISED WITH A MINIMUM FIBER LENGTH OF $\frac{1}{2}$ TO 2 $\frac{1}{4}$ COMPLYING WITH ASTM C 1116. THE DOSAGE AMOUNT SHALL BE 0.75 TO 3.0 POUNDS PER CUBIC YARD IN ACCORDANCE 2/OITAG//AMMOOSS 2'SSRIIT ASII/AM HTIW

- SLABS ON GRADE SHALL BEAR ON STRUCTURAL FILL WHICH SHALL BE CLEAN SAND FREE OF DEBRIS AND OTHER DELETERIOUS MATERIAL, STRUCTURAL FILL SHALL BE COMPACTED TO A DENSITY OF AT LEAST 95% OF THE MODIFIED PROCTOR MAXIMUMN DRY DENSITY (ASTM D1557). TERMITE PROTECTION SHALL BE PROVIDED IN ACCORDANCE WITH APPLICABLE CODE REQUIREMENTS. IF SOIL TREATMENT IS USED. THE TREATMENT SHALL BE DONE AFTER ALL EXCAVATION, BACKFILLING, AND COMPACTION IS COMPLETED.

- FOOTINGS MAY BEAR UPON UNDISTURBED SOIL OR UPON STRUCTURAL FILL, STRUCTURAL FILL SHALL BE COMPACTED TO A DENSITY OF AT LEAST 95% OF THE MODIFIED PROCTOR MAXIMUMN DRY DENSITY (ASTM D1557) FOR A DEPTH OF AT LEAST TWO FEET (2'-0") BELOW THE BOTTOM OF THE FOOTING.

- THE FOLLOWING MINIMUM CONCRETE COVER SHALL BE PROVIDED FOR REINFORCEMENT:

3" CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH 2" CONCRETE EXPOSED TO EARTH AND WEATHER

1" CONCRETE NOT EXPOSED TO EARTH OR WEATHER

- SLOPÉ CONCRETE SLAB 4" MINIMUM TOWARDS GARAGE DOOR

- EXTERIOR FLATWORK/GARAGES SHALL HAVE A MINIMUM CONCRETE SRENGTH OF 4,500 PSI

- ASSUMED ALLOWABLE SOIL BEARING PRESSURE: 2,000 p.s.f.

- INTERIOR FLATWORK SHALL HAVE A MINIMUM CONCRETE STRENGTH OF 3.000 PSI.

- ALL STEEL IN STRUCTURAL SLABS TO BE GRADE 60. ALL HORIZONTAL STEEL IN FOUNDATION WALLS AND FOOTERS TO BE GRADE 40 STEEL

MECHANICAL/ELECTRICAL NOTES

- ANY GAS APPLIANCES MUST BE INSTALLED PER MANUFACTURER'S SPECIFICATIONS.

- HOLD THE CENTERLINE OF ALL EXTERIOR LIGHT FIXTURES AT 5'-8" OFF BOTTOM OF DOOR OPENING.

- ALL KITCHEN CABINET DIMENSIONS ARE CABINET TO CABINET.

- CABINET STYLES MAY VARY FROM INTERIOR ELEVATIONS DEPENDING ON STYLE, MANUFACTURER, ETC. FOR CABINET DETAILS SEE SHOP DRAWINGS

- CABINET SIZES MAY VARY WITH FULL-OVERLAY CABINETS.

- GROUND FAULT INTERRUPTER (GFCI) OUTLETS TO BE INSTALLED PER NEC 2017, SECT. 210.8

- PROVIDE HOSE BIBS PER DIVISION SPEC. SHEET. EXACT LOCATION TO BE FIELD DETERMINED UNLESS OTHERWISE NOTED ON THE PLANS.

- MIN. 50 C.F.M. FOR ALL EXHAUST FANS IN BATHROOMS

INSULATION DETAILS

OVER GARAGE:

EXTERIOR STUD WALL CAVITY: R-19

FLOOR JOIST CAVITY AT CANTILEVER:

(SLOPED AND VERTICAL SPACE)

(2x4)

R-38 BATT

FLOOR JOIST CAVITY AT STANDARD PERIMETER: R-19 (OVER HORIZONTAL SPACE)

R-19 R-38 BLOWN

R-15

ELEVATION NOTES

- WINDOW STYLE AND MULLIONS MAY VARY FROM ELEVATION DEPENDING UPON MANUFACTURER, STYLE, PATTERN, TYPE, ETC.

- USE SECONDARY HEAT BARRIER ON ALL DIRECT VENT FIREPLACES 7' OR LESS ABOVE A WALKWAY

- Grade away from foundation walls shall fall a minimum of 6" within the first 10'.

- Provide tyvek or equivalent house wrap behind brick and Stone veneer over wood sheathing. PROVIDE BRICK WEEP HOLES AT 24" O.C. WITH BRICK VENEER AND MORTER NET BEHIND AND THROUGH WEEP HOLES.

PROVIDE FLASHING AND WEEP HOLES ABOVE ALL BRICK ANGLE IRONS, BELOW ALL BRICK SILLS AND ABOVE SILL PLATE SEALERS.

- EXTERIOR STEPS TO HAVE A MAXIMUM 8" RISER. WHEN VERTICAL RISE EXCEEDS 30" OR FOUR OR MORE CONTINUOUS RISERS. A HANDRAIL IS REQUIRED

ROOF PLAN NOTES

- ALL OVERHANGS TO HAVE (2) SOFFIT VENTS PER EACH 8' SOFFIT SECTION.

- PROVIDE BAFFLES AT EXTERIOR TRUSS BEARING FOR VENTILATION.

PROVIDE 15# FELT PAPER LINDER SHINGLES

Space for Architect Seal



07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD

Job Number Drawina Date Coord Name TBRD-0007-00 1/27/2024

the PARKETTE

House Name:

Born on Date:

Drawing Scale: 1/8" = 1'0"

GREG P.

07/11/23 CDs Drawn By

HOMES_{sn} Copyright © 2023 (2023) The Drees Company. All Rights Reserved 8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288

Elevation "A"

Series

Plan No.:


Coord Phone

Contract Drawn By

859-578-4355

EW1

EXECUTIVE



General Notes:

. REFER TO SHEET ON.1 FOR GENERAL NOTES.

2. ALL FOUNDATION WALLS TO BE 8" THICK UNLESS OTHERWISE NOTED.

Key Notes:

101A SLAB CONTROL JOINT

C101B GARAGE SLAB TO BE HELD A MINIMUM OF 4" BELOW TOP OF FOUNDATION AND IS TO SLOPE 1/4" PER FOOT TOWARDS GARAGE DOOR

CONTINUOUS FOOTING AND FOUNDATION; DROP TO BE FIELD DETERMINED

4" CONCRETE SLAB (3000 PSI) OVER 4" CRUSHED STONE, OVER COMPACTED OR UNDISTURBED EARTH.

36"W x 30"H CRAWL SPACE ACCESS PANEL WITH DOUBLE BANDBOARD - BUILDER TO FIELD VERIFY LOCATION PER GRADE

C101H 8"W x 8"H x 4"D BEAM POCKET

101Q 16"x16" CMU PIER W/ 30"x30"x12" PLAIN CONC. FOOTING

101U PORCH STEPS - RISE AND RUN TO BE FIELD DETERMINED

101Y 6x6 P.T. POST W/ SIMPSON BCS2-3/6 CAP & ABW66Z BASE ON 16" DIA. SONOTUBE FOOTING TO FROST

2x10 P.T. LEDGER FASTENED TO RIM w/ (3)1/4"x3-1/2" LONG SIMPSON SDS SCREWS @ 16" O.C.

Space for Architect Seal



The Drees Company 07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD

CDs Drawn Bv

Job Number: Coord Name TBRD-0007-00 1/27/2024 GREG P. House Name: Drawing Scale: 1/8" = 1'0"

859-578-4355

Contract Drawn By

EXECUTIVE Plan No.:


HOMES_{SM} Copyright © 2023 (2023) The Drees Company. All Rights Reserved.

8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288

Elevation "A"

General Notes: PROVIDE 8' TALL DOORS . REFER TO SHEET ON.1 FOR GENERAL NOTES. THROUGHOUT FIRST FLOOR, 2. ALL FIRST FLOOR CEILINGS TO BE 10"-1" ABOVE SUBFLOOR UNLESS OTHERWISE NOTED.

3. FRAME TOP OF ALL WINDOWS AT 1"-10" BELOW TOP OF PLATE UNLESS OTHERWISE NOTED. U.N.O. . ALL DROPPED, INTERIOR HEADERS (FALSE AND BEARING) ARE DROPPED 1'-3" FROM CEILING. S. REFER TO SELECTION SHEETS FOR FLOORING MATERIAL PRIOR TO CONSTRUCTING STAIRS TO DETERMINE 6. REFER TO SHEET 2.01S FOR STRUCTURAL INFORMATION. '. REFER TO SHEET S-0 FOR STRUCTURAL DETAILS AND INFORMATION 79'-11" 2'-11 1/2" 9'-0" 16'-0" 7'-0 1/2" 10'-2" 5'-8 1/2" 6'-11" 19'-7 1/2" Key Notes: 201B FRAME GARAGE WALL FULL HEIGHT STUDS AT 11'-5 1/4" WITH (2)2x4 STUDS AT 16" O.C. FROM TOP OF OUNDATION WALL; IF ELECTRICAL PANEL LOCATED IN GARAGE, PAD OUT WALL FOR ELECTRICAL PANE 201E SLOPE WALL EVEN WITH TOP OF STAIR STRINGER, RAILING ABOVE 201F SEE DETAIL C/7.02 FOR STAIR FRAMING DETAILS APPROX, LOCATION OF 36" HIGH WALL UNDER STAIRS (FIELD VERIFY) 201B 2040 S/H TEMP 9'0" x 7'0" GARAGE DOOR 16'0" x 7'0" GARAGE DOOR RAME TOP OF OPENING AT HEIGHT SPECIFIED IN GENERAL NOTES ON THIS SHEET FRAME TOP OF OPENING AT REFRIGERATOR AT 6'-1 1/2" A.F.F. 34'-5" 10'-7 1/2" 14'-5" PRE-FABRICATED FIREPLACE INSERT ~50" HIGH WALL BATH #3_ CARPENTER TO DROP ELECTRICAL WIRE THROUGH PORCH CEILING FOR LIGHTS 201X COLUMN - SEE DETAIL B/7.01 BATH BEDROOM #3 BALLOON FRAME WALL TO UNDERSIDE OF SCISSOR TRUSSES PRIMARY SUITE 201X PROVIDE BLOCKING FOR SHOWER DOOR/ENCLOSURE 60"x34" 4'-3 1/2" 5'-8 1/2"_5 201Y PROVIDE 4-1/2" SHOWER CURB 201Z 22-1/2" x 32" ATTIC ACCESS 11'-0 1/2" W.I.C. 201Z 2017 GARAGE PANTRY R/I 9'-11" 8'-9 1/2" 11'-4" Space for Architect Seal KITCHEN LAUNDRY === 16'-11" 5 1/2" 201B 7'-4" İ 51/2" VAULTED CLG. 2'-4 1/2" 34-1/2" H.WALL 201L O HOME OFFICE H CARO DINING 10'1" CLG. 5'-2 1/2 201F 14'-6" 201E 201K SEAL ₩ 201K W.I.C. 12648 3'-5" 5'-9 1/2" 3'-0" 5'-2 1/2" 11'-0 1/2" 201 J WOOD BEAMS FÖYER 201 J PORCH 6080 S.G.D. 15'-9 1/2" 201J -10'-1" The Drees Company FAMILY ROOM 07/07/2025 9:40:07 AM VAUITED CLG OUTDOOR LIVING (SCREENED-IN) BEDROOM #2 51/2" RE: D7.1 FOR MORE INFO BATH #2-FLEX 5'-1 1/2" **RESIDENCE FOR:** 201N PRE-FAB FIREPLACE **MARKET** 6", 243 HARVESTER ROAD 4010_IFIXED 3060 S/H | 3060 S/H 3020₁FIXED 3020 FIXED **TOBACCO ROAD** 4'-3" 20 T -6'-9 1/2" Coord Name Job Number: Drawina Date: TBRD-0007-00 1/27/2024 GREG P. 859-578-4355 TO COLUMN C.L. House Name: Drawing Scale: 1/8" = 1'0" Contract Drawn By 8'-10 3/4" 3'-0 1/4" the PARKETTE 18'-5" 9'-3 1/2" 12'-1 1/2" EXECUTIVE 7'-4 1/2" 51'-9" Plan No.: 69'-11 1/2" CDs Drawn Bv **HOMES**_{SM} Copyright © 2023 (2023) The Drees Company. All Rights Reserved. 8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288 Elevation "A"



General Notes:

1. REFER TO SHEET ON.1 FOR GENERAL NOTES. 2. REFER TO SHEET S-0 FOR STRUCTURAL DETAILS AND INFORMATION

Key Notes:

ST1A 4x4 P.T. POST W/ SIMPSON BCS2-2/4 CAP & ABW44Z BASE

STIC FRAME TOP OF BEAM AT 9'-1" ABOVE INTERIOR FIRST FLOOR SUBFLOOR/SLAB

TIM HANG DROPPED BEAM TO POST W/ SIMPSON HUC210-2 HANGER

Space for Architect Seal



The Drees Company 07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD


Job Number: 1/27/2024 859-578-4355 TBRD-0007-00 GREG P. House Name: Drawing Scale: 1/8" = 1'0"

the PARKETTE

EXECUTIVE Plan No.:

HOMES_{SM} Copyright © 2023 (2023) The Drees Company. All Rights Reserved. 8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288

Elevation "A"



6/3/2025 4:30:20 PM



General Notes: 1. REFER TO SHEET ON.1 FOR GENERAL NOTES. 2. REFER TO SHEET S-0 FOR STRUCTURAL DETAILS AND INFORMATION Space for Architect Seal The Drees Company 07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD

Drawing Date: Coord Name: 1/27/2024 859-578-4355 TBRD-0007-00 GREG P. Drawing Scale: 1/8" = 1'0"

the PARKETTE

EXECUTIVE Plan No.:





Elevation "A"

	HEEL	CUT STAN	IDARDS
		OVERH	HANG
		1'-0"	2'-0"
	4:12	3-3/4"	7-3/4"
	5:12	4-3/4"	9-3/4"
	6:12	5-3/4"	11-3/4"
E.	7:12	6-3/4"	13-3/4"
ROOF PITCH	8:12	7-3/4"	N/A
90F	9:12	8-3/4"	N/A
2	10:12	9-3/4"	N/A
	12:12	11-3/4"	N/A
	14:12	13-3/4"	N/A


ROOF VENTILATION	
CITY/SERIES:	RALEIGH
	MAIN HOUSE
TOTAL ATTIC AREA:	3,566
REQUIRED NET FREE VENTILATION (ATTIC AREA/300):	11.89
ACTUAL NET FREE VENTILATION (UPPER + LOWER):	11.96
MOITA IIIO IAO TILOGRIAWOO	


DOWNSPOUT CALCULA	ATION
	MAIN HOUS
TOTAL DRAINABLE ROOF AREA:	4635.8
MINIMUM # OF DOWNSPOUTS:	8





ntracts/SOUTHEAST/RALEIGH/TBRD/TBRD-0007-00/TBRD-0007-0





General Notes:

- 1. REFER TO SHEET ON.1 FOR GENERAL NOTES.
- 2. FLOOR JOISTS TO BE 14" TJI 210 SERIES, OR EQUAL, @ 19.2" O.C., UNLESS OTHERWISE NOTED.
- 3. JOISTS ARE NOT TO BE PLACE DIRECTLY OVER INTERIOR PARALLEL WALL.
- 4. ADD'L JOISTS MAY BE LOCATED UP TO 2" AWAY FROM THE PARTITION WALL ABOVE IN CASES
- WHERE MECHANICAL PENETRATIONS
 5. REFER TO SHEET S-0 FOR STRUCTURAL DETAILS AND INFORMATION

Key Notes:

302A BEARING WALL BELOW

302B BEAM BELOW - SEE SHEET 2.01S FOR MORE INFO

302C FLUSH BEAM - SEE SHEET 2.01S FOR MORE INFO

302L 2x12 FLAT FRAME (TOP FLUSH) FOR HEADROOM OVER STAIRS - FASTEN TO LYL EA, END W/ SIMPSON A21 CLIPS (4 TOTAL) - SEE STAIR DETAIL

Space for Architect Seal



The Drees Company 07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD

TBRD-0007-00 1/27
House Name:

the PARKETTE

Job Number:

g Date: Coord Name: Coord Phone: 1/27/2024 GREG P. 859-578-4355

Drawing Scale: 1/8" = 1'0" Contract Drawn By


Series: EXECUTIVE


Plan No.:




3.02

Second Floor Subfloor Plan
Elevation "A"









. REFER TO SHEET ON.1 FOR GENERAL NOTES.

Key Notes:

- 401A TO SWITCH OR LIGHT ABOVE
- 401C SEE DETAIL A/4.01 FOR KITCHEN ISLAND COUNTERTOP DIMENSIONS
- 401D HOLD OUTLET HIGH ON ISLAND
- OUTLET FOR RANGE HOOD/MICROWAVE HELD HIGH VENT TO EXTERIOR
- OUTLET FOR DISHWASHER LOCATED IN SINK CABINET
- LOCATE WASHER TO LEFT OF DRYER
- UPPER WALL CABINETS OR 16" DEEP x 5'-6" LONG SHELF HELD AT 5'-7" A.F.F. REFER TO SELECTIONS

CLG. MOUNTED LIGHT FIXT.

SURFACE MOUNT DISC LIGHT OR RECESSED CEILING LIGHT, PER SPECS.

— WALL MOUNTED LIGHT FIXT.

₩ WALL SCONCE @ 5'-6" A.F.F.

DOUBLE SPOTLIGHT FIXT.

PIN LIGHT

FLUORESCENT LIGHT

> UNDER CABINET LIGHTING

- PRE-FABRICATED FIREPLACE INSERT
- 401M 22-1/2" x 32" ATTIC ACCESS PANEL IN CEILING
- 401R LOCATE SHOWER CONTROLS HERE

MECHANICAL LEGEND

- ⇒ WALL OUTLET
- € WEATHERPROOF GFCI OUTLET
- ₹ 220 VOLT OUTLET ੇ ਭੇ⊖= GFCI OUTLET
- FLOOR OUTLET
- ← SINGLE POLE SWITCH

- STAIR LIGHT
- BLOCK, MOUNT, & SWITCH FOR FUTURE FAN/LIGHT
- COMBINATION (CENTER, UNLESS OTHERWISE NOTED)

- + HOSE BIB
- SHOWER HEAD GAS GAS HOOK UP
- (SD) SMOKE DETECTOR
- SMOKE DETECTOR/ CO DETECTOR COMBINATION
- EXHAUST FAN AND LIGHT COMBINATION O CLG. MTD. EXHAUST FAN
- DATA JACK
- (TV) CABLE TELEVISION JACK

Space for Architect Seal



The Drees Company 07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD **TOBACCO ROAD**

Coord Name Job Number: TBRD-0007-00 1/27/2024 GREG P. 859-578-4355 House Name: Drawing Scale: 1/8" = 1'0"

the PARKETTE

Born on Date: CDs Drawn Bv

HOMES_{SM} Copyright © 2023 (2023) The Drees Company. All Rights Reserved. 8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288


Elevation "A"

Plan No.:

EWT

EXECUTIVE





RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD

Job Number:	Drawing Date:	Coord Name:	Coord Phone:
TBRD-0007-00	1/27/2024	GREG P.	859-578-4355
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Contract Drawn By
			EW1

the PARKETTE


Born on Date:

EXECUTIVE


Plan No.: 07/11/23 CDs Drawn By:


HOMES_{SM} Copyright © 2023 (2023) The Drees Company. All Rights Reserved. 8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288

Elevation "A"



BUILDING SECTION THRU FAMILY ROOM 5.01 1/8" = 1'-0"





B BUILDING SECTION THRU GARAGE
5.01 1/8" = 1'-0"



TYPICAL TRIM:

(ALL SIDES)

8" FRIEZE (FRONT ONLY, UNLESS OTHERWISE NOTED)

General Notes:

- . REFER TO SHEET ON.1 FOR GENERAL NOTES.
- 2. ROOFING MATERIAL PER SELECTIONS.

 3. CONTACT M&K ENGINEERING FOR HEADER SIZE/BRICK SUPPORT IF GRADE DROPS AND THE AMOUNT OF BRICK OVER GARAGE DOOR SHOWN ON CURRENT ELEVATION IS NO LONGER ACCURATE
- 4. REFER TO SHEET S-0 FOR STRUCTURAL DETAILS AND INFORMATION

Key Notes:

Space for Architect Seal



07/07/2025 9:40:07 AM

RESIDENCE FOR:

MARKET

243 HARVESTER ROAD TOBACCO ROAD

Coord Name: Job Number: TBRD-0007-00 1/27/2024 859-578-4355 GREG P. House Name: Drawing Scale: 1/8" = 1'0"

the PARKETTE


EXECUTIVE

Plan No.:

HOMES_{SM} Copyright © 2023 (2023) The Drees Company. All Rights Reserved.

8521 Six Forks Road, Suite 500, Raleigh, NC 27615 Phone: [919] 844-9288

Elevation "A"





5/3/2025 4:30:23 PM






6/3/2025 4:30:24 PM







243 HARVESTER ROAD TOBACCO ROAD

the PARKETTE


Series:
EXECUTIVE
Plan No.:

Date: 07/11/23 CDs Drawn By:

Copyright © 2023 [2023] The Drees Company, All Rights Reserved.
8521 Six Forks Road, Suite 500, Raleigh, NC 27615
Phone: [919] 84449288


7.0


House Specific Deta





BEARING COLUMN

NON-BEARING COLUMN










c 2ND FLOOR STAIR DETAIL
7.02 1/4" = 1'-0"



K:\Contracts\SOUTHEAST\RALE\GH\TBRD\TBRD-0007-00\TBRD-0007-4

CONNECTION SPECIFICATIONS (TYP. U.N.O.) NOTE: IOd NAII = 3" x 0 I31" GUN NAII JOIST TO SOLE PLATE SOLE PLATE TO JOIST/BLK'S. STUD TO SOLE PLATE (3)10d toenails 10d nails • 6" o.c (3)10d TOENAILS ZIM TO TOP PLATE Ind to ENAILS @ 6" oc BLK'G. BTWN. JOISTS TO TOP PL. (3)10d TOENAILS TER/TRUSS TO TOP PLATE (1) SIMPSON H2.5A AB. END TRUSS TO DBL. TOP PL. | 10d TOENAILS • 8" o R.T. w/ HEEL HT. 9 以 TO 12" 2xIO BLK EVERY 3RD BAY FASTENED TO DBL. TOP PLATE W/ IOd TOENAILS @ 6" O.C. R.T. w/ HEEL HT. 12" TO 16" 2xI2 BLK EVERY 3RD BAY FASTENED TO DBL. TOP PLATE w/ 10d toenails @ 6" O.C. R.T. w/ HEEL HT. UP TO 24" LAP WALL SHTG. W/ DBL. TOP PL. INSTALL ON TRUSS VERT Fasten W 8d Nails @ 6" O.C R.T. w/ HEEL HT. 24" TO 48" LAP WALL SHTG. W/ DBL. TOP PL. INSTALL ON TRUSS VERT FASTEN w/ 8d NAILS @ 6" O.C PROVIDE 2x BLK . EA. BAY AT TOP OF HEEL 10d NAILS @ 24" o.c. DOUBLE TOP PLATE 10d NAILS @ 24" 0.0 DOUBLE TOP PLATE LAP SPLICE (10)10d NAILS IN LAPPED AREA OP PLATE LAP O CORNERS \$ NTERSECTING WALLS VALL TO FOUNDATION WALL SHTG. LAP W/ SILL PL. & ASTENED PER SHEAR WALL

GARAGE SLAB

4" CONC. SI AB W/ 6x6-WI 4xWI 4 WWF ON 6 MIL VAPOR BARRIER ON 4" MIN GRANULAR FILL ON 95% COMPACTED FILL VIRGIN SOIL

PORCH SLAB

4" CONC. SLAB W/ 6x6-WI.4xWI.4 WWF ON 95% COMPACTED FILL/VIRGIN SOIL

BASEMENT SLAB 4" CONC. SI AB ON 6 MIL VAPOR BARRIER

ON 4" MIN. GRANULAR FILL ON 95% COMPACTED FILL MIRGIN SOIL

SLAB ON GRADE

4" CONC. SLAB w/ 6x6-WI.4xWI.4 WWF ON 6 MIL VAPOR BARRIER ON 4" MIN. GRANULAR FILL ON 95% COMPACTED FILL MIRGIN SOIL

HOLD-DOWN SCHEDULE

SYMBOL	SPECIFICATION
► HD-I	SIMPSON HTT4 HOLD-DOWN *
▶ HD-2	SIMPSON HDU4-SDS2.5 HOLD-DOWN *
▶ нр-з	SIMPSON HDU5-SDS2.5 HOLD-DOWN *
► HD-4	SIMPSON STHDI4RJ HOLD-DOWN
▶ HD-5	SIMPSON CSI6 STRAP TIE (14" END LENGTH)
► HD-6	SIMPSON MSTC40 STRAP TIE (CENTER STRAP ON FLOOR SYSTEM U.N.O.)
► HD-7	SIMPSON MSTC66 STRAP TIE (CENTER STRAP ON FLOOR SYSTEM U.N.O.)

ALTERNATIVE TO SSTB24 ANCHOR BOLT SPECIFICATION: * UTILIZE SIMPSON "SET" EPOXY SYSTEM TO FASTEN % DIA. THREADED ROD INTO CONCRETE FOUNDATION. PROVIDE 12" MIN. EMBEDMENT INTO CONCRETE.
INSTALL PER MANUF. RECOMMENDATIONS. DO NOT LOCATE ANCHORS WITHIN I 3/4" OF EDGE OF FOUNDATION

YENEER LINTEL SCHEDULE

SPAN (MAX)	HEIGHT OF VENEER ABOVE LINTEL	STEEL ANGLE SIZE
3'-0 "	20 FT. MAX	L4"x3"x4;"
6'-0"	3 FT. MAX	L4'x3'x/4"
0-0	I6 FT. MAX	L5'x3'x%'
β'-0 "	6 FT. MAX	L5'x3'x%'
9'-6"	3 FT. MAX	L5'x3'x%'
12'-0"	2 FT. MAX	L5'x3'x%'

LUNIELS: MALL SUPPORT 2 %" - 3 ½" VENEER N/ 40 pet MAXIMUM MEIGHT. 6' SHALL HAVE 4" MIN BEARING 6' SHALL HAVE 8" MIN BEARING 2' SHALL NOT BE FASTENED BACK TO HEADER.

IZ SHALL BY FOR PASTEND PACK TO FEADER IN MALL 649'06. N /3' DIA x 5 3'.

LONG LAS SCRIPPS IN 2' LONG VERTICALLY SUTTED HOLES.

LONG LAS SCRIPPS IN 2' LONG VERTICALLY SUTTED HOLES.

LONG LAS SCRIPPS IN 2' LONG VERTICALLY SUTTED HOLES.

LINES SHALL BE CANCE OF SERVICE OF THE COPENNO.

LL LINES SHALL BE CANCE OF SERVIS STREET.

LL SHELD SHALL SHA

MIK STND. - MAY 20

LEGEND

INTERIOR BEARING WALL

BEAM / HEADER

EXTENT OF OVERFRAMING

INDICATES EXTENT OF INT. OSB SHEARWALL BLOCKED PANEL EDGES.

INDICATES HOLDOWN

JOISTS SHALL BE DESIGNED TO MEET THE DEFLECTION CRITERIA BELOW, UNLESS NOTED THERWISE ON PLAN. MULHERN & KULP CANNOT BE HELD RESPONSIBLE FOR ANY STRUCTURAL ISSUES RELATED TO ANY BUILDING COMPONENT IF COMPONENT SHOP DRAWINGS ARE NOT SUBMITTED TO M&K FOR REVIEW PRIOR TO FABRICATION, DELIVERY, OR INSTALLATION.

TRUSSES/JOISTS SHALL BE DESIGNED SO THAT DIFFERENTIAL DEFLECTION BETWEEN ADJACENT BEAMS DO NOT EXCEED THE FOLLOWING: ROOF TRUSSES

ABSOLUTE DEAD LOAD DEFECTION OF FLOOR RUSSES/ATTIC TRUSSES WHEN ADJACENT TO FLOOR FRAMING BY OTHERS SHALL BE LIMITED TO 3/16". (NOT DIFFERENTIAL DEFLECTION

FOUNDATION

DESIGN IS BASED ON 2018 NORTH CAROLINA RESIDENTIAL CODE.

FOOTING DESIGN - 1500 PSF NET ALLOWABLE SOIL BEARING PRESSURE IS ASSUMED. BUILDER/CONTRACTOR MUST VERIFI

ANCHORS PER PLATE, 12" MAX. FROM PLATE ENDS - UTILIZING:

• 1/2" DIA, ANCHOR BOLTS @ 6'-0" O.C.7" MIN, EMBEDMENT

BUILDER TO VERIEY CORROSION-RESISTANCE COMPATIBILITY OF HARDWARE & FASTENERS IN CONTACT W/ PRESERVATIVE-TREATED

CONCRETE DESIGN BASED ON ACI 318, CONCRETE SHALL ATTAIN THE FOLLOWING MIN. COMPRESSIVE STRENGTHS IN 28 DAYS, U.N.O.:

3500 osl: GARAGE & EXTERIOR SLABS ON GRADE

BEARING WALL ABOVE

METAL HANGER

• JL

INDICATES POST ABOVE (P.A.) PROVIDE SOLID BLOCKING UNDER POST OR JAMB

ADDITIONAL NOTES FOR TRUSS \$ I-JOIST MANUFACTURER

ROOF TRUSS, FLOOR TRUSS AND ENGINEERED

'ARALLEL TRUSSES/JOISTS OR GIRDER TRUSSES/FLUS

I/4" DEAD LOAD

FLOOR TRUSSES ATTIC TRUSSES & I- KISTS

GENERAL STRUCTURAL NOTES

FASTEN 2x SILL PLATES TO CONC FND WITH A MINIMUM OF 2

SIMPSON MAB STRAPS @ 32" O.C . SIMPSON MASA ANCHOR STRAPS @ 6'-0" O.C.

ALL LUMBER EXPOSED TO WEATHER OR IN CONTACT W PERIMETER FOUNDATION SHALL BE PRESERVATIVE TREATED SOUTHERN PINE #2

WOOD, CONTACT LUMBER & HARDWARE SUPPLIERS TO COORD.

FOUNDATION WALLS & FOOTINGS SHALL BE PLAIN CONCRETE, U.N.O.

fic = 4,000 psi: FOUNDATION WALLS 3,000 psi: FOOTINGS & INTERIOR SLABS ON GRADE

BASEMENT FOUNDATION WALL DESIGN BASED ON:

. 8' OR 9' HEIGHT (AS NOTED ON PLANS)

- TALLER WALLS MUST BE ENGINEERED NOMINAL WIDTH (8" FOR 8' WALL, 10" FOR 10' WALL)

BASEMENT WALL DESIGN IS BASED ON 30 OR 45 PCF BACKFILL

SOIL TYPE CLASSIFICATIONS:

30 PCF TYPE (GW, GP, SW, SP) 45 PCF TYPE (GM, GC, SM, SM-SC, ML)

IMPORTANT - IF 60 PCF SOIL TYPE (SC, ML-CL, OR CL) IS UTILIZED FOR BACKFILL, CONTACT MULHERN & KULP FOR URTHER EVALUATION OF FOUNDATION DESIGN.

BASEMENT WALLS SHALL BE BRACED, PRIOR TO BACKFILLING, BY ADEQUATE TEMPORARY BRACING OR INSTALL ISt FLOOR DECK

PROVIDE (2) #5 BARS AROUND ALL SIDES OF OPENINGS IN CONCRETE BSMT, FND, WALL WITH 2" CLEAR, REINFORGEMENT

SHALL EXTEND 12" PAST CORNER OF OPENING IN ALL DIRECTIONS.

• FOR OPENINGS UP TO 36", PROVIDE MINIMUM 10" CONCRETE

DEPTH OVER OPENING OR (3)2x10 w/(2)2x6 JACK STUDS, U.N.O LARGER OPENINGS SHALL BE PER PLAN.

ALL CONCRETE EXPOSED TO THE WEATHER SHALL NOT HAVE LESS THAN 5% OR MORE THAN 7% AIR ENTRAINMENT

ALL FOOTINGS SHALL BEAR BELOW FROST LINE (TYP.) OR 12" MIN IN REGIONS WHERE CODE FROST DEPTH IS NOT APPLICABLE. CONSUL SOILS REPORT OR BUILDING DEPT. FOR MINIMUM DEPTH BELOW

FOOTINGS AND SLABS ON GRADE SHALL BEAR ON VIRGIN SOIL OR 95% COMPACTED FILL.

PROVIDE CONTROL JOINTS AT ALL INSIDE CORNERS OF SLAB EDGES, AND OTHER LOCATIONS WHERE SLAB CRACKS ARE LIKELY • JOINTS SHALL BE LOCATED • 10'-0" O.C. (RECOMMENDED) OR

15'-0" O.C. (MAXIMUM)

• JOINT GRID PATTERN SHALL BE AS CLOSE TO SQUARES AS POSSIBLE (I:I RATIO), WITH A MAXIMUM OF I:1.5 RATIO

· CONTROL JOINTS SHALL NOT BE INSTALLED IN STRUCTURAL

TYPICAL REINFORGEMENT DETAILS: PROVIDE 3" MIN. CLEAR COVER WHERE CAST AGAINST EARTH, I 1/2" MIN. CLEAR COVER AGAINST FORMS. LAP ALL REBAR 48 BAR DIAMETERS MIN. (24" FOR #4 BARS) & BEND BARS AND LAP AT CORNERS PROVIDE 6 HOOK INTO SUPPORTING FOOTINGS WHEN FOOTINGS INTERSECT

DIMENSIONS BY OTHERS, BUILDER TO VERIFY.

LATERAL/WALL BRACING & WALL SHEATHING SPECIFICATIONS

THIS MODEL HAS BEEN DESIGNED TO RESIST LATERAL FORCES RESULTING FROM: 120 MPH WIND IN 2018 NCSRC

> (120 MPH WIND SPEED IN ASCE 7-10 WIND MAP, PER IRC R301,2,1,1) EXP. B & SEISMIC CAT. A/B.

EXT. WALL SHEATHING SPECIFICATION

7/16" OSB OR 15/32" PLYWOOD: FASTEN SHEATHING W/ 2 3"x0.113 NAILS @ 6" O.C. AT EDGES & @ 12" O.C. IN THE PANEL FIELD. (TYP. U.N.O.

ALL SHEATHING PANELS SHALL BE ORIENTED VERTICALLY (LONG DIRECTION PARALLEL TO STUDS) AND INSTALLED FULL HEIGHT OF SHEAR WALL - OR 2x HORIZONTAL BLOCKING SHALL BE PROVIDED TO SUPPORT ALL UNSUPPORTED PANEL EDGES \$ EDGE

ALL EXT. WALLS SHALL BE CONTINUOUSLY SHEATHED AND ARE CONSIDERED SHEAR WALLS.

ALT. STAPLE CONNECTION SPEC: 1 3/4" 16 GA STAPLES (1/4" CROWN) @ 3" O.C. AT EDGES & @ 6" O.C. IN FIELD.

3" O.C. EDGE NAILING

AT DESIGNATED AREAS - FASTEN PANEL EDGES OF WOOD STRUCTURAL WALL SHEATHING TO FRAMING W 2 3" x 0.113" NAILS @ 3" O.C. AND 12" O.C. IN THE PANEL FIELD NO STAPLE ALTERNATIVE AVAILABLE AT THIS SPEC. ALL SHEATHING PANELS SHALL BE DRIENTED VERTICALLY (LONG DIRECTION PARALLEL TO STUD) AND INSTALLED FULL HEIGHT OF SHEAR WALL - OR - 2x HORIZONTAL BLOCKING SHALL BE PROVIDED TO SUPPORT UNSUPPORTED PANEL EDGES AND 3" O.C. EDGE FASTENING.

NOTES

SEE CONNECTION SPECIFICATIONS CHART FOR STANDARD SHEAR TRANSFER DETAILING. IF ADDITIONAL CAPACITY IS REQUIRED BY DESIGN T WILL BE SPECIFICALLY NOTED ON PLAN.

DESIGN ASSUMES 16" O.C MAX. STUD SPACING, U.N.O.

ALL STRUCTURAL PANELS ARE TO BE DIRECTLY

PRE-MANUFACTURED PANELIZED WALLS: FASTEN TOGETHER END STUDS OF WALL PANELS SHEATHED W/ OSB OR PLYWOOD W/ IOd NAII S 9 4" O.C. (THRU ONE SIDE ONLY)

> INDICATES EXTENT OF INT. OSB SHEARWALL, BLOCKED PANEL EDGES. AND/OR 3" O.C. EDGE NAILING



INDICATES POST ABOVE (P.A.) PROVIDE SOLID BLOCKING UNDER POST OR JAMB

MIK STND. - SEPT. 20

GENERAL STRUCTURAL NOTES

FLOOR FRAMING

I-JOISTS/TRUSSES SHALL BE DESIGNED BY MANUF. TO MEET OR EXCEED L/480 LIVE LOAD DEFLECTION CRITERIA. (EXCLUDES STONE/MARBLE OR WET BED CONSTRUCTED FLOORS - CONTACT M&K FOR EXCLUDED FLOOR DESIGNS)

PER THE GUIDELINES OF THE TILE COUNCIL OF NORTH AMERICA (TCNA HANDBOOK), IT SHALL BE THE FLOOR FINISH INSTALLER'S MATCH THE DESIGN CRITERIA NOTED ABOVE (UNDER "DESIGN

AT I-JOIST FLOORS, PROVIDE I 1/8" MIN. OSB RIM BOARD.

• METAL HANGERS SHALL BE SPECIFIED BY MANUFACTURER, U.N.O.

 FLOOR SHEATHING SHALL BE 23/32" A.P.A. RATED 'STURD-I-FLOOR 24" O.C., EXPOSURE I (OR APPROVED EQUAL) WITH TONGUE AND GROOVE EDGES. FASTEN TO FRAMING MEMBERS W GLUE AND

- 2 1 x 0.131" NAILS @ 6"0c. @ PANEL EDGES & @ 12"0c. FIELD. - 2 3" x 0 120" NAILS @ 4" OC @ PANEL EDGES & @ 8" OC FIELD

- 2 3" x 0.113" NAILS @ 3" O.C. @ PANEL EDGES & @ 6" O.C. IN FIELD

ROOF FRAMING

ROOF SHEATHING SHALL BE 7/16" A.P.A. RATED SHEATHING 24/16 EXPOSURE I (OR APPROVED EQUAL). FASTEN TO FRAMING MEMBERS

W/ 2 3" x 0.131" NAILS @ 6"O.C. @ PANEL EDGES & @ 12" O.C. FIELD. W/ 2 8 × 0.120 NAILS @ 4 O.C. @ PANEL EDGES \$ @ 8" O.C. FIELD. - W/ 2 🖥 x 0.113" NAILS @ 3"O.C. @ PANEL EDGES \$ @ 6" O.C. FIELD.

WITHIN 48" OF ALL ROOF FDGES, RIDGES, & HIPS FASTEN ROOF SHEATHING FIELDS PER EDGE NAILING SPEC.

FASTEN EACH ROOF TRUSS TO TOP PLATE W SIMPSON H2.5A CLIP (OR APPROVED EQUAL) • ALL BEARING POINTS. PROVIDE (2) H2.5A CLIPS AT 2-PLY GIRDER TRUSSES, (3) H2.5A CLIPS AT 3-PLY GIRDER TRUSSES & ROOF BEAMS - AT ALL BEARING POINTS.

METAL HANGERS SHALL BE SPECIFIED BY THE MANUFACTURER, U.N.O.

ERECT AND INSTALL ROOF TRUSSES PER WITCA & TPI'S BOSI "GUIDE TO GOOD PRACTICE FOR HANDLING INSTALLING & BRACING OF METAL PLATE CONNECTED WOOD TRUSSES.

SUPPORT SHORT SPAN ROOF TRUSSES w/2x4 LEDGER FASTENED TO FRAMING W/(2) 3" x 0.120" NAILS @ 16" O.C. (UP TO 7' SPAN).

MULHERN+KULP

n 215-646-8001 ► mulhernkuln con

RESIDENTIAL STRUCTURAL ENGINEERING 300 Brookside Ave, Building 4 ► Ambler, PA 19002

GENERAL STRUCTURAL NOTES

DESIGN IS BASED ON 2018 NORTH CAROLINA RESIDENTIAL CODE.

WOOD FRAME ENGINEERING IS BASED ON NDS, "NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION" - LATEST EDITION.

DESIGN LOADS **ROOF**

LIVE = 20 PSF (18 PSF REDUCED) DEAD = 1 PSE TO TO PSE BO LOAD DURATION FACTOR = 1.15

LIVE = 40 PSF (30 PSF @ SLEEPING AREAS) DEAD = 10 PSF (1-JOISTS & SOLID SAWN) ADD'L IO PSF @ CERAMIC TILE IN KITCHEN, BATHS, SUNROOM, & LAUND.

1,500 PSF ASSUMED ALLOWABLE BEARING PRESSURE (TO BE VERIFIED BY BUILDER)

GENERAL FRAMING

ALL TYP. NAIL FASTENER REQUIREMENTS ARE NOTED IN STANDARD CONNECTIONS TABLE (IRC TABLE R602.3(1)) OR ON PLANS. ALL VAILS SPECIFIED ARE MIN DIAMETER AND LENGTH REQUIRED FOR CONNECTION ALL HANGER NAILS SHALL BE INSTALLED PER NOTE: HANGERS USE COMMON NAIL DIAMETERS NOT TYPICAL

EXT. \$ INT. BEARING WALLS SHALL BE 2x4 OR 2x6 (AS SHOWN ON PLANS) • 16" O.C. SPF "STUD" GRADE LUMBER, OR BETTER, U.N.O. MALLS OVER 10' TALL SHALL BE PER PLAN.

ALL INTERIOR BEARING WALLS ARE ASSUMED TO BE SHEATHED W GYP WALL BOARD (ONE SIDE MIN.) OR PROVIDE MID HT. BLOCKING

ALL 2x8, 2x10, \$ 2x12 HEADERS, BEAMS \$ OTHER STRUCTURAL MEMBERS SHALL BE S.Y.P. #2 LUMBER, OR BETTER ALL 2x6 HEADERS, BEAMS & OTHER STRUCTURAL MEMBERS SHALL

BE SPF "STUD" GRADE LUMBER, OR BETTER. SUPPORT ALL HEADERS/ BEAMS W (1)2x JACK STUD \$ (1)2x KING

THE NUMBER OF STUDS SPECIFIED AT A SUPPORT INDICATES THE NUMBER OF JACK STUDS REQUIRED, U.N.O., ALL NON-BEARING INTERIOR STUD WALLS SHALL BE CONSTRUCTED WITH 2X STUD' GRADE MEMBERS SPACED @ 24" O.C. (MAX., U.N.O.)

* HEADERS IN NON-LOAD BEARING WALLS SHALL BE:

(1)2x4/6 FLAT @ OPENINGS UP TO 4', (2)2x4/6 FLAT UP TO 8'.

ALL FRAMING LUMBER SHALL BE DRIED TO 15% MC (KD-15). ENGINEERED LUMBER BEAMS TO MEET OR EXCEED THE FOLLOWING 'LSL' - Fb=2325 psi: Fv=310 psi: E=1,55x10^6 psi

· 'LVL' - Fb=2600 psi; Fv=265 psi; E=2.0x10^6 psi ENGINEERED LUMBER POSTS TO MEET OR EXCEED THE FOLLOWING

• 'LVL' - Fb=2400 psi; FcII=2500 psi; E=I.8xI0^6 psi FOR 2 & 3 PLY BEAMS OF EQUAL 13/4" MAX. WIDTH, FASTEN PLIES TOGETHER WITH 3 ROWS OF 3"x0.120" NAILS @ 8" O/C OR 2 ROWS 以"x3K" SIMPSON SDS SCREWS (OR 3K" TRUSSLOK SCREWS) @ 16' O/C. USE A MINIMUM OF 4 ROWG FOR BEAM DEPTHS OF 14" OF GREATER. APPLY FASTENING AT BOTH FACES FOR 3-PLY CONDITION. LOCATE TOP & BOTTOM NAILS/SCREWS 2" FROM EDGE SOLID 3 K" OR 5 K" BEAMS ARE ACCEPTABLE. USE 2 ROWS OF NAILS FOR 2x6 \$ 2x8 MEMBERS

FOR 4 PLY BEAMS OF EQUAL 13/4" MAX. WIDTH, FASTEN PLIES TOGETHER WITH 3 ROWS OF 1/4"x6" SIMPSON SDS SCREWS (OR 6 3/4" TRUSSLOK SCREMS) • 16" O/C. USE A MINIMUM OF 4 ROWS FOR BEAM DEPTHS OF 14" OR GREATER, APPLY FASTENING AT BOTH FACES (ONE SIDE ONLY FOR TRUSSLOK SCREWS). LOCATE TOP AND BOTTOM SCREWS 2" FROM EDGE. A SOLID 7" BEAM IS ACCEPTABLE

PROVIDE SOLID BLOCKING IN FLOOR SYSTEM UNDER ALL POSTS

FASTEN 2x WOOD PLATES TO TOP FLANGE OF STEEL BEAMS WITH PAE'S ('HILTI' XI PINS OR FOUAL) @ 16" O.C. STAGGERED. OR I/2" DIA. BOLTS • 48" O.C. STAGGERED.

STEEL PIPE COLUMN "ASD CAPACITIES" SHALL MEET OR EXCEED THE LOADS PROVIDED AT EACH STEEL PIPE COLUMN LOCATION ON PLAN. COLUMNS ARE TO BE INSTALLED PER THE MANUFACTURER'S REQUIREMENT THAT ACHIEVES THE RATED CAPACITY USED NCLUDING BUT NOT LIMITED TO POSITIVE CONNECTIONS AT THE TOP AND BOTTOM OF THE COLUMN, TWO COLUMNS MAY BE USED UNDER CONTINUOUS BEAMS TO ACHIEVE THE FULL PLAN SPECIFIED REQUIRED CAPACITY IF INSTALLED CENTERED ON THE EXISTING FOOTING/ PLAN SPECIFIED SINGLE COLUMN LOCATION





Mulhern+Kulp project number

085-2001

BSM drawn by: B.JC issue date 08-08-2

REVISIONS


project mar


initial: DML

MULHERN+KULP
RESIDENTIAL STRUCTURAL ENGINEERING

Y

Ш STRUCTUR Ш ARKI





TYPICAL SHEAR TRANSFER DETAIL

@ INTERIOR SHEARMALL SAFELY SAFELY (INIT)

TYPICAL SHEAR TRANSFER DETAIL @ INTERIOR SHEARWALL

SCALE 5/4"=1"-0" 5/6"=1"-0" (lixiti)



085-2001

drawn by: BJD issue date: 08-08-23

REVISIONS:

initial: DML


MUCHERNHAU STRUCTURAL ENGINEERING
300 Brodside Ave Building 4 - Ambler, PA 19002
p. 215-596-8001 - mulliaming.com


¥


MODEL MODEL STRUCTURAL PARKETTE N

SD-1

BOTH SIDES OF GARAGE DOOR 115 MPH WIND SPEED (ULT)










The Drees Company 07/07/2025 9:40:22 AM



D2.2



SHEET NO.




1'-4"

— CROWN MOULD (PER SPECS)









STANDARD FRAMING DETAILS RALEIGH DIVISION SCALE: AS NOTED

D2.5




The Drees Company 07/07/2025 9:40:22 AM





Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.




2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.

Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On

-5-1/4" CROWN MOULD 5/8"x3/4" BASE MOULD


TYPICAL PLAN



(VARIES) TYPICAL PLAN




Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.



12x6 BOX BEAM

TYPICAL PLAN

(VARIES)



DETAIL





The Drees Company 07/07/2025 9:40:22 AM

Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.

CEILING TREATMENTS


SCALE: AS NOTED






FIREPLACE DOGHOUSE SECTIONS

SCALE: 1/4" = 1'-0"



DIRECT VENT REAR WALL FRAMING

CALE: 1/4" = 1'-0"



RAVE FIREPLACE PLATFORM DETAIL

SCALE: 1/2" = 1'-0"

A C

<u>NOTE:</u> PROVIDE OSB SHEATHING WHEN STONE VENEER SELECTED

	FIREPLACE RC	DUGH OPEN	IING SCHED	ULE	
	MODEL	А	В	С	D
FIREPLACE MANUFACTURER		(FIREBOX REQUIRED WIDTH)	(FIREBOX REQUIRED HEIGHT) *ADD 18" W/ OPT. HEARTH	(FIREBOX REQUIRED DEPTH - INTERIOR REAR WALL TO FRONT EXTERIOR WALL)	(VENT CENTERLINE HEIGHT) *ADD 18" W/ OPT. HEARTH
	SLIMLINE SL-7	42"	38-1/4"	16-1/4"	TOP 40" SIDE 26-7/8"
HEAT & GLO	COSMO 42	49"	32-3/4"	17-3/4"	TOP ONLY 47-1/16"
	NOVUS 33	39"	34-7/8"	19-5/8"	TOP 40" SIDE 23-1/2"
	COURTYARD 36	43-3/8"	44-1/8"	18-3/8"	SEE MANUFACTURER'S SPEC
HEARTH & HOME	COURTYARD 42	48-1/2"	34-1/4"	20-1/4"	SEE MANUFACTURER'S SPECS
NEAKIN & NOME	LANAI *(NOT IN CINCY/NKY)	57-3/4"	39-1/2"	17-5/8"	SEE MANUFACTURER'S SPECS
	RAVE	49"	32-3/4" *RAISED 15-1/4"*	18-1/4"	TOP ONLY 46-1/2"
-	•		all dimensions	are in inches	



REFER TO SHEET ON.1 FOR GENERAL NOTES.
 VERIFY FIREPLACE MODEL AND HEARTH SELECTION WITH CUSTOMER'S SELECTIONS.

Key Notes

1 FUTURE FRAMING FOR F.P. OPENING AFTER INSULATION HAS BEEN INSTALLED IN EXT. WALLS

2 FLASHING

3 HEADER PER PLAN

4

5 1" AIRSPACE

6 BOX OUT FOR FLUE (REFER TO SELECTIONS FOR FIREPLACE AND OPENING HEIGHT)





The Drees Company

211 Grandview Drive Fort Mitchell, Kentucky 41017 PH:(859) 578-4200

Copyright © 2021, [2021] The Drees Company. All Rights Reserved. No portion of this material may be reproduced in any form or by any means, including photocopying, without the express written permission of the Drees Company. The Drees Company will vigorously prosecute any unauthorized use of this material. FIREPLACE DETAILS

Std. Drawn By:	MRPH	Sheet Description:	SCALE: VARIES
		FIREPLACE DETAIL	
Std. Date:	02.29.20		
Date of Last Rev:	7.10.2023	g:\architecture\cincinnati\cinti standard drawings\fireplace\fireplace defail sheets.dwg	

Sheet No.

F-1

RALEIGH WINDOW SCHEDULE

* MEETS EMERGENCY ESCAPE & RESCUE OPENING REQUIREMENTS

Drees General	Window Type	MI Windows and Doors Capitol Series			Drees General				
Callout	Willdow Type	Call No. Rough Opening	Call No.	Rough Opening	Callout	Call No.	Rough Opening	Call No.	Rough Opening
1660	SINGLE/DOUBLE HUNG	CW3500 1/8 x 6/0 20" x 60-1/4"							
1670 1860	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 1/8 x 7/0 20" x 84" CW3500 1/8 x 6/0 20" x 60-1/4"							
2030	SINGLE/DOUBLE HUNG	L CW3500 2/0 x 3/0 L 24" x 36"		 					
2040	SINGLE/DOUBLE HUNG	CW3500 2/0 x 4/0 24" x 48"							
2050	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/0 x 5/0 24" x 60-1/4" CW3500 2/0 x 6/0 24" x 72"							
2060 2070	SINGLE/DOUBLE HUNG	CW3500 2/0 x 6/0 24 x 72							
2430	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/0 x 7/0 24" x 84" CW3500 2/4 x 3/0 28" x 36"							
2440	SINGLE/DOUBLE HUNG	CW3500 2/4 x 4/0 28" x 48"							
2450 2460	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/4 x 5/0 28" x 60-1/4" CW3500 2/4 x 6/0 28" x 72"							
2830	SINGLE/DOUBLE HUNG	CW3500 2/8 x 3/0 32" x 36"							
2840	SINGLE/DOUBLE HUNG	CW3500 2/8 x 4/0 32" x 48" CW3500 2/8 x 5/0 32" x 60-1/4"							
2850 2860	SINGLE/DOUBLE HUNG	CW3500 2/8 x 5/0 32" x 60-1/4" CW3500 2/8 x 6/0 32" x 72"							
3030	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/8 x 6/0 32 x 72 CW3500 3/0 x 3/0 36-1/4" x 36"		+					
3040	SINGLE/DOUBLE HUNG	CW3500 3/0 x 4/0 36-1/4" x 48"							
3050	SINGLE/DOUBLE HUNG	CW3500 3/0 x 5/0 36-1/4" x 60-1/4"							
3060 3070	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 3/0 x 6/0 36-1/4" x 72" CW3500 3/0 x 7/0 36-1/4" x 84"		-					
3470	SINGLE/DOUBLE HUNG	CW3500 3/0 x 7/0 30-1/4 x 84"		 					
1050 FIXED		910T 5/0 x 1/0 59-5/8" x 11-1/2"							
1640 FIXED		910T 4/0 x 1/8 47-1/4" x 19-1/2"							
2020 FIXED 2030 FIXED		CW3500 2/0 x 2/0 24" x 24" CW3500SL 2/0 x 3/0 24" x 36"							
2040 FIXED		CW3500SL 2/0 x 3/0 24 x 30 CW3500SL 2/0 x 4/0 24" x 48"							
2050 FIXED		CW3500SL 2/0 x 5/0 24" x 60-1/4"							
2816 FIXED		910TSL 2/6 x 1/8 29-1/4" x 19-1/2" CW3500 3/0 x 6/0 36" x 72"							
2860 FIXED 3016 FIXED		910TSL 3/0 x 1/8 35-1/4" x 19-1/2"		+					
3020 FIXED		910TSL 3/0 x 2/0 35-1/4" x 23-1/2"							
3030 FIXED		CW3500P 3/0 x 3/0 36-1/4" x 36"							
3040 FIXED 3050 FIXED		CW3500P 3/0 x 4/0 36-1/4" x 48" CW3500P 3/0 x 5/0 36-1/4" x 60-1/4"		-					
3060 FIXED		CW3500P 3/0 x 5/0 36-1/4 x 60-1/4 CW3500P 3/0 x 6/0 36-1/4" x 72"							
3070 FIXED		CW3500P 3/0 x 7/0 36-1/4" x 84"							
4010 FIXED		910T 4/0 x 1/0 47-1/4" x 11-1/2"							
4020 FIXED 4030 FIXED		910T 4/0 x 2/0 47-1/4" x 23-1/2" CW3500P 4/0 x 3/0 48" x 36"							
4040 FIXED		CW3500F 4/0 x 4/0 48" x 48"							
4044 FIXED		CW3500P 4/0 x 4/4 48" x 52"							
4050 FIXED		CW3500P 4/0 x 5/0 48" x 60-1/4"							
4060 FIXED 4070 FIXED		CW3500P 4/0 x 6/0 48" x 72" CW3500P 4/0 x 7/0 48" x 84"		+					
5030 FIXED		CW3500P 5/0 x 3/0 60" x 36"							
5040 FIXED		CW3500P 5/0 x 4/0 60" x 48"							
5060 FIXED 5070 FIXED		CW3500P 5/0 x 6/0 60" x 72" CW3500P 5/0 x 7/0 60" x 84"							
6020 FIXED		910T 6/0 x 2/0 71-5/8" x 23-1/2"		 					
6050 FIXED		CW3500P 6/0 x 5/0 72" x 60-1/4"							
6060 FIXED		CW3500P 6/0 x 6/0 72" x 72"							
3'-0" HALF ROUND 4'-0" HALF ROUND		CW3500 3/0 HC 36-1/4" CW3500 3/0 HC 48"		+					
5'-0" HALF ROUND		CW3500 3/0 HC 60"							
2020 OCTAGON	UND	CW3500 2/0 OCT 24"							
2'-4" QUARTER RO 3'-0" QUARTER RO		CW3500 2/4 QC 28" CW3500 3/0 QC 36-1/4"							
3-U QUAKTEK KU	עוויט	CW3300 3/0 QC 30-1/4							



Drees Homes

7701 Six Forks Road, Suite 132, Raleigh, NC 27615 PH:(919) 844-9288

Copyright © 2008, (2013) The Drees Company. All Rights Reserved. No portion of this material may be reproduced in any form or by any means, including photocopying, without the express written permission of the Drees Company. The Drees Company will vigorously prosecute any unauthorized use of this material.

Sheet Description:

WINDOW SCHEDULE

Sheet No.

MOULDED MILLWORK SCHEDULE

LAST REVISED 11/22/1

Droos Coporal Callout	Number	Fypon
Drees General Callout	Nuwood	* *
ARCHED HEADER D1	H8xxEFR	N/A
ARCHED HEADER D1K	H8xxEFKR	N/A
ARCHED HEADER D2	H8xxEFTR	N/A
ARCHED HEADER D2K	H8xxEFTKR	N/A
ARCHED HEADER D3	AH10xx	WCHSEGxxX10
ARCHED HEADER D3K	N/A	WCHSEGxxX10K
ARCHED HEADER D4	AR5xx	ARxxX6M
ARCHED HEADER D4K	AR5xxK	ARxxX6MK
ARCHED HEADER D5	AR10xxEC	ARXXX6METAR6C
ARCHED HEADER D5K	AR10xxECK	ARXXX6METAR6CK
ARCHED HEADER D6	AR10xxC	ARxxX10MC
ARCHED HEADER D6K	AR10xxCK	ARxxX10MCK
ARCHED HEADER D7K	H7xxEF-4K	N/A
ARCHED HEADER D8	AR14xxC	ARXXX14MC
ARCHED HEADER D8K	AR14xxCK	ARxxX14MCK
ARCHED HEADER D9	H9xxE	WCHARSxx13
CROSSHEAD A1	H9xx	WCHxxX9N
CROSSHEAD A1K	H9xxK	WCHxxX9NK
CROSSHEAD B1	H14xxBT	WCHxxX14BT
CROSSHEAD B1K	H14xxBTK	WCHxxX14BTK
CROSSHEAD B2	H12xx	WCHxxX12
CROSSHEAD B2K	H12xxK	WCHxxX12K
CROSSHEAD C1	H18xxBT	WCHxxX14BT
CROSSHEAD C1K	H18xxBTK	WCHxxX14BTK
CROSSHEAD C2	H18xxBT-PA	LDCHxxX18
CROSSHEAD C2K	H18xxBTK-PA	LDCHxxX18K
CROSSHEAD Z-E1-HDR	Z-E1-HDR	Z-E1-HDR
CROSSHEAD Z-E2-HDR	Z-E2-HDR	Z-E2-HDR
Crosshead z-e3-hdr	Z-E3-HDR	Z-E3-HDR
CROSSHEAD Z-E3-ARCHHDR	Z-E3-ARCHHDR	Z-E3-ARCHHDR
CROSSHEAD Z-E3-CLHDR	Z-E3-CLHDR	Z-E3-CLHDR
CROSSHEAD Z-E5-HDR	Z-E5-HDR	Z-E5-HDR
WINDOW HEADER A1	H6xx	WCHxxX6
WINDOW HEADER A1K	H6xxK	WCHxxX6K
WINDOW HEADER B1	H9xx-2	WCHxxX9N
WINDOW HEADER B1K	H9xx-2K	WCHxxX9NK
WINDOW HEADER B2	H9xxBT	WCHxxX10NBT
WINDOW HEADER B2K	H9xxBTK	WCHxxX10NBTK
WINDOW HEADER C1	H9xx	CCAxxX10
WINDOW HEADER C1K	H9xxK	CCAxxX10K
WINDOW HEADER C2	H9xxT	WCHxxX9T
WINDOW HEADER C2K	H9xxTK	WCHxxX9TK
WINDOW HEADER C3	H12xxBT	WCHxxX10BT
WINDOW HEADER C3K	H12xxBTK	WCHxxX10BTK
WINDOW HEADER C4	H14xxBT	WCHxxX14BT
WINDOW HEADER D1	H7xxF-4	N/A
WINDOW HEADER D1K	H7xxF-4K	N/A
WINDOW HEADER D2K	H9xxK-1	N/A
WINDOW HEADER Z-W1	Z-W1	Z-W1
WINDOW HEADER Z-W3	Z-W3	Z-W3
WINDOW HEADER Z-W3K	Z-W3K	Z-W3K
WINDOW HEADER Z-W3D	Z-W3D	Z-W3D
WINDOW HEADER Z-W4	Z-W4	Z-W4
window header z-w4k	Z-W4K	Z-W4K

PILASTERS				
Drees General Callout	Nuwood	Fypon		
FLUTED PILASTER A1	PL7xxF	PIL7Xxx		
FLUTED PILASTER B1	PL9xxF	PIL9Xxx		
FLUTED PILASTER C1	PL11xxFM	PIL11Xxx		
PANEL PILASTER A2	PL7xxP	PIL7XxxDP		
PANEL PILASTER B2	PL9xxP	PIL9XxxDP		
PANEL PILASTER C2	PL11xxPM	PIL11XxxDP		
PILASTER D1	M311-9	PIL10XxxA		
PILASTER D2	M323-9	N/A		
PILASTER Z-E1-PIL	Z-E1-PIL	Z-E1-P I L		
PILASTER Z-E2-PIL	Z-E2-PIL	Z-E2-PIL		
PILASTER Z-E3-PIL	Z-E3-PIL	Z-E3-PIL		
PILASTER Z-PIL-EXT	Z-PIL-EXT	Z-PIL-EXT		
PLAIN PILASTER A3	PL7xxS	PIL7XxxP		
PLAIN PILASTER B3	PL9xxS	PIL9XxxP		
PLAIN PILASTER C3	PL11xxS	PIL11XxxP		
PLINTH D1	PF10	ADD "P" TO END OF PILASTER		
PLINTH D2	P14.5	N/A		
LOUVERS				

Drees General Callout	Nuwood	Fypon	Mid-America
CATHEDRAL LOUVER D1	CLV1224	CLV12X24	
CATHEDRAL LOUVER D1T	CLV1224TRIM4	CLV12X24X4F	
CATHEDRAL LOUVER D2	CLV1432	CLV14X32	
CATHEDRAL LOUVER D2T	CLV1432TRIM4	CLV14X32X4F	00 44 1422
CATHEDRAL LOUVER D3	CLV2232	CLV22X32	
CATHEDRAL LOUVER D3T	CLV2232TRIM4	CLV22X32X4F	
HALF CIRCLE LOUVER D1	HRLV32	HRLV32X16	
HALF CIRCLE LOUVER D1T	HRLV32TRIM4	HRLV32X4F	
HALF CIRCLE LOUVER D2	HRLV36	HRLV36X18	

HALF CIRCLE LOUVER DT	HRLV32	HRLV32X16	
HALF CIRCLE LOUVER D1T	HRLV32TRIM4	HRLV32X4F	
HALF CIRCLE LOUVER D2	HRLV36	HRLV36X18	
HALF CIRCLE LOUVER D2T	HRLV36TRIM4	HRLV36X4F	00 43 2234
OCTAGONAL LOUVER D1	OLV24	OLV24	
OCTAGONAL LOUVER D12	OLV24TRIM4	OLV24X4F	
OVAL LOUVER D1	OLV2537	OLV37X25	
OVAL LOUVER D1T	OLV2537TRIM4	OLV37X25X4F	
RECTANGUAR LOUVER D1	LV1224V	LV12X24	00 45 1218
RECTANGUAR LOUVER D1T	LV1224VTRIM4	LV12X24-4F	00 45 1218
RECTANGUAR LOUVER D2	LV1636V	LV16X36	
RECTANGUAR LOUVER D2T	LV1636VTRIM4	LV16X36-4F	
RECTANGUAR LOUVER D3	LV2436V	LV24X36	
RECTANGUAR LOUVER D3T	LV2436VTRIM4	LV24X36-4F	
RECTANGUAR LOUVER D4	LV2424V	LV24X24	
RECTANGUAR LOUVER D4T	LV2424VTRIM4	LV24X24-4F	
ROUND LOUVER D1	RLV18	RLV18	
ROUND LOUVER DIT	RLV18TRIM4	RLV18X4F	
ROUND LOUVER D2	RLV22	RLV22	
ROUND LOUVER D2T	RLV22TRIM4	RLV22X4F	
TRIANGULAR LOUVER D1		TRLVxxX36	00 47 0x0x
· ·	· · · · · · · · · · · · · · · · · · ·	1	· · · · · · · · · · · · · · · · · · ·

BRACKETS

Drees General Callout	Nuwood	Fypon
EXTERIOR BRACKET D1	BR437	N/A
EXTERIOR BRACKET D2	DB102	DTLB6X4X6
EXTERIOR BRACKET D3	BR304 (7" WIDE)	BKT24X24X7
EXTERIOR BRACKET D4	BR455	N/A
EXTERIOR BRACKET D5	BR300-1	BKT12X12X6
EXTERIOR BRACKET D6	BR300	BKT12X12
EXTERIOR BRACKET D7	BR409	BKT16X18X3
EXTERIOR BRACKET D8	BR413	DTLB5X5X3
EXTERIOR BRACKET D9	TBD	BKT11X20
EXTERIOR BRACKET D10	TBD	BKT12X24X3
EXTERIOR BRACKET D11	BR435	BKT25X27
EXTERIOR BRACKET D12	BR404	BKT16X30X4
EXTERIOR BRACKET D13	BR23.13x10.13x5.5	N/A
GABLE BRACKET D1	TBD	DTLB6X4X6R(OR L)PITCH
GABLE BRACKET D2	BR423-x:12	BKT5X20
GABLE BRACKET D3	BR424-x:12	BKT5X20 (CUT 2" PROJECTION)

MOULDINGS			
Drees General Callout	Nuwood	Fypon	
BAND MOULD D1	M210-16	MLD612-12	
BAND MOULD D2	M301-16	MLD220-16	
BARGE MOULD D1	WM210	WM210	
CASE MOULD D1	M320-16	MLD226-16	
CASE MOULD D2	N/A	MLD244-12	
CROWN MOULD D1	M404-16	MLD572-16	
DENTIL MOULD D1	M105-16	MLD310-16	
DENTIL MOULD D2	M108-8	MLD353-8	
HALF ROUND MOULD D1	N/A	MLD605-12	
PANEL MOULD D1	M310-8 OR 16	MLD612-12	

PEDIMENTS / COMBO HEADERS

Drees General Callout	Nuwood	Fypon
BROW COMBO D1	BCxx	CSAPxx
PEAK PEDIMENT D1	Pxx-4 (6:12)	PCPxx
PEAK PEDIMENT Z-E1-PED	Z-E1-PED	Z-E1-PED
PEAKED COMBO D1	PCxx-4	CPCPxx
RAMS HEAD PEDIMENT D1	Rxx	RHPxx00
ROUND PEDIMENT D1	Bxx-4	PSPxx
SUNRISE COMBO D1	SCxx-4	CSPxx
VICTORIAN PEDIMENT D1	VPxx	DVPxx w/ SWDHxxXxx

WINDOW DECORATION

Drees General Callout	Nuwood	Fypon
HALF CIRCLE SUNBURST D1	SPxxxx	SWDHxxXxx
PALLADIAN WINDOW D1	H9AR10-xx xx" FL/FR	ARxxX10MFLxxx
PALLADIAN WINDOW D1K	H9AR10-xxK xx" FL/FR	ARxxX10MFLxxx with K10TM
PALLADIAN WINDOW D2	H9AR10SPxxxx	ARxxX10MFLxxx with
		SWDHxxXxx
PALLADIAN WINDOW D2K	H9AR10SPxxxxK	ARxxX10MFLxxx with
		SWDHxxXxx and K10TM
PEAKED CAP HEADER D1	N/A	CHPCxxX15
PLAIN SEGMENT D1	SPxxxxP	PSPxx
SEGMENT SUNBURST D1	SPxxxx	SWDHxxXxx

ACCESSORIES

Drees General Callout	Nuwood	Fypon
GABLE D1	PGDx12	GPA (width X height)
KEYSTONE D1	KY14F-3	KY14
KEYSTONE D2	KYHM9F	К9М
WREATH D1	N/A	WAB34



Sheet Description:

MOULDED MILLWORK SCHEDULE

Sheet No.