

## Kimberly Gibbons

---

**From:** Jay Sikes  
**Sent:** Wednesday, November 19, 2025 1:50 PM  
**To:** Kimberly Gibbons  
**Subject:** SFD2507-0042

Hey Kimberly,

The per the distance shown on this provided plot plan it seems to show house will be in FEMA floodplain. A survey drawn site plan is needed to show exact location of house. If in floodplain, an Elevation Certificate will be needed, which would be completed by a surveyor. Also, it should not be in Conservation area.

Thank you,

**Jay Sikes, CFM**  
Development Services Assistant Director/ Manager of Planning Services  
Harnett County Development Services



(910) 814-6418 | [jsikes@harnett.org](mailto:jsikes@harnett.org)

420 McKinney Parkway (physical) | P.O. Box 65 (mailing) | Lillington, N.C. 27546

[www.harnett.org/planning/](http://www.harnett.org/planning/)

Privacy & Confidentiality Notice

Email correspondence to and from this address may be subject to the North Carolina Public Records Law and shall be disclosed to third parties when required by statutes. (NCGS Ch. 132)