

ROY COOPER • Governor

KODY H. KINSLEY • Secretary

MARK BENTON • Chief Deputy Secretary for Health

SUSAN KANSAGRA • Assistant Secretary for Public Health

Division of Public Health

Submittal Includes:	(a2) Improvement Permit	(a2) Construction Authorization	Fee \$
	IMPROVEM	ENT PERMIT FOR G.S. 130A-335	i(a2)
County: Harnett			
	42-84-4681 (Birchwood	Trails, Lot 71)	
Issued To: KB Hom	es		
Property Location: 53	Thunderbird Lane, Fuq	uay Varina, NC 27526	
Subdivision (if applicable	_{e)} Birchwood Trails	Lot #: 71	Block: Section:
LSS Report Provided: Y			
If yes, name and license	number of LSS: Heath Clapp	#1354	
New Facility Type: SFR (4	Expansion 1-bedroom)	System Relocation	
		Other:	
Design Wastewater Stre	ength: Domestic	☐ High Strength ☐ Industri	al Process Wastewater
Proposed Design Daily I	Flow: 480 GPD	Proposed LTAR (Initial): 0.4	oposed LTAR (Repair): 0.4
Proposed Wastewater S	System Type*: Accepted Pre	ssure Manifold (Initial) Pump Req	uired: • Yes No May be required
Proposed Wastewater S	System Type*: Accepted Pre	ssure Manifold (Repair) Pump Req	uired: Tes No May be required
*Please include system	classification for proposed wastew	ater system types in accordance with Rule	.1301 Table XXXII
Effluent Standard:	DSE HSE NSF/ANSI 40	☐ TS-I ☐ TS-II ☐ RCW	
Saprolite System (Initia	l): Yes No Saprolite	System (Repair): Yes 🔳 No	
Fill System (Initial):	Yes 🔳 No If yes, specify: 🗌 Nev	Existing (when adding more than 6	inches of fill to system area provide a fill plan)
			6 inches of fill to system area provide a fill plan)
Usable Depth to LC (Init	tial) ^x : 35"	Usable Depth to LC (Repair)x: 35"	× Limiting Condition
Max. Trench Depth (Init	tial)‡: 23" Max. Tre	nch Depth (Repair)‡: 23"	Measured on the downhill side of the trench
Artificial Drainage Requ	ired: Yes 🔳 No If yes, please	e specify details:	
Type of Water Supply: [Private well Public well	Shared well Municipal Supply	Spring Other:
Drainfield location mee	ts requirements of Rule .0508: Yes	■ No Drainfield location meets r	requirements of Rule .0601: Yes 🔳 No 🗌
Permit valid for: 🔳 Five	e years [site plan submitted pursua	nt to GS 130A-334(13a)] No expiratio	n [plat submitted pursuant to GS 130A-334(7a)]
Permit conditions:			
	1111-01		
	rint Name: Heath Clapp	th Clapp	10/6/2025
Licensed Soil Scientist S	ignature: #100	IN CHARACTER STATES	Date: 10/6/2025

The LSS evaluation is being submitted pursuant to and meets the requirements of G.S. 130A-335(a2).



This Section for Local Health Department Use Only

Initial submittal received: _	10	14	25	by <u>OT</u>	
		Di	ate	Initials	

G.S. 130A-335(a3) states the following:

When an applicant for an Improvement Permit submits to a local health department an Improvement Permit application, the permit fee charged by the local health department, the common form developed by the Department, and a soil evaluation pursuant to subsection (a2) of this section, the local health department shall, within five business days of receiving the application, conduct a completeness review of the submittal. A determination of completeness means that the Improvement Permit includes all of the required components. If the local health department determines that the Improvement Permit is incomplete, the local health department shall notify the applicant of the components needed to complete the Improvement Permit. The applicant may submit additional information to the local health department to cure the deficiencies in the Improvement Permit. The local health department shall make a final determination as to whether the Improvement Permit is complete within five business days after the local health department receives the additional information from the applicant. If the local health department fails to act within any period set out in this subsection, the applicant may treat the failure to act as a determination of completeness. The Department shall develop a common form for use as the Improvement Permit.

The review for completeness of this Improvement Permit was conducted in accordance with G.S. 130A-335(a3). This Improvement Permit is determined to be:

Incomplete (If box is checked, information in this section is required.)

The following items are missing:	
Copies of this were sent to the LSS and the Applicant on	_
State Authorized Agent:	Date:
Complete State Authorized Agent: 0435	Date: Joliahs

This Improvement Permit is issued pursuant to G.S. 130A-335.(a2) and (a3) using the signed and sealed LSS/LG evaluation(s) attached here. The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

The Department, the Department's authorized agents, and the local health departments shall be discharged and released from any liabilities, duties, and responsibilities imposed by statute or in common law from any claim arising out of or attributed to evaluations, submittals, or actions from a licensed soil scientist or licensed geologist pursuant to GS 130A-335(a2).

Improvement Permit Expiration Date: 10 17 30

See attached site sketch



CONSTRUCTION AUTHORIZATION FOR G.S. 130A-335(a2)

County: Harne	ett	Pre-Construction Conference Required: Yes No	
PIN/Lot Identifier	0642-84-468	31 (Birchwood Trails, Lot 71)	
Issued To: KB H	Homes		
Property Location	53 Thunderb	bird Lane, Fuquay Varina, NC 27526	
AOWE/PE Plans/E	Evaluations Provided:	d: Yes No If yes, name and license number of AOWE/PE: Heath Clapp, 10057E	
the state of the s	R (4-bedroom		
Number of bedro	oms: 4 Numb	ber of Occupants: 8 Other:	
■ New	Expansion	Repair System Relocation Change of Use	
Basement?	Yes	■ No Basement Fixtures?	
		■ No Slab Foundation? ■ Yes No	
Type of Wastewa	ter System* ACCE	epted Pressure Manifold (Initial) Accepted Pressure Manifold (Fig. 1)	Repair
	400	for proposed wastewater system types in accordance with Rule .1301 Table XXXII	
Design Daily Flow	480	GPD Wastewater Strength: Domestic High Strength Industrial Process W	W
	-120 Section 53, Eng vide engineering doc	gineering Design Utilizing Low-flow Fixtures and Low-flow Technologies? Yes No cumentation)	
Effluent Standard	: DSE HSE	SE NSF/ANSI 40 TS-II RCW	
Type of Water Su	pply: 🗌 Private well	ll ☐ Public well ☐ Shared well ■ Municipal Supply ☐ Spring ☐ Other:	
	irements/Conditions		
Septic Tank Size:	1,250 gallons	Total Trench/Bed Length: 300 feet Trench/Bed Spacing: 9 feet on center	
Trench/Bed Widt	h: <u>36</u> inches	Total Trench/Bed Length: 300 feet Trench/Bed Spacing: 9 feet on center LTAR: 0.4 gpd/ft² Usable Depth to LC (Initial)x: 35" xLimiting condit	ion
Soil Cover: 0	inches Slope Co	orrected Maximum Trench/Bed Depth [‡] : 23" inches * Measured on the downhill side of the tren	ich
Pump Tank Size (i	f applicable): 1,25	gallons Requires more than 1 pump? Yes No	
Pump Requireme	nts: 12.28 ft. TDH v	vs. 28.85 GPM Grease Trap Size (if applicable): N/A gallons	
Distribution Meth	nod: Serial 🔲	D-Box or Parallel Pressure Manifold(s) LPP Other:	
Artificial Drainage	Required: Yes	No If yes, please specify details:	
Legal Agreement	s (If the answer is "Ye	Yes" to any type of legal agreements, please attach a copy of the agreement.)	
		04(g)]: Yes No Declaration of Restrictive Covenants: Yes No	
Easement, Right-o	of-Way, or Encroachr	ment Agreement Required [.0301(b)]: Yes • No	
Management Ent	ity Required: Yes	No Minimum O&M Requirements:	
Permit condition	ons:		
			_
with the attached Construction Aut	d site sketch. <u>This Co</u> horization shall not	are incorporated by reference into this permit and shall be met. Systems shall be installed in accordan Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. To be affected by a change in ownership of the site. This Construction Authorization is subject to complied or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.	The
AOWE/PE Print N	_{ame:} Heath Cla	app	
AOWE/PE Signatu		Hath Clapp Date: 10/6/2025	
	This AOWE/PE	PE submittal is pursuant to and meets the requirements of G.S. 130A-335(a2) and (a5).	

See attached site sketch



This Section for Local Health Department Use Only

Initial submittal received:	10	14	25	by _0T
		Da	te	Initials

G.S. 130A-335(a5) states the following:

When an applicant for a Construction Authorization, or an Improvement Permit and Construction Authorization together, submits a Construction Authorization, or an Improvement Permit and Construction Authorization application together, the permit fee charged by the local health department, the common form developed by the Department, and any necessary signed and sealed plans or evaluations conducted by a person licensed pursuant to Chapter 89C of the General Statutes as a licensed engineer or a person certified pursuant to Article 5 of Chapter 90A of the General Statutes as an Authorized On-Site Wastewater Evaluator, the local health department shall, within five business days of receiving the application, conduct a completeness review of the submittal. A determination of completeness means that the Construction Authorization or Improvement Permit and Construction Authorization includes all of the required components. If the local health department determines that the Construction Authorization or Improvement Permit and Construction Authorization is incomplete, the local health department shall notify the applicant of the components needed to complete the Construction Authorization or Improvement Permit and Construction Authorization. The applicant may submit additional information to the local health department to cure the deficiencies in the Construction Authorization or Improvement Permit and Construction Authorization. The local health department shall make a final determination as to whether the Construction Authorization or Improvement Permit and Construction Authorization is complete within five business days after the local health department receives the additional information from the applicant. If the local health department fails to act within any period set out in this subsection, the applicant may treat the failure to act as a determination of completeness. The applicant may apply for the building permit for the project upon the decision of completeness of the Construction Authorization or Improvement Permit and Construction Authorization by the local health department or if the local health department fails to act within five business days. The Authorized On-Site Wastewater Evaluator or licensed engineer submitting the evaluation pursuant to this subsection may request that the local health department revoke or suspend the Construction Authorization or Improvement Permit and Construction Authorization for cause. Upon written request of the Authorized On-Site Wastewater Evaluator or licensed engineer, the local health department shall suspend or revoke the Construction Authorization or Improvement Permit and Construction Authorization pursuant to G.S. 130A-23. The Department shall develop a common form for use as the Construction Authorization.


The review for completeness of this Construction Authorization was o	onducted in accorda	ance with G.S. 130A-335(a5). This
Construction Authorization is determined to be:		
☐ Incomplete (If box is checked, information in this section is require	red.)	
The following items are missing:		
Copies of this were sent to the AOWE/PE and the Applicant on	Date	5
State Authorized Agent:		Date:
Complete State Authorized Agent:		Date of Issuance: 10 17 35

This Construction Authorization is issued pursuant to G.S. 130A-335(a2) and (a5) using the signed and sealed plans or evaluations attached here. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

The Department, the Department's authorized agents, and the local health departments shall be discharged and released from any liabilities, duties, and responsibilities imposed by statute or in common law from any claim arising out of or attributed to plans, evaluations, preconstruction conference findings, submittals, or actions from a person licensed pursuant to Chapter 89C of the General Statutes as a licensed engineer or a person certified pursuant to Article 5 of Chapter 90A of the General Statutes as an Authorized On-Site Wastewater Evaluator in GS 130A-335(a2), (a5), and (a7). The Department, the Department's authorized agents, and the local health departments shall be responsible and bear liability for their actions and evaluations and other obligations under State law or rule, including the issuance of the operations permit pursuant to GS 130A-337.

30

See attached site sketch



Agri-Waste Technology, Inc. 1225 Crescent Green, Suite 250 Cary, North Carolina 27518 919-859-0669 www.agriwaste.com

KB Home Birchwood Trails - Lot 71

Project Location: 53 Thunderbird Lane, Fuguay Varina, NC 27526 Harnett County PIN: 0642-84-4681

Project Owner. KB Hame 1800 Perimeter Park Drive, STE 140, Morrisville, NC 27560 919-766-7950 enpolitock@kthome.com

NC ONSITE WASTEWATER



REY. ISSUED DATE DESCRIPTION

Property Layout

DRAWN BY: H. Clapp	10/6/2025
REVISED BY:	REVISED ON:
RELEASED BY:	RELEASED ON

DRAWING MUMBER

WW-2