



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

11/10/2025

SUBJECT: SFD2508-0087
SINGLE FAMILY DWELLING

To: Steve Thomas

Here are the results of all Inspections located at **105 POWELL FARM RD**:

Inspection Type: ADDRESS

Scheduled Date/Time:

Completed Date/Time:

Inspector: GIS Bucket

Result:

Remarks:

Notes:

Inspection Type: CONDITIONAL POWER

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:

Inspection Type: GAS PIPING

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:

Inspection Type: INSULATION

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SEWER SERVICE INSPECTION

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:

Inspection Type: T-POLE

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:

Inspection Type: WATER SERVICE INSPECTION

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:

Inspection Type: ENV OPERATIONS PERMIT

Scheduled Date/Time:

Completed Date/Time:

Inspector: EH Bucket

Result:

Remarks:

Notes:

Inspection Type: FINAL SFD MONO**

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SETBACK VERIFICATION SURVEY

Scheduled Date/Time:

Completed Date/Time:

Inspector: CP Bucket

Result:

Remarks: not needed

Notes:

Inspection Type: ROUGH IN

Scheduled Date/Time:

Completed Date/Time:

Inspector: James T Hall

Result:

Remarks:

Notes:

Inspection Type: UNDER SLAB TRADES

Scheduled Date/Time: 10/15/2025

Completed Date/Time: 10/15/2025

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: MONO SLAB

Scheduled Date/Time: 10/20/2025

Completed Date/Time: 10/20/2025

Inspector: Kory S Denny

Result: APPROVED

Remarks:

Notes:

Inspection Type: ROUGH IN

Scheduled Date/Time: 11/10/2025

Completed Date/Time: 11/10/2025

Inspector: John B Kokoszka

Result: DISAPPROVED

Remarks:

Notes: Need to see a water heater lines to the outside. Need correct nails in girder truss Missing baffles were needed A03 trusses are in the wrong spot Note that the porch posts not installed