

Harnett County Department of Public Health

PERMIT # SFD 2509-0007

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 98 Gray Pine Way

SUBDIVISION Briarwood Park

LOT # 5

Name: (owner) Smith Douglas Homes

System Installer: A&R

Basement with plumbing: Garage Number of Bedrooms 3 (6 people)


Type of Water Supply: Community Public Well Distance from well _____ feet

System Type: Type III B Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____

Subsurface system operator required? Yes No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

Manifold D-Box Pump Alarm H2OLine PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 25% reduction in Q4 Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface No. of exact length width of ditches 18 inches

Drainage Field ditches 1 feet 3 feet

French Drain Required: Linear feet

Authorized State Agent _____

PCAS

Date 11/26/25