ROOF TRUSS NOTES: DO NOT CUT, DRILL, NOTCH, OR OTHERWISE 50-09-08 DAMAGE TRUSSES. Contact your BFS Representative for assistance PRIOR TO modifying 16-11-08 33-10-00 any truss. Espanol - (NO CORTE, PERFORE, HAGA 1-03-08 MUESCAS O DANE DE CUALQUIER OTRA MANERA LAS TRUSSES (CERCHAS DE MADERA). Contacte a su representante de BFS para sistencia ANTES de realizar cualquier nodification.) This Truss Placement Diagram is intended to serve as a guide for truss installation. This Diagram has been prepared by a Truss Technician and is not an engineered drawing. 00-00-9 The responsibilities of the Owner, Building Designer, Contractor, Truss Designer, and Truss Manufacturer shall be as defined by the TPI 1 National Standard. 3. The wood components shown on this diagram are to be used in dry service (moisture content<19%) and non-toxic environmental applications. The metal plates and hangers are galvanized to the G60 Standard unless noted otherwise. 4. Refer to the Truss Design Drawings for specific (10) A2 @ 24" O.C. (6) A3 @ 24" O.C. information about each individual truss design. 5. The Truss Technician shall provide Truss-to-Truss (6) A6 @ 24" O.**(** Connection Requirements. Any special or other connection shall be the responsibility of the Building 6. The Truss Placement Diagram and Truss Design Drawings are the property of Builders FirstSource and may not be reused or reproduced in part or in total under any circumstances without prior written 6.5/12 7. In some cases, field framing may be required to achieve the final appearance shown on the 6.5/12 Construction Documents. . Field framing, including valley rafters, installed over roof trusses shall have a knee brace from the rafter to the truss top chord at intervals of 48" on center (O.C.) or less. Stagger knee braces from adjacent rafters such that the load is distributed uniformly over multiple truss locations and not concentrated at one location or along one truss. Truss Top Chords shall be fully sheathed or have lateral bracing (purlins) spaced at 24" O.C. or less. Truss Bottom Chord Bracing shall not exceed the maximum shown on the Truss Design Drawing. Field framed bottom chord floor or ceiling attachments shall be spaced at 24" O.C. or less. Proper Bracing prevents buckling of individual truss members due to design loads. 10. This Placement Diagram is based upon the supporting structure being structurally adequate, dimensionally correct, square, plumb, and level to

adequately support the trusses. The foundation design, structural member sizing, load transfer, bearing conditions, and the structure's compliance with the applicable building code are the responsibility of the Owner, Building Designer, and Contractor.

11. If Piggyback Trusses are included in this project, refer to the Mitek Piggyback Connection Detail applicable for the project details and wind load

category.
12. The Contractor shall follow the SBCA TTB Partition Separation Prevention and Solutions for truss attachment to non-load bearing walls and carefully complete these details to avoid gypsum wall board

WARNING:

TRUSSES MUST BE BRACED DURING INSTALLATION. FAILURE TO DO SO MAY RESULT IN INJURY OR DEATH. ESPANOI - (TRUSSES (CERCHAS) DEBERAN
ITENER UN SOPORTE DURANTE LA INSTALACION

NO HACERLO PODRIA RESULTAR EN LESIONES O MUERTE.)

Trusses shall be installed in a safe manner meetin all code, local, OSHA, TPI, and BCSI Specifications. Failure to follow these specifications may result in injury or death.

2. Buildings under construction are vulnerable to high

winds and present a possible safety hazard. The Contractor is responsible for recognizing adverse veather conditions and shall take appropriate action to prevent injury or death.

BCSI INSTRUCTIONS SHALL BE FOLLOWED:

BCSI-B1 = Safe Truss Handling and Installation BCSI-B2 = Installation and Temporary Restraint

BCSI-B3 = Permanent Restraint

BCSI-B4 = Safe Construction Loading

BCSI-B5 = Truss Damage and Modification Guidelines BCSI-B7 = Floor Truss Installation

BCSI-B8 = Toe-Nailed Connections BCSI-B9 = Multi-Ply Girders

BCSI-B10 = Post Frame Truss Installation BCSI-B11 = Fall Protection

Follow TPI Requirements for Long Span Trusses

TOTAL ROOF AREA 3057.34 SQ FT

