


- Per ANSI/TPI 1-2002 all "Truss to Wall" connections are the responsibility of the Building Designer, not the Truss Manufacturer.
- Dimensions are Feet-Inches- Sixteenths.
- Trusses are to be 24" o.c. unless noted otherwise (U.N.O.)
- Trusses are not designed to support brick U.N.O.
- Do not cut or modify trusses without first contacting Builders FirstSource.
- Immediately contact Builders FirstSource if trusses are damaged.

- All hangers are to be Simpson or equivalent U.N.O.
- Use Manufacturer's specifications for all hanger connections U.N.O.
- Use 10d x 1 1/2" Nails in hanger connections to single ply roof girder trusses.

- Shift truss as required to avoid plumbing traps.
- Installation Contractor and/or Field Supervisor are to verify all dimensions, trap locations, and options prior to installation

- Drawing not to scale. Do not scale dimensions



	<u>MISC MATERIAL</u>

<ul style="list-style-type: none"> • [OPTION 1] • [OPTION 2] • [OPTION 3] 	NC	LOT:	2
		<u>APPPWRRIGHT #</u>	
		4682526	
		<u>CODE:</u>	IRC 2015
		<u>LOADING:</u>	
		T.C.L.L.	40 PSF

REVISION HISTORY		WIND:	
REV1:	XX/XX/XX	M.P.H.	115 MPH
REV2:	XX/XX/XX	EXPOSURE CATEGORY	
REV3:	XX/XX/XX	B (WOODED AREAS/OTHERS)	

HATCH LEGEND	
	ATTIC ROOM
	VOLUME CEILING
	STICK FRAMING

