

HAL OWEN & ASSOCIATES, INC.

SOIL & ENVIRONMENTAL SCIENTISTS

P.O. Box 400, Lillington, NC 27546-0400

Phone (910) 893-8743 / Fax (910) 893-3594

www.halowensoil.com

Site Address: 20 Mendenhall Drive, Angier, NC

County: Harnett PIN 0682-17-8988.000

LHD Reference: SFD2509-0039 HOA Permit #: HOA-AOWE-2407-15

Applicant:

Name: Mattamy Homes, LLC

Address: 11000 Regency Parkway, Suite 110; Cary NC 27518

I, Andrew Brody, acknowledge receipt of the Licensed

Soil Scientist Report which includes:

- Signed and sealed copy of the AOWE's report that includes the information in G.S. 130A-336.2(k)
- Authorization to Operate
- Operation and Management Program

I accept the septic system installation and understand that I will be responsible for continued adherence to the Operations and Management program established by the AOWE.

Drew Brody
Signature

11/21/2025
Date

HAL OWEN & ASSOCIATES, INC.

SOIL & ENVIRONMENTAL SCIENTISTS

P.O. Box 400, Lillington, NC 27546-0400

Phone (910) 893-8743 / Fax (910) 893-3594

www.halowensoil.com

19 November 2025

Mattamy Homes, LLC
11000 Regency Parkway
Suite 110; Cary NC 27518

Reference: LSS Report for Authorization to Operate (ATO)
20 Mendenhall Dr, Angier, NC
Riverfall Subdivision, Lot 36, Phase 2
LHD # SFD2509-0039
AOWE # HOA-AOWE-2407-15

Dear Mattamy Homes, LLC,

This LSS Report is being provided pursuant to and meets the requirements of G.S. 130A-336. This report is based on information provided by the property owner or their representative. Hal Owen & Associates, Inc. is not responsible for false or misleading information that may have been provided to us in pursuit of this permit, nor for concealed conditions on the property. Hal Owen & Associates Inc. does not warrant that the septic system will continue to function satisfactorily in the future.

The septic system for the above referenced property has been installed and was inspected by Hal Owen & Associates staff on 11 November 2025. The system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the AOWE Permit.

Enclosed with this report are the *Septic System Final Inspection Report*, As-Built map (Figure 1), and *Operation and Management Program*.

You will need to sign a document confirming receipt of this report and acceptance of the installed system (pg 1) and submit this report to the Local Health Department (LHD). The LHD shall issue a certificate of occupancy upon receipt of a complete ATO.

I appreciate the opportunity to provide this service. If you have any questions or need additional information, please contact me at your convenience.



Sincerely,

Hal Owen
Licensed Soil Scientist
Authorized Onsite Wastewater Evaluator

LSS Report for Authorization to Operate (ATO)
20 Mendenhall Dr, Lot 36

AOWE# HOA-AOWE-2407-15

19 November 2025

Contacts

APPLICANT

Applicant Name	Mattamy Homes, LLC
Mailing Address	11000 Regency Parkway, Suite 110; Cary NC 27518
Telephone Number	919-625-9546
E-mail Address	Drew.Brody@mattamycorp.com

SOIL SCIENTIST

Company Name	Hal Owen & Associates, Inc.
Mailing Address	PO Box 400, Lillington, NC 27546
Telephone Number	910-893-8743 Fax: 910-893-3594
E-mail Address	hal@halowensoil.com
Licensed Soil Scientist	Hal Owen, LSS#1102 and AOWE# 10036E
System Designer	Jocelyn Proulx
System Inspector	Jocelyn Proulx#9943I

INSTALLER

Company Name	David Brantley & Sons, Inc.
Mailing Address	37 Pine Ridge Rd, Zebulon, NC 27597
Telephone Number	(252) 478-3721
E-mail Address	1installer@gmail.com
Installer & Certification #	Cory J. Brantley #1036

LOCAL HEALTH DEPARTMENT

Agency Name	Harnett County Health Department Environmental Health Division
Mailing Address	307 W Cornelius Harnett Blvd, Lillington, NC 27546
Telephone Number	(910) 893-7547
LHD Application #	SFD2509-0039

Septic System Final Inspection Report

Property Identifiers

County	Harnett	PIN	0682-17-8988.000
Size (Acre)	0.63	County PID	040682 0131 39
Site Address	20 Mendenhall Drive, Angier, NC		
S/D Name and Lot#	Riverfall Subdivision, Lot 36, Phase 2		

System Description

Facility Type	Single Family Residence
Basement	No
Basis of flow	4 bedrooms
Wastewater Strength	Domestic
Design Wastewater Flow	480 gpd
Water Supply	Public
.0403 Eng Low Flow	No
Soil LTAR	0.50
System Type	IIIbg

Installation

Date	11 November 2025
System Inspector	Jocelyn Proulx, #9943I
Installer	Cory J. Brantley #1036

Septic Tank:

Volume (gallons)	1000
Brand and Tank ID#	DB-STB-502
Date of Manufacture	NA
Certified watertight	NA
Distance to Structure	8'
Elevation of tank inlet	5' 10 3/4"
Elevation of tank outlet	6' 1"

Effluent Filter:

Make and Model	SIMTECH STF-110
----------------	-----------------

Pump Tank:

Volume (gallons)	1000
Brand and Tank ID#	DB-PT-237
Date of Manufacture	NA
Certified watertight	NA
Elevation of tank inlet	6' 7"
Elevation of tank outlet	6' 9"

Pump:

Make and Model	Ashland EPF30
Pump Sys- Elevation Head	7.93
Pump Sys- Friction Loss	1.66
Pump Sys- Design Head	2.0
Pump Sys- TDH	11.59
GPM (actual)	25.63

Control Panel:

Manufacturer	Zoeller Model # 51354-0002
--------------	----------------------------

Distribution:

Supply Line Length to Distribution	55'
Supply Line Diameter	2"
Distribution Device:	Pressure Manifold
Number of outlets (laterals)	3

Drainfield:

Type	EZFlow
Distance to Structure	8'
Distance to Well	NA


Trench Depth	24"	Trench width	36"
Trench Spacing	9'	Aggregate	Polystyrene
	<u>Length (ft)</u>	<u>Start</u>	<u>Middle</u>
Line 1	50	4' 8 1/2"	4' 8 1/2"
Line 2	90	5' 2 1/2"	5' 2 1/2"
Line 3	105	5' 7"	5' 7"
Total	245		

All elevations are given as relative grade rod reading.

Notes:

Legend

House
Driveway
→ Distances
Septic Components
Septic Tank
Pressure Manifold
Pump Tank
Drainlines
Initial
Repair
Supply Line



0 40 80 ft

Hal Owen & Associates Inc.
PO Box 400, Lillington, NC 27546
www.halowensoil.com
919-893-8743

20 Mendenhall Drive
Riverfall SD, Ph 2
Lot 36

As-Built Septic Layout

For reference only. Not a survey.

LSS Report for Authorization to Operate (ATO)
20 Mendenhall Dr, Lot 36

AOWE# HOA-AOWE-2407-15

19 November 2025

5

Installation pictures









Operation and Management Program

In accordance with G.S. § 130A-336.2, the owner is responsible for continued adherence to the operations and management program. Septic systems safely treat and dispose of wastewaters produced in the bathroom, kitchen, and laundry. These wastewaters may contain disease-causing germs and pollutants that must be treated to protect human health and the environment. Septic systems must be properly used, operated, and maintained by the homeowner to assure the long-term performance of the system.

PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Section .1300.
- II. Monitoring: As required by Section .1300.
- III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other: _____

Subsurface system operator required? Yes _____ No X _____

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

TABLE XXXII. Management responsibilities based on wastewater system classification type and description.

System Classification Type and Description	LHD Compliance Inspection Frequency	Management Entity	Management Entity Minimum Maintenance Inspection Frequency
IIIB- Wastewater system with a single pump or siphon	5 years NA	Owner or Certified operator	N/A 5 years
IIIG- Other non-conventional systems	N/A	Owner	N/A

KNOW WHERE YOUR SEPTIC SYSTEM IS LOCATED

Your property has an onsite subsurface sewage waste disposal system. Familiarize yourself with the location of the system including the tanks, distribution devices, and disposal fields (including repair area). These areas shall be protected from excavation, building additions, outbuildings, pool construction, and soil disturbing activities. Prohibit vehicular traffic over the ground absorption field.

DAY-TO-DAY MANAGEMENT

Don't use too much water.

- ◆ The drainfield does not have unlimited capacity.
- ◆ Typical daily water use is 50 gallons per person.
- ◆ The soil drainfield usually has a maximum daily design capacity of 120 gallons per bedroom, even for short periods of time.
- ◆ Overloads can occur seasonally, daily, or on the weekend.
- ◆ Water conservation will extend the life of your system.
- ◆ Repair dripping faucets and toilets.

Limit disposal to sewage.

- ◆ Don't use your septic tank as a trash can for cigarette butts, tissues, sanitary napkins, cotton swabs, cat box litter, coffee grounds, or disposable diapers.
- ◆ Restrict the use of your garbage disposal. These add quite a lot of extra solids.
- ◆ Don't pour grease or cooking oil down the drain.
- ◆ Don't poison your system with harmful chemicals such as solvents, oils, paints, thinners, discarded medications, disinfectants, pesticides, poisons, and other substances.
- ◆ Save money. Commercial septic tank additives are usually not necessary.

Protect the system from physical damage (site maintenance).

- ◆ Keep the soil over the drainfield covered with vegetation to prevent soil erosion.
- ◆ Don't drive vehicles over the system.
- ◆ Avoid construction over the system and repair area.
- ◆ Don't cover the tank or drainfield with asphalt or concrete.
- ◆ Do not install irrigation systems over your drainfield as these could damage the system and/or hydraulically overload the soils.

Dispose of all wastewater in an approved system.

- ◆ Don't put in a separate pipe to carry wash waters to a side ditch or the woods. This is illegal.
- ◆ Don't connect pipes from air conditioners or ice makers to the septic system.

PERIODIC MAINTENANCE AND REPAIR

Home and yard (site maintenance):

- ◆ Protect and maintain the site of your septic tank and drainfield.
- ◆ In the drainfield area, cut down and remove trees that like wet conditions. This includes willows, elms, sweetgums, and some maples.
- ◆ Landscape the yard to divert surface waters away from the tank and drainfield. Eliminate depressional areas within the drainfield.
- ◆ Be sure that the water from the roof, gutters, and foundation drains does not flow over the system.
- ◆ Maintain drainage ditches, subsurface tiles, and drainage outlets so that water can flow freely from them.

Septic tank:

- ◆ Ensure tank risers remain accessible for measuring and pumping solids as well as cleaning the effluent filter.
- ◆ Measure how quickly sludge and scum accumulate in the tank. Pump septic when solids occupy 1/3 to 1/4 of the liquid capacity of the tank (frequency 1 to 3 years).
- ◆ Don't wait until your drainfield fails to have your tank pumped. By then, the drainfield may be ruined. With septic systems, an ounce of prevention is worth a ton of cure!

Table 1. Estimated septic tank inspection and pumping frequency (in years). Tank Size (gallons)

Tank Size (gallons)	Number of People Using the System				
	1	2	4	6	8
900	11	5	2	1	<1
1000	12	6	3	2	1
1250	16	8	3	2	1
1500	19	9	4	3	2

SIGNS OF POSSIBLE SEPTIC SYSTEM PROBLEMS

- ◆ Sewage backing up into your toilets, tubs, or sinks.
- ◆ Slowly draining fixtures, particularly after it has rained.
- ◆ The smell of raw sewage accompanied by soggy soil or sewage discharged over the ground or in nearby ditches or woods.
- ◆ Note: pump systems sewage may come to the ground surface when the pump is turned on and then disappear after the pump turns off. This is still a system failure and must be repaired.
- ◆ An alarm flashing (red light) or beeping in the house or in the yard indicating a pump is not working properly or that the water level in a pump tank is too high and close to failure.
- ◆ Don't attempt to repair a failing system yourself. Get a repair permit and hire an experienced contractor.

REGULATIONS AND PRECAUTIONS:

- ◆ Sewage contains germs that can cause diseases. Never enter a septic tank. Toxic and explosive gases in the tank present a hazard. Old tanks may collapse. Electrical controls present a shock and spark hazard. Secure the septic tank lid so that children cannot open it.

For more information about septic systems, contact your county Extension agent or local health department. <https://content.ces.ncsu.edu/septic-system-owners-guide>

Experience and study have shown that pressure manifold systems require routine maintenance in order to function properly. Items 1, 4, and 6 are also recommended for conventional septic systems. The maintenance schedule frequency is as follows:

System Component	Frequency	Maintenance
Septic Tank	6-12 months	Check riser condition (must be accessible from ground surface), excess in/exfiltration, entry of water at riser, and solids accumulation.
	1-3 years	Check and clean septic tank filter. Pump septic when 1-3 to $\frac{1}{4}$ of the liquid capacity of the tank is occupied by solids.
Pump or Dosing Tank	6-12 months	Check riser conditions (must be accessible from ground surface), excess in/exfiltration, entry of water at riser, and solids accumulation. Pump sludge accumulation as required and when septic tank is pumped. Check pump(s), controls, floats, electrical connections, and alarm for proper operation. Wash (hose) sludge accumulation from pump housing.
Supply Lines (Manifold)	6-12 months	Check for settling, pipe exposure and leakage
Ground Absorption Field	1-4 weeks 6-12 months	Maintain vegetative cover (mow grass and remove weeds and brush). Check for settling, erosion and surfacing effluent. Check site drainage, eliminate low or settled areas and divert surface or shallow groundwater movement around fields.
Pressure Manifold	6-12 months	Flush sludge from pressure manifold (any discharge sludge and effluent is to be treated with a chlorine solution). Check and reset pressure head.
General	At all times	Prohibit vehicular or equipment traffic on ground absorption field. Prohibit tillage (gardening) or other soil disturbance over septic field. Practice water conservation to reduce wastewater load on system. Do not permit entry of grease and non-domestic waste to system. Use of garbage disposal is prohibited. Addition of chemical or biological additives has <u>not</u> been demonstrated to be necessary to maintain proper system function. Prevention of root intervention on lateral lines and trenches may be necessary on certain sites. Surface and groundwater diversion structures must be maintained.

PREVENTIVE MAINTENANCE RECORD

Your Septic System Pumper

Name: _____

Address: _____

Phone: _____ Email: _____

Date System Installed:



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER SIA Group, Inc. 827 Gum Branch Road Jacksonville NC 28540	CONTACT NAME: Certificate Administrator	FAX (A/C, No): 910-455-7481
	PHONE (A/C, No, Ext): 910-455-7576	
INSURED David Brantley & Sons, Inc. 37 Pine Ridge Road Zebulon NC 27597	E-MAIL ADDRESS: certs@siagroup.com	
	INSURER(S) AFFORDING COVERAGE	
	INSURER A : Owners Insurance Company	
	INSURER B : Auto-Owners Insurance Company	
	INSURER C : FFVA Mutual Insurance Co.	
	INSURER D :	
	INSURER E :	
INSURER F :		
	NAIC #	
	32700	
	18988	
	10385	

COVERAGES

CERTIFICATE NUMBER: 1515141711

REVISION NUMBER:

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE			ADDL INSD	SUBR WVD	POLICY NUMBER		POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS								
A	COMMERCIAL GENERAL LIABILITY					35506165		7/2/2025	7/2/2026	EACH OCCURRENCE	\$ 1,000,000							
	CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR									DAMAGE TO RENTED PREMISES (Ea occurrence)	\$ 300,000							
										MED EXP (Any one person)	\$ 10,000							
										PERSONAL & ADV INJURY	\$ 1,000,000							
	GEN'L AGGREGATE LIMIT APPLIES PER:									GENERAL AGGREGATE	\$ 2,000,000							
	POLICY <input checked="" type="checkbox"/> PROJECT <input type="checkbox"/> LOC									PRODUCTS - COMP/OP AGG	\$ 2,000,000							
	OTHER:										\$							
A	AUTOMOBILE LIABILITY					5391466100		7/2/2025	7/2/2026	COMBINED SINGLE LIMIT (Ea accident)	\$ 1,000,000							
	ANY AUTO <input checked="" type="checkbox"/>									BODILY INJURY (Per person)	\$							
	OWNED AUTOS ONLY <input type="checkbox"/> SCHEDULED AUTOS									BODILY INJURY (Per accident)	\$							
	HIRED AUTOS ONLY <input checked="" type="checkbox"/> NON-OWNED AUTOS ONLY									PROPERTY DAMAGE (Per accident)	\$							
											\$							
											\$							
B	<input checked="" type="checkbox"/> UMBRELLA LIAB		<input checked="" type="checkbox"/> OCCUR			5391466101		7/2/2025	7/2/2026	EACH OCCURRENCE	\$ 3,000,000							
	EXCESS LIAB		<input type="checkbox"/> CLAIMS-MADE							AGGREGATE	\$ 3,000,000							
	DED <input type="checkbox"/>	<input checked="" type="checkbox"/> RETENTION \$ 10,000									\$							
C	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY			Y/N	N/A	WC850-0050098-2025A		7/2/2025	7/2/2026	<input checked="" type="checkbox"/> PER STATUTE	OTH-ER							
	ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED?									E.L. EACH ACCIDENT	\$ 1,000,000							
	(Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below									E.L. DISEASE - EA EMPLOYEE	\$ 1,000,000							
										E.L. DISEASE - POLICY LIMIT	\$ 1,000,000							
A	Contractors Equipment					35506165		7/2/2025	7/2/2026	Leased/Rented	\$50,000							

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)

CERTIFICATE HOLDER

CANCELLATION

Hal Owen & Associates
PO Box 400
Lillington NC 27546

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.

AUTHORIZED REPRESENTATIVE

Diana Evans

© 1988-2015 ACORD CORPORATION. All rights reserved.